

REPORT ID: **17283.01.T36.RP1**

---

## **North Kent Wind 1 LP – Turbine T36**


### **IEC 61400-11 Edition 3.0 Measurement Report**

---


Prepared for:

**North Kent Wind 1 LP**  
2050 Derry Road West, 2nd Floor  
Mississauga, Ontario  
L5N 0B9


Prepared by:



**Daniel Eduardo Adarve Villanueva, B. Eng., E.I.T.**



**Addie Denison, B.A.Sc., P.Eng.**



**Payam Ashtiani, B.A.Sc., P.Eng.**

19 July 2019 – Revision 2



## Revision History

Revision Number	Description	Date
1	Issued test report	20 March 2019
2	Corrections to Microphone Distance, Figure B.1 and Table 1	19 July 2019

**This report in its entirety, including appendices contains 106 pages.**

## Statement Qualifications and Limitations

This report was prepared by Aercoustics Engineering Limited in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), "Wind turbine generator systems – Part 11: Acoustic noise measurement techniques". This report is specific only to the Wind Turbine identified in this report.

Aercoustics Engineering Limited shall not be responsible for any events or circumstances that may have occurred since the date on which the Wind Turbine was tested and/or this report was prepared, or for any inaccuracies contained in information that was provided to Aercoustics Engineering Limited. Further, Aercoustics Engineering Limited agrees that this report represents test data analysed as per the above described standard for the specific Wind Turbine described in this report, but Aercoustics Engineering Limited makes no other representations with respect to this report or any part thereof.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Aercoustics Engineering Limited accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Any use of this report is subject to this Statement of Qualifications and Limitations. Any damages arising from improper use of this report or parts thereof shall be borne by the party making such use.

This Statement of Qualifications and Limitations is attached to and forms part of this report.

## Table of Contents

<b>Revision History</b>	<b>2</b>
<b>Statement Qualifications and Limitations</b>	<b>2</b>
<b>List of Appendices</b>	<b>4</b>
<b>1      Introduction</b>	<b>6</b>
<b>2      Wind Turbine Information</b>	<b>6</b>
2.1    Wind Turbine Equipment Details.....	6
2.2    Wind Turbine Location.....	7
<b>3      Measurement Details</b>	<b>8</b>
3.1    Measurement Equipment.....	8
3.1.1    Acoustic Measurement Equipment.....	8
3.1.2    Non-Acoustic Measurement Equipment .....	8
3.2    Measurement Setup .....	8
3.2.1    Microphone Placement.....	8
3.2.2    Double Windscreen Setup.....	9
3.3    Measurement Periods.....	9
3.4    Meteorological Conditions.....	9
3.5    Turbine operational information .....	10
<b>4      Measurement Results</b>	<b>10</b>
4.1    Deviations from IEC-61400-11 Edition 3.0 .....	10
4.2    Special Notes & Considerations.....	10
4.3    Analysis Methodology .....	10
4.3.1    Double Windscreen Adjustment .....	10
4.3.2    Wind Speed Correction .....	10
4.4    Type B uncertainties .....	11
4.5    Sound Pressure Level Measurements .....	11
4.6    Sound Power Level of Turbine.....	12
4.7    Tonality Analysis.....	13
<b>5      Closure</b>	<b>13</b>
<b>6      References</b>	<b>13</b>

## List of Appendices

Appendix A Site Details	
Figure A.01	Site Plan
Figure A.02	Site Photos
Appendix B Turbine Information	
Figure B.01	Power Curve
Figure B.02	Rotor RPM vs. Wind Speed
Table B.01	Allowed range of power curve and required wind speeds
Appendix C Apparent Sound Power Level	
Figure C.01	Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)
Figure C.02	Plot of measured total noise vs. electrical power output
Figure C.03	Plot of power curve relative to nacelle anemometer and 10 m anemometer
Figure C.04	Plot of rotor RPM vs. electrical power output
Figure C.05	Plot of sound pressure spectrum in 1/3 octave at 7.5 m/s
Figure C.06	Plot of sound pressure spectrum in 1/3 octave at 8 m/s
Figure C.07	Plot of sound pressure spectrum in 1/3 octave at 8.5 m/s
Figure C.08	Plot of sound pressure spectrum in 1/3 octave at 9 m/s
Figure C.09	Plot of sound pressure spectrum in 1/3 octave at 9.5 m/s
Figure C.10	Plot of sound pressure spectrum in 1/3 octave at 10 m/s
Figure C.11	Plot of sound pressure spectrum in 1/3 octave at 10.5 m/s
Figure C.12	Plot of sound pressure spectrum in 1/3 octave at 11 m/s
Figure C.13	Plot of sound pressure spectrum in 1/3 octave at 11.5 m/s
Figure C.14	Plot of sound pressure spectrum in 1/3 octave at 12 m/s
Figure C.15	Plot of sound pressure spectrum in 1/3 octave at 12.5 m/s
Table C.01	Detailed apparent sound power level data at hub height
Table C.02	Detailed apparent sound power level data at 10 m height
Table C.03	Type B measurement uncertainty summary
Table C.04	Detailed measurement uncertainty at hub height
Table C.05	Secondary Windscreen Influence

## ***List of Appendices (cont'd)***

Appendix D Tonality Assessment	
Figure D.01	Plot of narrow band spectra - Turbine ON vs. Background at 7.5 m/s
Figure D.02	Plot of narrow band spectra - Turbine ON vs. Background at 8 m/s
Figure D.03	Plot of narrow band spectra - Turbine ON vs. Background at 8.5 m/s
Figure D.04	Plot of narrow band spectra - Turbine ON vs. Background at 9 m/s
Figure D.05	Plot of narrow band spectra - Turbine ON vs. Background at 9.5 m/s
Figure D.06	Plot of narrow band spectra - Turbine ON vs. Background at 10 m/s
Figure D.07	Plot of narrow band spectra - Turbine ON vs. Background at 10.5 m/s
Figure D.08	Plot of narrow band spectra - Turbine ON vs. Background at 11 m/s
Figure D.09	Plot of narrow band spectra - Turbine ON vs. Background at 11.5 m/s
Figure D.10	Plot of narrow band spectra - Turbine ON vs. Background at 12 m/s
Figure D.11	Plot of narrow band spectra - Turbine ON vs. Background at 12.5 m/s
Table D.01	Tonality Assessment Table – 7.5 m/s
Table D.02	Tonality Assessment Table - 8 m/s
Table D.03	Tonality Assessment Table – 8.5 m/s
Table D.04	Tonality Assessment Table - 9 m/s
Table D.05	Tonality Assessment Table – 9.5 m/s
Table D.06	Tonality Assessment Table - 10 m/s
Table D.07	Tonality Assessment Table – 10.5 m/s
Table D.08	Tonality Assessment Table - 11 m/s

Appendix E Measurement Data	
Table E.01	Measurement Data - Turbine ON
Table E.02	Measurement Data - Background

Appendix F Supplementary Information for the Regulators	
Appendix F.01	Calibration Certificates
Appendix F.02	Summary of Measurement Results
Appendix F.03	E-Audit Checklist

## 1 Introduction

Aercoustics Engineering Limited (“Aercoustics”) was retained by North Kent Wind 1 LP to conduct testing per the IEC 61400-11 test standard on one of the wind turbines, designated as T36, located in the North Kent Wind 1 Project. The measurements were carried out in accordance with IEC 61400-11:2012, “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to turbine T36.

Aercoustics is accredited by the Standards Council of Canada under ISO/IEC 17025 to perform testing according to the IEC 61400-11 test standard.

## 2 Wind Turbine Information

### 2.1 Wind Turbine Equipment Details

Equipment information specific to turbine T36 was provided by the manufacturer and is summarized in Tables 1 to 5.

Table 1 – Wind Turbine Details

Wind Turbine Details	
Manufacturer	Siemens Gamesa Renewable Energy
Model Number	SWT 2.772-113
Turbine ID	T36

Table 2 – Operating Details

Operating Details	
Vertical or Horizontal axis wind turbine	Horizontal
Upwind or downwind rotor	Upwind rotor
Hub height	99.5 m
Horizontal distance from rotor centre to tower axis	5.5 m
Diameter of rotor	113 m
Tower type (lattice or tube)	Tubular
Passive stall, active stall, or pitch controlled turbine	Pitch controlled turbine
Constant or variable speed	Variable speed
Power curve	Rev 0
Rotational speed at each integer standardised wind speed	Max speed, 13.2 rpm
Rated power output	2772 kW
Control software version	133.0.0.6

Table 3 – Rotor Details

Rotor Details	
Rotor control devices	Pitch control
Presence of aerodynamic add-ons, such as vortex generators, stall strips, serrated trailing edges, etc.	Vortex generators and Dinotails
Blade type	B55
Serial number	Blade A: 550275501 Blade B: 550276301 Blade C: 550274901
Number of blades	3

Table 4 – Gearbox Details

Gearbox Details	
Manufacturer	N/A Direct drive
Model number	N/A Direct drive
Serial number	N/A Direct drive

Table 5 – Generator Details

Generator Details	
Manufacturer	Siemens
Model number	DD22_02
Serial number	5100241526

## 2.2 Wind Turbine Location

Turbine T36 is located in the municipality of Chatham-Kent near the town of Chatham-Kent, approximately 805 m East of St. Clair Road, and 865 m South of Eberts Line. The area surrounding T36 is flat and consists primarily of farmland.

A general layout of the area in which the turbine is located is provided in the site plan (Figure A.01).

### **3 Measurement Details**

#### **3.1 Measurement Equipment**

##### **3.1.1 Acoustic Measurement Equipment**

Details regarding the acoustic measurement equipment utilized for the test is summarized in Table 6.

Table 6 – Acoustic Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Acoustic Data acquisition system	SIEMENS SCR202	22163146
Microphone	B&K 4189	2625417
Pre-amplifier	B&K 2671	2614900
Acoustic calibrator	B&K 4231	3012380

A field calibration of the measurement chain was performed at the beginning and end of each measurement day.

##### **3.1.2 Non-Acoustic Measurement Equipment**

Non-acoustic measurement equipment includes an anemometer installed 10 meters above ground level (“10-m AGL”) as well any sensing equipment utilized by the wind turbine to measure and record operational parameters. The 10-m AGL anemometer is provided by Aeroustics while the turbine sensing equipment is a part of the turbine installation.

Details regarding the non-acoustic measurement equipment utilized and controlled by Aeroustics is summarized in Table 7. Equipment used to measure turbine parameters, such as yaw angle and power output, are outside of Aeroustics’ control and are not reported here.

Table 7 – Meteorological Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Anemometer	VAISALA WXT520	G4420002
Serial to Analog Converter	NOKEVAL 7470	A159784

#### **3.2 Measurement Setup**

##### **3.2.1 Microphone Placement**

The measurement microphone was setup 156 meters from the base of the turbine in a downwind position (Position 1, per IEC 61400-11), at an elevation of 0 meters relative to the base of T36. The slant distance ( $R_1$ ) from microphone location to rotor centre includes

the distance from rotor center to tower axis ( $R_1 = 189.7$  m). The microphone was placed in the centre of a circular, acoustically reflective board.

During the measurement period, data points were used only when the microphone was within 15 degrees of the downwind direction from the turbine. The microphone position relative to downwind is monitored via the turbine yaw angle provided from the turbine SCADA system (discussed further in Section 3.5).

During the test, the land surrounding the turbine was a plowed field. No crops or vegetation were in the nearby area which would influence the results of the measurement. There were no nearby reflecting surfaces (houses, barns etc.); as such the influence from reflecting surfaces is negligible.

Photos of the measurement setup are provided in Figure A.02, Appendix A.

### 3.2.2 Double Windscreen Setup

A double windscreen setup was utilized for the first measurement day on November 28, 2019. Documentation of how the secondary windscreen affects the overall sound pressure level and 1/3 Octave Band spectrum in comparison to a single windscreen setup is provided in Appendix C.

The secondary windscreen used meets the performance criterion specified in Annex E (Characterization of a secondary wind screen) of IEC-61400-11:2012.

## 3.3 Measurement Periods

Table 8 – Summary of Measurement Periods

Date	Test Type	Start Time	Finish time
November 28, 2018	Turbine ON	1:18 PM	2:01 PM
	Background	2:02 PM	2:35 PM
	Turbine ON	2:42 PM	3:26 PM
	Background	3:26 PM	3:58 PM
January 9, 2019	Turbine ON	11:32AM	12:03 PM
	Background	12:06 PM	12:36 PM
	Turbine ON	12:43 PM	1:45 PM
	Background	1:48PM	2:11PM
	Turbine ON	2:17PM	2:30PM
	Background	2:32PM	3:25PM

### 3.4 Meteorological Conditions

The normalised hub height wind speed during Turbine ON periods is either derived directly using the turbine power curve and measured power output (Section 8.2.1.1 of [1]) or indirectly using the measured wind speed from the nacelle anemometer and applying a correction factor (Section 8.2.1.2 of [1]). Wind speeds during Background periods are measured using the 10-m AGL anemometer and corrected to hub-height using a

correction factor (Section 8.2.2 of [1]). The downwind direction is determined using the turbine yaw angle output, also known as the nacelle position (Section 8.3 of [1]).

Other atmospheric conditions, including ambient temperature and atmospheric pressure, are measured by the 10-m AGL anemometer during the measurement periods.

Detailed meteorological data relevant to the measurement is provided in Appendix E.

### 3.5 Turbine operational information

Turbine operational parameters – including electrical power, nacelle position (yaw angle), rotational speed, and nacelle wind speed – are acquired from the turbine controller simultaneously with the acoustic and weather measurement data using Aeroustics' data acquisition system.

## 4 Measurement Results

### 4.1 Deviations from IEC-61400-11 Edition 3.0

No deviations.

### 4.2 Special Notes & Considerations

No adjacent turbines were parked during the test.

### 4.3 Analysis Methodology

The following section outlines any corrections applied to the acoustic or weather measurement data, per IEC 61400-11. Transient events, such as vehicle traffic, wildlife, or air traffic, are excluded from the measurement data set.

#### 4.3.1 Double Windscreen Adjustment

As previously mentioned, a double wind screen was used, as such; the measurement data was adjusted on a per-data-point basis, as appropriate, to account for its influence. All 1/3 Octave Band spectrum and overall level data presented in this report is based on data that has been adjusted appropriately for the influence of the secondary wind screen.

FFT spectral data used for the tonality assessment was not adjusted. However, it should be noted that the effect of the windscreens on the tonality assessment is considered to be negligible.

No double wind screen was utilized for the second measurement run, as such the measurement data did not require adjustment.

#### 4.3.2 Wind Speed Correction

Following the methodology described in Section 8.2 of [1] and summarized in Section 0 of this report, two correction factors are derived from the measurement data and used to

determine the normalized hub-height wind speed in certain conditions. The first correction factor ( $k_{nac}$ ) is used to correct nacelle wind speeds measured for intervals that fall outside of the allowable power curve range. The second correction factor ( $k_Z$ ) is used to correct 10m-AGL wind speeds measured during Background measurement periods up to hub-height.

The k-factors for this measurement set are provided in Table 9.

Table 9 – Calculated nacelle anemometer ( $k_{nac}$ ) and 10m ( $k_Z$ ) wind speed k-factor

$k_{nac}$	$k_Z$
0.97	1.20

#### 4.4 Type B uncertainties

Type B uncertainties were obtained through interpretation of the information provided in Annex C of [1]. A summary of Type B uncertainties is provided in Table 10, while detailed information, including uncertainties by 1/3 octave band, is provided in Appendix C.

Table 10 – Summary of Type B uncertainties

Component	Typical (dB)	Used (dB)
Calibration	0.2	0.2
Board	0.3	0.3
Distance & direction	0.1	0.1
Air absorption	0	0
Weather conditions	0.5	0.5
Wind speed measured	0.7	0.7
Wind speed derived	0.2	0.2
Wind speed from power curve	0.2	0.2

#### 4.5 Sound Pressure Level Measurements

Average overall sound pressure levels in each wind bin for Turbine ON and Background periods are summarized in Table 11. Average sound levels and uncertainties by 1/3 octave band are provided in Appendix C. A copy of the measurement data used for analysis is provided in Appendix E.

Table 11 – Summary of Sound Pressure Level Measurements

Wind Speed (m/s)	Turbine ON		Background		Turbine ON, Background adjusted L <sub>eq</sub> , (dBA)
	L <sub>eq</sub> , (dBA)	# of data pts	L <sub>eq</sub> , (dBA)	# of data pts	
7.5	51.1	26	39.6	67	50.8
8	52.6	31	41.0	68	52.3
8.5	53.1	57	41.9	52	52.8
9	53.2	75	42.9	75	52.8
9.5	53.3	110	44.4	78	52.7
10	53.1	82	44.5	67	52.5
10.5	53.1	108	44.7	86	52.5
11	52.9	105	46.0	66	52.1
11.5	52.8	90	46.2	52	51.8
12	52.8	57	46.3	53	51.8
12.5	52.6	31	46.0	46	51.6

#### 4.6 Sound Power Level of Turbine

The calculated apparent sound power level at hub height is summarized in Table 12. Corresponding sound power levels for 10-meter height wind speeds are provided in Table 13. Wind speeds at 10 meters are calculated using the wind shear profile described in Section 9.4 of [1]. Sound power levels by 1/3 octave band are provided in Appendix C.

Table 12 – L<sub>WA, K</sub> at each integer wind speed

Wind Speed (m/s)	Apparent L <sub>WA</sub> , (dBA)	Uncertainty (dB)
7.5	101.4	0.8
8	102.9	0.7
8.5	103.3	0.8
9	103.3	0.9
9.5	103.2	0.9
10	103.1	0.9
10.5	103.0	0.9
11	102.6	1.0
11.5	102.4	1.0
12	102.4	1.0
12.5	102.1	1.0

Table 13 – L<sub>WA 10m, K</sub> at each integer wind speed

Wind Speed (m/s)	Apparent L <sub>WA</sub> , (dBA)	Uncertainty (dB)
5	100.6	1.0
6	103.1	0.8
7	103.1	0.9
8	102.5	0.9
9	102.4	1.2

#### 4.7 Tonality Analysis

The tonality analysis for turbine T36 is summarized in Table 14, while plots of narrow band spectra at each wind speed are provided in Appendix D. All  $\Delta L_{tn}$  and  $\Delta L_a$  values reported represent the energy average of all data points with an identified tone that fall within the same frequency of origin (Section 9.5.8 of [1]).

The narrow band spectra provided in the plots represents an energy average of all data points in the given wind speed bin for both Turbine ON and Background.

Table 14 – Tonality Assessment Summary

Wind Speed (m/s)	Frequency (Hz)	Tonality, $\Delta L_{tn}$ (dB)	Tonal audibility, $\Delta L_a$ (dB)	FFT's with tones	Total # of FFT's	Presence (%)
7.5	64	-4.7	-2.7	25	26	96%
8	71	-2.0	0.0	28	31	90%
8.5	70	-1.9	0.1	57	57	100%
9	70	-1.2	0.8	74	75	99%
9.5	70	-1.7	0.3	104	110	95%
10	68	-3.2	-1.2	68	82	83%
10.5	66	-3.8	-1.8	68	108	63%
11	66	-4.2	-2.2	82	105	78%

## 5 Closure

Measurements and analyses per IEC 61400-11:2012 (Edition 3.0) were performed on turbine T36 of the North Kent Wind 1 Project, located in the municipality of Chatham-Kent, Ontario. The test turbine was found to have a maximum apparent sound power level of 103.3 dBA and a maximum tonal audibility of 0.8 dB.

Supplementary information to address specific local regulatory requirements are attached separately in Appendix F.

Should you have any questions or comments please contact the authors of this report.


## 6 References

- [1] IEC 61400-11 , *Wind Turbines - Part 11: Acoustic noise measurement techniques*, International Electrotechnical Commission, 2012.

---

## Appendix A Site Details

---



 aercoustics	170283.01.T36.RP2	Project Name North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	Figure Title Site Plan

**Figure A.01**



 aercoustics

17283.01.T36.RP2  
Scale: NTS  
Drawn by: DEA  
Reviewed by: MAD  
Date: Feb 2019  
Revision: 1

**Project Name**

North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36

**Figure Title**

Site Photo

**Figure A.02**

---

## Appendix B Turbine Information

---

## Table B.01 Allowed range of power curve and required wind speeds

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement


Report ID: 17283.01.T36.RP2

Page 1 of 1


Created on: 2/21/2019

Power Curve & Required Wind Speeds		
Power Curve Tolerance	3%	
Acceptable range min	4	m/s
Acceptable range max	10	m/s
Min allowable range	4	m/s
Max allowable range	10	m/s
Power Output	2772	kW
85% Power	2356.2	kW
Corresponding wind speed	9.64	m/s
Minimum bin	7.5	m/s
Maximum bin	12.5	m/s

Power Curve (+ value = acceptable)		
Hub Wind Speed (m/s)	Power [kW]	Slope of Power Curve
0	0	-166.32
1	0	-166.32
2	0	-104.32
3	62	-61.32
4	167	11.68
5	345	102.68
6	614	209.68
7	990	324.68
8	1481	403.68
9	2051	312.68
10	2530	30.68
11	2727	-125.32
12	2768	-162.32
13	2772	-166.32
14	2772	-166.32
15	2772	-166.32
16	2772	-166.32
17	2772	-166.32
18	2772	-166.32
19	2772	-166.32
20	2772	-166.32
21	2772	-166.32
22	2772	-193.32
23	2745	-194.32
24	2717	-419.32
25	2464	



 aercoustics	17283.01.T36.RP1	Project Name
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: July 2019 Revision: 1	North Kent Wind 1 LP - IEC 61400-11 Edition 3.0 - Turbine T36
	Figure Title	Figure B.01
	Power Curve	



■ Rotor Speed vs. Hub Height Wind Speed

 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Rotor RPM vs. Wind Speed
		<b>Figure B.02</b>

---

## Appendix C Apparent Sound Power Level

---

Table C.01 Detailed apparent sound power level data at hub height

Project: North Kent Wind Farm - Turbine T36 - IEC 61400-11 Measurement

Report ID: 172831.01.T36.RP2

Page 1 of 2

Created on: 2/22/2019

1/3 Octave values marked with brackets [ ] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk \* denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

# Table C.01 Detailed apparent sound power level data at hub height

Project: North Kent Wind Farm - Turbine T36 - IEC 61400-11 Measurement

Report ID: 172831.01.T36.RP2

Page 2 of 2

Created on: 2/22/2019

1/3 Octave values marked with brackets [ ] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk \* denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																								Overall					
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
10.5	Turbine ON (dBA)	16.7	20.9	22.9	25.4	28.1	32.7	33.7	33.4	34.7	36.0	38.6	39.2	39.1	40.8	42.1	42.8	43.4	43.3	42.7	41.4	40.2	43.4	38.7	31.4	28.1	24.5	23.9	22.7	53.1	
	Background (dBA)	17.9	21.1	23.3	25.4	27.6	29.8	30.9	31.3	32.0	33.2	34.2	34.9	35.0	34.7	33.7	32.7	31.7	30.7	29.2	27.9	26.1	23.4	21.1	19.3	18.4	16.5	15.8	12.9	44.7	
	Turbine ON - background adj (dBA)	13.7	17.9	19.9	22.4	25.1	29.7	30.7	30.4	31.7	33.0	36.6	37.2	37.0	39.6	41.4	42.4	43.1	43.1	42.5	41.2	40.1	43.3	38.6	31.2	27.6	23.8	23.1	22.3	52.5	
	Signal to noise (dB)	-1.3	-0.2	-0.4	0.0	0.5	3.0	2.8	2.2	2.7	2.9	4.4	4.4	4.1	6.1	8.4	10.2	11.8	12.6	13.5	13.5	14.2	20.0	17.6	12.1	9.7	8.0	8.1	9.8	8.4	
	Uncertainty (dB)	4.6	3.8	2.7	3.5	2.5	2.2	2.0	2.0	2.0	1.2	1.3	1.3	1.0	0.8	0.8	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.1	1.3	1.8	2.2	0.9		
	PWL (dBA)	64.2	68.4	70.4	73.0	75.7	80.3	81.2	81.0	82.3	83.6	87.2	87.8	87.6	90.2	91.9	93.0	93.7	93.6	93.1	91.7	90.6	93.9	89.2	81.7	78.1	74.3	73.7	72.8	103.0	
11.0	Turbine ON (dBA)	17.9	21.6	23.7	26.3	28.9	33.3	34.2	34.0	35.1	36.3	38.5	39.2	39.3	40.8	41.7	42.4	43.1	43.2	42.7	41.4	40.2	42.8	38.2	31.0	27.4	23.1	21.1	19.2	52.9	
	Background (dBA)	19.6	22.8	24.9	27.2	29.1	30.9	32.2	32.7	33.6	34.6	35.7	36.3	36.5	36.0	35.1	34.0	32.7	31.3	29.1	27.5	25.6	23.6	21.4	19.8	18.9	16.9	16.2	13.4	46.0	
	Turbine ON - background adj (dBA)	14.9	18.6	20.7	23.3	25.9	30.3	31.2	31.0	32.1	33.3	35.5	36.2	36.3	39.0	40.7	41.8	42.7	42.9	42.5	41.2	40.1	42.7	38.1	30.6	26.7	22.0	19.4	17.9	52.1	
	Signal to noise (dB)	-1.7	-1.1	-1.2	-0.9	-0.2	2.3	2.1	1.3	1.6	1.7	2.8	2.9	2.9	4.7	6.6	8.5	10.5	11.9	13.6	13.9	14.7	19.2	16.8	11.2	8.5	6.3	4.9	5.8	7.0	
	Uncertainty (dB)	4.7	3.8	2.7	3.6	2.5	2.2	2.0	2.0	2.0	1.7	1.7	1.7	1.2	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.2	1.2	1.5	2.2	2.5	1.0		
	PWL (dBA)	65.4	69.2	71.3	73.9	76.4	80.8	81.8	81.5	82.7	83.9	86.1	86.8	86.9	89.6	91.2	92.3	93.3	93.5	93.0	91.8	90.6	93.3	88.7	81.2	77.3	72.5	69.9	68.5	102.6	
11.5	Turbine ON (dBA)	20.0	24.1	26.2	28.3	30.6	34.2	35.3	35.0	36.2	37.3	38.9	39.8	40.1	41.0	41.5	41.8	42.5	42.8	42.4	41.3	39.9	42.0	37.6	30.0	26.1	21.4	19.5	16.7	52.8	
	Background (dBA)	19.3	22.8	25.5	27.1	29.2	31.1	32.3	32.9	33.6	34.9	35.9	36.5	36.7	36.2	35.4	34.3	32.9	31.6	29.4	27.8	26.0	24.1	22.0	20.5	19.5	17.6	16.8	14.0	46.2	
	Turbine ON - background adj (dBA)	17.0	21.1	23.2	25.3	27.6	31.3	32.3	32.0	33.2	34.3	35.9	37.1	37.4	39.2	40.3	41.0	42.0	42.5	42.2	41.1	39.7	41.9	37.5	29.4	25.1	18.9	16.5	13.7	51.8	
	Signal to noise (dB)	0.7	1.3	1.1	1.2	1.4	3.1	2.9	2.1	2.6	2.3	3.0	3.3	3.4	4.8	6.1	7.5	9.6	11.2	13.0	13.5	13.9	17.9	15.6	9.5	6.7	3.7	2.7	6.6		
	Uncertainty (dB)	4.6	3.8	2.7	3.6	2.5	2.2	2.0	2.0	2.0	1.7	1.6	1.6	1.2	1.0	0.9	0.8	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.2	1.3	2.1	3.2	3.9	1.0	
	PWL (dBA)	67.6	71.7	73.7	75.9	78.2	81.8	82.8	82.6	83.7	84.8	86.4	87.6	88.0	89.8	90.8	91.5	92.5	93.0	92.7	91.7	90.3	92.5	88.1	80.0	75.6	69.5	67.1	64.3	102.4	
12.0	Turbine ON (dBA)	20.2	24.0	26.3	28.9	31.0	34.4	35.8	35.2	36.3	37.1	38.8	39.6	39.8	40.9	41.4	41.8	42.5	42.8	42.4	41.5	40.1	41.6	37.5	30.4	26.8	23.2	22.3	20.8	52.8	
	Background (dBA)	20.0	23.2	25.5	27.3	29.4	31.4	33.0	33.1	33.9	35.0	36.1	36.8	36.9	36.4	35.4	34.1	32.7	31.1	28.6	26.7	25.0	23.0	20.7	19.1	18.4	16.3	16.0	13.0	46.3	
	Turbine ON - background adj (dBA)	17.2	21.0	23.3	25.9	28.0	31.4	32.8	32.2	33.3	34.1	35.8	36.6	36.8	38.9	40.2	41.0	42.0	42.6	42.4	41.4	39.9	41.5	37.4	30.0	26.1	22.3	21.2	20.0	51.8	
	Signal to noise (dB)	0.2	0.8	1.6	1.6	3.0	2.7	2.2	2.4	2.1	2.7	2.7	2.9	4.4	6.0	7.7	9.8	11.8	13.9	14.8	15.1	18.6	16.8	11.2	8.4	6.9	6.3	7.7	6.5		
	Uncertainty (dB)	4.6	3.8	2.7	3.6	2.6	2.2	2.0	2.0	1.9	1.6	1.7	1.7	1.2	1.0	0.9	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.2	1.2	1.5	2.1	2.4	1.0		
	PWL (dBA)	67.7	71.6	73.9	76.5	78.5	82.0	83.3	82.8	83.8	84.7	86.3	87.1	87.3	89.5	90.8	91.5	92.6	93.1	92.9	91.9	90.5	92.1	88.0	80.6	76.7	72.8	71.7	70.5	102.4	
12.5	Turbine ON (dBA)	20.5	24.2	27.2	29.0	31.5	34.5	35.9	35.7	36.7	37.7	39.0	39.7	40.2	41.0	41.2	41.3	41.9	42.5	42.2	41.2	39.8	41.2	36.7	29.4	25.6	20.7	18.4	15.0	52.6	
	Background (dBA)	19.9	23.0	25.1	27.0	28.9	31.1	32.3	32.9	33.7	34.8	35.8	36.6	36.6	36.0	35.0	33.9	32.4	30.9	28.4	26.5	24.9	23.0	20.7	19.3	18.4	16.3	16.2	13.0	46.0	
	Turbine ON - background adj (dBA)	17.5	21.2	24.2	26.0	28.5	31.9	33.3	32.7	33.8	34.7	36.2	36.9	37.6	39.3	40.0	40.5	41.4	42.1	42.0	41.1	39.7	41.2	36.5	28.9	24.7	18.7	15.4	12.0	51.6	
	Signal to noise (dB)	0.6	1.2	2.1	2.0	2.5	3.4	3.5	2.8	3.1	2.8	3.2	3.2	3.6	5.0	6.2	7.5	9.6	11.6	13.8	14.7	14.9	18.2	15.9	10.1	7.2	4.4	2.2	2.0	6.6	
	Uncertainty (dB)	4.2	3.5	2.6	3.3	2.4	1.8	1.6	1.9	1.8	1.8	1.5	1.6	1.4	1.1	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	1.0	1.1	1.2	1.7	2.9	3.6	1.0
	PWL (dBA)	68.1	71.8	74.7	76.6	79.0	82.4	83.9	83.3	84.3	85.2	86.8	87.4	88.2	89.8	90.6	91.0	92.0	92.7	92.5	91.6	90.2	91.7	87.1	79.5	75.2	69.3	66.0	62.6	102.1	

## Table C.02 Detailed apparent sound power level data at 10m height

Project: North Kent Wind Farm - Turbine T36 - IEC 61400-11 Measurement

Report ID: 172831.01.T36.RP2

Page 1 of 1

Created on: 2/22/2019

1/3 Octave values marked with brackets [ ] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk \* denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																								Overall					
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
5.0	Turbine ON (dBA)	7.6	11.6	16.0	21.4	24.0	31.8	28.4	31.4	32.4	31.8	36.3	37.0	36.2	37.9	39.7	40.8	41.4	40.5	40.5	39.1	39.4	38.6	32.1	28.5	24.0	18.2	10.7	7.2	50.5	
	Background (dBA)	6.6	9.6	12.2	15.5	18.5	21.6	21.5	21.5	21.9	22.7	24.1	24.7	25.1	25.8	26.5	29.8	30.8	30.5	31.8	30.9	26.2	21.5	18.2	15.3	12.5	11.6	10.4	8.1	39.7	
	Turbine ON - background adj (dBA)	4.6	8.6	13.7	20.2	22.6	31.4	27.3	30.9	32.0	31.3	36.1	36.7	35.8	39.5	40.5	41.0	40.0	39.9	38.3	39.2	38.5	31.9	28.3	23.7	17.1	7.7	4.2	50.1		
	Signal to noise (dB)	1.0	2.1	3.8	5.9	5.5	10.3	6.8	9.9	10.5	9.2	12.2	12.3	11.1	12.1	13.2	11.0	10.6	10.0	8.7	8.1	13.2	17.1	13.9	13.2	11.5	6.6	0.4	-0.9	10.8	
	Uncertainty (dB)	5.0	4.2	2.0	2.4	1.8	1.2	1.3	1.1	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	1.0	1.1	1.1	0.9	1.0	1.3	1.3	1.6	3.4	4.3	1.0	1.0
	PWL (dBA)	55.1	59.2	64.3	70.7	73.1	82.0	77.9	81.5	82.5	81.8	86.6	87.3	86.4	88.1	90.1	91.0	91.5	90.6	90.4	88.9	89.7	89.1	82.5	78.8	74.3	67.7	58.3	54.8	100.6	
6.0	Turbine ON (dBA)	11.9	16.0	19.4	22.8	26.2	33.2	34.3	32.5	33.7	35.2	38.4	39.1	38.7	40.6	42.2	43.2	43.7	43.2	42.9	41.3	40.2	42.4	37.4	30.6	26.7	21.1	15.0	11.5	52.9	
	Background (dBA)	14.0	17.4	19.9	22.0	23.9	26.5	27.7	28.1	28.8	29.3	30.3	31.0	31.1	30.9	30.4	30.8	31.5	30.7	31.2	29.9	25.9	22.7	20.0	17.5	16.3	14.0	13.2	10.5	42.2	
	Turbine ON - background adj (dBA)	8.9	13.0	16.4	19.8	23.2	32.1	33.2	30.5	32.0	33.8	37.6	38.3	37.8	40.1	41.9	42.9	43.4	43.0	42.6	41.0	40.0	42.4	37.3	30.4	26.3	20.1	12.0	8.5	52.6	
	Signal to noise (dB)	-2.1	-1.5	-0.6	0.8	2.2	6.7	6.6	4.4	4.9	5.8	8.0	8.1	7.6	9.7	11.8	12.3	12.2	12.5	11.7	11.4	14.3	19.7	17.4	13.1	10.5	7.1	1.8	1.0	10.7	
	Uncertainty (dB)	4.3	3.6	2.4	3.3	2.3	1.1	1.0	1.3	1.2	1.1	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.7	0.8	1.0	1.0	1.0	1.3	2.9	3.6	0.8	0.8
	PWL (dBA)	59.5	63.5	66.9	70.3	73.7	82.7	83.8	81.1	82.5	84.4	88.2	88.9	88.4	90.6	92.5	93.4	94.0	93.5	93.2	91.6	90.5	92.9	87.9	81.0	76.9	70.7	62.6	59.0	103.1	
7.0	Turbine ON (dBA)	15.9	20.0	22.3	24.9	27.7	33.2	34.2	33.4	34.9	36.3	38.9	39.5	39.3	41.0	42.2	43.0	43.5	43.3	42.8	41.3	40.3	43.3	38.4	31.4	27.9	23.8	22.7	21.5	53.2	
	Background (dBA)	17.5	20.8	23.0	25.2	27.4	29.7	30.5	31.3	32.5	32.8	33.9	34.5	34.7	34.3	33.5	32.7	31.9	31.0	30.5	29.1	26.6	23.5	21.2	19.3	18.3	16.5	15.8	13.3	44.7	
	Turbine ON - background adj (dBA)	12.9	17.0	19.3	21.9	24.7	30.7	31.7	30.4	31.9	33.6	37.3	37.8	37.4	39.9	41.6	42.5	43.2	43.0	42.5	41.1	40.1	43.3	38.3	31.1	27.4	22.9	21.7	20.8	52.5	
	Signal to noise (dB)	-1.6	-0.8	-0.7	-0.3	0.4	3.5	3.6	2.2	2.4	3.4	5.0	5.0	4.6	6.6	8.7	10.3	11.6	12.3	12.3	12.2	13.7	19.9	17.2	12.1	9.5	7.3	6.9	8.2	8.5	
	Uncertainty (dB)	4.5	3.8	2.5	3.5	2.4	1.9	1.6	1.9	1.9	1.7	1.1	1.1	1.2	0.9	0.8	0.8	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.1	1.3	1.8	2.1	0.9	0.9
	PWL (dBA)	63.5	67.5	69.8	72.4	75.3	81.2	82.3	81.0	82.4	84.2	87.8	88.4	87.9	90.5	92.2	93.1	93.7	93.5	93.0	91.6	90.7	93.9	88.9	81.6	77.9	73.4	72.3	71.3	103.1	
8.0	Turbine ON (dBA)	19.4	23.3	25.5	27.9	30.2	34.0	35.1	34.8	35.9	37.0	38.8	39.6	39.8	40.9	41.6	42.1	42.7	43.0	42.5	41.4	40.1	42.2	37.8	30.5	26.8	22.5	20.8	18.8	52.9	
	Background (dBA)	19.6	22.9	25.1	27.2	29.2	31.1	32.5	32.9	33.7	34.8	35.9	36.5	36.6	36.2	35.3	34.1	32.8	31.3	29.1	27.4	25.6	23.6	21.5	19.9	19.0	17.0	16.4	13.5	46.1	
	Turbine ON - background adj (dBA)	16.4	20.3	22.5	24.9	27.2	31.0	32.1	31.8	32.9	34.0	35.8	36.6	36.9	39.1	40.4	41.3	42.3	42.7	42.3	41.2	39.9	42.1	37.7	30.1	26.0	21.1	18.9	17.3	51.9	
	Signal to noise (dB)	-0.2	0.4	0.4	0.7	1.0	2.8	2.6	1.9	2.2	2.1	2.9	3.0	3.1	4.7	6.3	7.9	10.0	11.6	13.5	14.0	14.5	18.6	16.3	10.6	7.8	5.5	4.5	5.3	6.7	
	Uncertainty (dB)	4.3	3.5	2.4	3.3	2.3	2.0	1.8	1.8	1.8	1.5	1.5	1.5	1.1	0.9	0.8	0.7	0.8	0.8	0.7	0.8	1.0	1.1	1.1	1.5	2.1	2.4	0.9	0.9		
	PWL (dBA)	67.0	70.9	73.1	75.5	77.8	81.5	82.6	82.3	83.4	84.5	86.3	87.1	87.4	89.7	91.0	91.9	92.8	93.2	92.9	91.8	90.5	92.7	88.2	80.6	76.6	71.7	69.5	67.8	102.5	
9.0	Turbine ON (dBA)	21.8	25.4	28.3	30.3	32.4	35.2	36.8	36.6	37.5	38.3	39.4	40.1	40.6	41.3	41.4	41.5	42.0	42.6	42.4	41.4	40.0	40.9	36.5	29.4	25.7	20.9	18.6	14.9	52.9	
	Background (dBA)	19.8	23.0	25.4	27.3	29.2	31.2	32.5	33.1	33.8	34.9	36.0	36.7	36.8	36.3	35.3	34.1	32.9	31.2	28.8	27.3	25.4	23.5	21.3	19.7	18.9	16.9	16.5	13.4	46.2	
	Turbine ON - background adj (dBA)	18.8	22.4	25.3	27.4	29.5	33.0	34.9	34.0	35.0	35.5	36.9	37.4	38.2	39.6	40.2	40.6	41.4	42.2	42.2	41.3	39.8	40.8	36.4	28.9	24.7	18.7	15.6	11.9	51.8	
	Signal to noise (dB)	2.0	2.3	2.9	3.0	3.2	4.0	4.4	3.5	3.7	3.3	3.5	3.4	3.8	5.0	6.2	7.3	9.1	11.3	13.5	14.1	14.6	17.4	15.3	9.7	6.8	4.0	2.1	1.5	6.7	
	Uncertainty (dB)	5.2	4.4	3.1	4.1	2.8	2.1	1.8	2.1	1.9	1.7	1.8	1.6	1.4	1.2	1.1	1.0	1.0	0.9	0.9	1.0	1.3	1.4	1.6	2.3	3.6	4.5	4.5	1.2		
	PWL (dBA)	69.3	72.9	75.8	77.9	80.1	83.6	85.4	84.6	85.6	86.1	87.4	88.0	88.8	90.1	90.8	91.1	92.0	92.8	92.7	91.8	90.4	91.4	87.0	79.5	75.2	69.2	66.1	62.5	102.4	

## Table C.03 Type B measurement uncertainty summary

Project: North Kent Wind Farm - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 1 of 1

Created on: 2/22/2019

Overall Equipment Uncertainties		
	Typical values	Used values
Calibration	0.2 dB	0.2 dB
Board	0.3 dB	0.3 dB
Distance	0.1 dB	0.1 dB
Air absorption	0 dB	0 dB
Weather	0.5 dB	0.5 dB

1/3 Octave Band Uncertainties		
Frequency (Hz)	Microphone Uncertainty	Overall (including overall equipment Uncertainties)
20	0.8 dB	2 dB
25	0.8 dB	1.6 dB
31.5	0.5 dB	1.1 dB
40	0.5 dB	1.5 dB
50	0.5 dB	1.1 dB
63	0.5 dB	0.9 dB
80	0.5 dB	0.8 dB
100	0.5 dB	0.8 dB
125	0.5 dB	0.8 dB
160	0.5 dB	0.8 dB
200	0.3 dB	0.7 dB
250	0.3 dB	0.7 dB
315	0.3 dB	0.7 dB
400	0.3 dB	0.7 dB
500	0.3 dB	0.7 dB
630	0.3 dB	0.7 dB
800	0.3 dB	0.7 dB
1000	0.3 dB	0.8 dB
1250	0.3 dB	0.8 dB
1600	0.3 dB	0.8 dB
2000	0.3 dB	0.7 dB
2500	0.5 dB	0.8 dB
3150	0.5 dB	1.1 dB
4000	0.5 dB	1.1 dB
5000	0.5 dB	1 dB
6300	0.5 dB	1.1 dB
8000	0.5 dB	1.4 dB
10000	1.3 dB	1.7 dB

**Table C.04 Detailed measurement uncertainty at hub height**

Project: North Kent Wind Farm - Turbine T36 - IEC 61400-11 Measurement

Report ID: 172831.01.T36.RP2

Page 1 of 2

Created on: 2/22/2019

Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																								Overall				
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	
7.5	Turbine ON	7.48	26	Average (dBA)	8.4	12.4	16.6	22.1	24.2	32.1	29.2	30.7	32.1	32.4	36.5	37.1	36.5	38.4	40.3	41.5	42.1	41.3	39.8	39.7	39.8	33.1	29.0	24.7	18.8	11.4	7.8	51.1	
				Uncertainty A (dB)	0.2	0.2	0.2	0.5	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.1	0.3	0.2	0.1	0.2	0.2	0.1	0.1	0.1
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	0.7	0.8	0.7	0.8	0.7
	Background	7.51	67	Combined Uncertainty (dB)	2.0	1.7	1.1	1.6	1.1	1.0	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.9	1.1	1.1	1.1	1.1	1.4	1.7
8.0	Turbine ON	8.07	31	Average (dBA)	11.0	15.0	18.8	22.4	25.9	33.2	34.1	32.3	33.1	34.6	38.1	38.8	38.4	40.3	42.2	43.2	43.8	43.2	42.9	41.4	40.0	42.1	36.8	30.5	26.5	20.8	13.8	9.9	52.8
				Uncertainty A (dB)	0.5	0.4	0.3	0.2	0.3	0.1	0.3	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.1	0.1	0.2	0.4	0.4	0.4	0.4	0.4
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.1	1.4	1.7	
	Background	8.01	68	Combined Uncertainty (dB)	2.4	2.0	1.4	1.7	1.2	1.1	1.0	1.1	1.2	1.3	1.2	1.1	1.0	1.0	0.8	0.8	0.8	0.9	1.0	0.9	1.0	1.2	1.1	1.1	1.1	1.4	1.7		
8.5	Turbine ON	8.47	57	Average (dBA)	11.3	15.7	19.1	22.6	26.0	32.9	34.5	32.3	33.4	35.1	38.3	39.0	38.7	40.7	42.3	43.4	43.9	43.4	43.2	41.6	40.2	42.5	37.6	30.7	26.8	21.2	14.8	11.1	53.1
				Uncertainty A (dB)	0.5	0.4	0.3	0.3	0.2	0.1	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.4	0.4
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7	
	Background	8.51	52	Combined Uncertainty (dB)	2.0	1.7	1.1	1.6	1.1	1.0	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7
9.0	Turbine ON	9.00	75	Average (dBA)	13.3	17.1	20.4	23.4	26.8	33.6	35.0	32.9	34.2	35.9	38.7	39.4	39.1	41.0	42.4	43.3	43.8	43.5	43.1	41.5	40.3	42.9	38.0	30.8	26.9	21.2	15.4	11.6	53.2
				Uncertainty A (dB)	0.6	0.5	0.4	0.4	0.3	0.1	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.4	0.4	
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7	
	Background	8.99	75	Combined Uncertainty (dB)	2.7	2.4	1.9	2.0	1.5	1.4	1.4	1.5	1.6	1.5	1.4	1.2	1.0	0.8	0.8	0.8	0.9	0.9	1.0	1.2	1.4	1.4	1.2	1.5	1.8				
9.5	Turbine ON	9.50	110	Average (dBA)	14.7	18.6	21.0	23.9	27.0	33.4	34.7	33.0	34.7	36.2	39.0	39.6	39.2	41.1	42.4	43.2	43.7	43.3	42.9	41.4	40.4	43.3	38.3	31.3	27.7	23.1	21.3	19.8	53.3
				Uncertainty A (dB)	0.6	0.5	0.4	0.3	0.3	0.1	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.3	0.6	0.9	
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7	
	Background	9.49	78	Combined Uncertainty (dB)	2.1	1.7	1.1	1.6	1.1	1.0	0.8	0.9	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.5	1.9
10.0	Turbine ON	9.97	82	Average (dBA)	17.1	20.2	22.5	24.6	27.0	29.7	30.3	31.4	33.2	32.3	33.4	34.1	34.2	33.8	33.1	32.4	31.9	31.0	30.9	30.2	25.7	21.8	19.2	16.9	15.6	14.0	13.4	10.7	42.9
				Uncertainty A (dB)	1.4	1.3	1.1	1.0	0.9	0.8	0.8	1.0	1.2	1.1	1.0	1.0	1.0	1.0	0.9	0.7	0.4	0.4	0.3	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.4		
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7	
	Background	10.02	67	Combined Uncertainty (dB)	2.4	2.1	1.5	1.8	1.4	1.3	1.2	1.3	1.4	1.4	1.3	1.2	1.1	1.0	0.8	0.8	0.8	0.9	1.0	0.9	1.0	1.2	1.2	1.2	1.4	1.7			
10.5	Turbine ON	10.48	108	Average (dBA)	16.6	20.8	22.9	25.4	28.1	32.7	33.7	33.4	34.7	36.0	38.6	39.2	39.1	40.8	42.2	42.9	43.4	43.3	42.7	41.4	40.2	43.4	38.7	31.4	28.1	24.6	20.0	20.7	53.1
				Uncertainty A (dB)	0.7	0.6	0.6	0.4	0.4	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.4	0.8	1.0				
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7	
	Background	10.49	86	Combined Uncertainty (dB)	2.1	1.7	1.2	1.6	1.1	1.0	0.9	0.9	0.9	0.9	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7

**Table C.04 Detailed measurement uncertainty at hub height**


Project: North Kent Wind Farm - Turbine T36 - IEC 61400-11 Measurement

Report ID: 172831.01.T36.RP2

Page 2 of 2

Created on: 2/22/2019

Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																								Overall					
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
11.0	Turbine ON	11.00	105	Average (dBA)	17.8	21.6	23.7	26.3	28.8	33.2	34.2	33.9	35.1	36.3	38.5	39.2	39.3	40.8	41.7	42.5	43.1	43.2	42.7	41.4	40.2	42.8	38.2	31.0	27.4	23.1	21.1	19.3	52.9	
				Uncertainty A (dB)	0.7	0.5	0.6	0.5	0.4	0.2	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.5	0.7					
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.6	0.6	0.5	0.5	0.4			
	Background	10.98	66	Combined Uncertainty (dB)	2.1	1.7	1.2	1.6	1.1	1.0	0.9	0.9	0.9	0.9	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.1	1.4	1.8	46.0	
11.5	Turbine ON	11.50	90	Average (dBA)	19.6	22.8	24.9	27.2	29.0	30.9	32.2	32.7	33.6	34.6	35.7	36.3	36.5	36.0	35.1	34.0	32.7	31.2	29.0	27.5	25.5	23.6	21.4	19.8	18.9	16.8	16.2	13.4	52.9	
				Uncertainty A (dB)	0.8	0.7	0.7	0.6	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.4	0.4	0.3	0.4	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.4			
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7	
	Background	11.50	52	Combined Uncertainty (dB)	2.1	1.8	1.3	1.6	1.2	1.0	1.0	1.0	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	1.0	1.2	1.2	1.1	1.2	1.4	1.8
12.0	Turbine ON	12.00	57	Average (dBA)	20.1	24.2	26.2	28.3	30.6	34.2	35.3	35.0	36.2	37.3	38.9	39.8	40.1	41.0	41.5	41.8	42.5	42.8	42.4	41.3	39.9	42.0	37.6	29.9	26.1	21.3	19.5	16.7	52.8	
				Uncertainty A (dB)	0.6	0.4	0.5	0.5	0.4	0.2	0.2	0.3	0.3	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.2	0.3	0.4	0.5		
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7	
	Background	11.98	53	Combined Uncertainty (dB)	2.1	1.7	1.2	1.6	1.2	1.0	0.9	0.9	0.9	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.7	0.6	0.6	0.6	0.5	0.5		
12.5	Turbine ON	12.43	31	Average (dBA)	20.2	24.0	26.3	28.9	31.0	34.4	35.8	35.2	36.3	37.1	38.8	39.6	39.8	40.9	41.4	41.8	42.5	42.9	42.6	41.5	40.1	41.6	37.5	30.4	26.8	23.3	22.3	20.8	52.8	
				Uncertainty A (dB)	0.7	0.6	0.7	0.6	0.5	0.3	0.3	0.4	0.3	0.3	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.3	0.6	0.8	1.1		
				Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	1.1	1.1	1.0	1.1	1.4	1.7		
	Background	12.46	46	Combined Uncertainty (dB)	2.0	1.7	1.2	1.6	1.1	1.0	0.9	0.9	0.9	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.8	0.9	0.9	0.9	0.9	1.0	1.2	1.2	1.1	1.2	1.5	1.8	46.0



■ Turbine ON - Derived from power curve

● Turbine ON - Derived from nacelle anemometer

● Background



17283.01.T36.RP2

Project Name


North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36

Scale: NTS  
Drawn by: DEA  
Reviewed by: MAD  
Date: Feb 2019  
Revision: 1

Figure Title

Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)


**Figure C.01**




■ Total noise vs electrical power output

 aercoustics	17283.01.T36.RP2	Project Name
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Figure Title	Plot of measured total noise vs. electrical power output

**Figure C.02**




 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of power curve relative to nacelle anemometer and 10 m anemometer
		<b>Figure C.03</b>




	17283.01.T36.RP2	Project Name
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Figure Title	Plot of rotor RPM vs. electrical power output
		<b>Figure C.04</b>

### 7.5 m/s - Hub Height




 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of sound pressure spectrum in 1/3 Octave at 7.5 m/s
		<b>Figure C.05</b>

### 8.0 m/s - Hub Height




 <span>aercoustics</span>	17283.01.T36.RP2	Project Name
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Figure Title	Plot of sound pressure spectrum in 1/3 Octave at 8.0 m/s
		<b>Figure C.06</b>

### 8.5 m/s - Hub Height



 aercoustics	17283.01.T36.RP2	Project Name North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s
		<b>Figure C.07</b>

### 9.0 m/s - Hub Height



aercoustics


17283.01.T36.RP2  
Scale: NTS  
Drawn by: DEA  
Reviewed by: MAD  
Date: Feb 2019  
Revision: 1

Project Name  
North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36

Figure Title  
Plot of sound pressure spectrum in 1/3 Octave at 9.0 m/s


**Figure C.08**

### 9.5 m/s - Hub Height



 <span>aercoustics</span>	17283.01.T36.RP2	Project Name
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Figure Title	Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s
		<b>Figure C.09</b>

### 10.0 m/s - Hub Height



aercoustics


17283.01.T36.RP2  
Scale: NTS  
Drawn by: DEA  
Reviewed by: MAD  
Date: Feb 2019  
Revision: 1

Project Name  
North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36

Figure Title  
Plot of sound pressure spectrum in 1/3 Octave at 10.0 m/s

**Figure C.10**

### 10.5 m/s - Hub Height



aercoustics


17283.01.T36.RP2  
Scale: NTS  
Drawn by: DEA  
Reviewed by: MAD  
Date: Feb 2019  
Revision: 1

Project Name  
North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36

Figure Title  
Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s


**Figure C.11**

### 11.0 m/s - Hub Height




 17283.01.T36.RP2	<b>Project Name</b>		
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36 Plot of sound pressure spectrum in 1/3 Octave at 11.0 m/s	<b>Figure C.12</b>

### 11.5 m/s - Hub Height



 17283.01.T36.RP2	<b>Project Name</b>		
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36	
Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s			<b>Figure C.13</b>

### 12.0 m/s - Hub Height



aercoustics


17283.01.T36.RP2  
Scale: NTS  
Drawn by: DEA  
Reviewed by: MAD  
Date: Feb 2019  
Revision: 1

Project Name  
North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36

Figure Title  
Plot of sound pressure spectrum in 1/3 Octave at 12.0 m/s

**Figure C.14**

### 12.5 m/s - Hub Height



aercoustics

17283.01.T36.RP2  
Scale: NTS  
Drawn by: DEA  
Reviewed by: MAD  
Date: Feb 2019  
Revision: 1

Project Name  
North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36

Figure Title  
Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s

**Figure C.15**

---

## Appendix D Tonality Assessment

---

## Table D.01 Tonality Assessment Table - 7.5 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 1 of 13

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
490	58	21.4	39.6	30.9	-8.7	-2.0	-6.7
463	58	18.6	36.9	31.8	-5.1	-2.0	-3.1
462	58	19.0	37.3	32.9	-4.3	-2.0	-2.3
497	62	19.1	37.3	33.6	-3.7	-2.0	-1.7
343	62	19.1	37.3	36.2	-1.1	-2.0	0.9
496	62	18.7	36.9	34.0	-2.9	-2.0	-0.9
350	63	20.5	38.8	37.3	-1.5	-2.0	0.5
349	63	20.3	38.5	36.0	-2.6	-2.0	-0.6
491	63	20.1	38.4	32.4	-6.0	-2.0	-4.0
501	63	20.7	38.9	33.2	-5.7	-2.0	-3.7
353	63	20.9	39.1	32.9	-6.3	-2.0	-4.3
342	64	19.6	37.8	32.2	-5.6	-2.0	-3.6
500	65	21.1	39.3	32.0	-7.3	-2.0	-5.3
510	65	20.1	38.3	32.4	-5.9	-2.0	-3.9
460	65	18.8	37.0	33.6	-3.4	-2.0	-1.4
461	65	18.8	37.1	31.7	-5.3	-2.0	-3.3
502	65	20.0	38.3	35.2	-3.1	-2.0	-1.1
498	66	20.3	38.5	32.4	-6.1	-2.0	-4.1
487	66	19.8	38.0	32.5	-5.5	-2.0	-3.5
492	66	19.4	37.7	31.9	-5.8	-2.0	-3.8
503	66	21.3	39.5	32.4	-7.1	-2.0	-5.1
459	66	20.8	39.0	34.7	-4.4	-2.0	-2.4
486	67	21.3	39.5	30.7	-8.8	-2.0	-6.8
489	67	20.8	39.1	33.2	-5.9	-2.0	-3.9
495	67	20.5	38.7	32.1	-6.6	-2.0	-4.6
Average	63.8				-4.7	-2.0	-2.7

## Table D.02 Tonality Assessment Table - 8 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 2 of 13

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
488	67	20.7	38.9	32.4	-6.5	-2.0	-4.5
458	68	21.3	39.6	33.6	-6.0	-2.0	-4.0
509	69	22.4	40.6	35.7	-4.9	-2.0	-2.9
308	69	20.5	38.8	39.3	0.5	-2.0	2.5
457	69	21.2	39.4	36.3	-3.1	-2.0	-1.1
316	69	22.9	41.1	36.7	-4.4	-2.0	-2.4
484	70	20.8	39.1	37.5	-1.6	-2.0	0.4
306	70	20.5	38.8	38.0	-0.8	-2.0	1.2
175	70	21.6	39.8	39.0	-0.9	-2.0	1.1
309	70	20.4	38.7	39.1	0.4	-2.0	2.4
315	70	22.4	40.6	38.5	-2.1	-2.0	-0.1
494	70	20.7	38.9	36.8	-2.1	-2.0	-0.1
356	70	22.3	40.5	38.6	-1.9	-2.0	0.1
310	70	20.9	39.2	38.7	-0.5	-2.0	1.5
317	70	22.0	40.3	36.5	-3.8	-2.0	-1.8
511	70	18.6	36.8	35.6	-1.2	-2.0	0.8
485	70	20.9	39.1	37.8	-1.3	-2.0	0.7
341	70	20.2	38.5	36.5	-2.0	-2.0	0.0
357	70	22.5	40.8	36.7	-4.0	-2.0	-2.0
162	71	22.6	40.9	38.3	-2.6	-2.0	-0.6
176	71	22.1	40.3	39.7	-0.7	-2.0	1.3
358	71	23.0	41.3	39.8	-1.5	-2.0	0.5
355	71	21.6	39.9	38.6	-1.2	-2.0	0.8
657	71	23.1	41.3	39.3	-2.1	-2.0	-0.1
331	71	21.8	40.1	38.2	-1.9	-2.0	0.1
340	71	20.8	39.0	38.4	-0.6	-2.0	1.4
589	73	24.6	42.9	36.2	-6.7	-2.0	-4.7
472	86	22.7	40.9	37.0	-3.9	-2.0	-1.9
Average	71				-2.0	-2.0	0.0

## Table D.03 Tonality Assessment Table - 8.5 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 3 of 14

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
654	58	23.8	42.1	36.9	-5.2	-2.0	-3.2
178	58	22.5	40.7	37.8	-2.9	-2.0	-0.9
655	58	23.9	42.1	36.8	-5.3	-2.0	-3.3
592	58	24.0	42.3	37.7	-4.5	-2.0	-2.5
160	69	23.1	41.3	35.0	-6.3	-2.0	-4.3
588	69	23.7	41.9	36.3	-5.7	-2.0	-3.7
483	69	20.1	38.3	36.5	-1.9	-2.0	0.1
305	69	21.3	39.6	37.7	-1.8	-2.0	0.2
302	69	19.6	37.8	36.5	-1.4	-2.0	0.6
314	69	20.7	38.9	38.0	-0.9	-2.0	1.1
591	69	24.4	42.7	35.6	-7.0	-2.0	-5.0
322	69	21.7	40.0	36.6	-3.4	-2.0	-1.4
656	70	23.6	41.9	39.3	-2.6	-2.0	-0.6
362	70	22.7	40.9	35.3	-5.6	-2.0	-3.6
454	70	21.4	39.6	37.9	-1.7	-2.0	0.3
312	70	20.8	39.0	38.1	-0.9	-2.0	1.1
473	70	19.7	37.9	37.4	-0.5	-2.0	1.5
330	70	20.9	39.2	37.3	-1.9	-2.0	0.1
508	70	21.4	39.6	38.0	-1.6	-2.0	0.4
504	70	20.3	38.6	37.7	-0.9	-2.0	1.1
658	70	24.5	42.7	38.1	-4.6	-2.0	-2.6
452	70	21.1	39.4	36.8	-2.5	-2.0	-0.5
397	70	22.5	40.7	37.5	-3.2	-2.0	-1.2
338	70	20.2	38.5	37.9	-0.6	-2.0	1.5
166	70	22.4	40.6	38.4	-2.2	-2.0	-0.2
301	70	19.2	37.5	37.4	-0.1	-2.0	1.9
336	70	20.9	39.2	37.7	-1.5	-2.0	0.5
475	70	21.8	40.0	37.9	-2.1	-2.0	-0.1
303	70	19.4	37.7	38.2	0.6	-2.0	2.6
156	70	20.2	38.4	37.6	-0.8	-2.0	1.2
507	70	22.7	40.9	38.4	-2.5	-2.0	-0.5
173	71	23.6	41.8	38.3	-3.6	-2.0	-1.6
332	71	21.9	40.1	37.7	-2.4	-2.0	-0.4
170	71	20.7	38.9	39.1	0.2	-2.0	2.2
334	71	20.7	38.9	36.9	-2.0	-2.0	0.0
333	71	20.7	38.9	37.8	-1.1	-2.0	0.9
493	71	20.4	38.7	36.7	-2.0	-2.0	0.0
339	71	19.6	37.8	38.3	0.4	-2.0	2.4
304	71	20.3	38.6	38.1	-0.5	-2.0	1.5
307	71	20.0	38.2	37.9	-0.3	-2.0	1.7
453	71	21.6	39.8	37.3	-2.5	-2.0	-0.5
171	71	22.2	40.4	38.6	-1.8	-2.0	0.2
313	71	19.3	37.5	37.4	-0.1	-2.0	1.9
168	71	20.8	39.1	38.6	-0.5	-2.0	1.5
366	71	23.0	41.2	38.0	-3.3	-2.0	-1.3
167	71	20.8	39.1	38.6	-0.5	-2.0	1.5
474	71	22.2	40.5	35.3	-5.1	-2.0	-3.1
163	71	22.9	41.1	37.7	-3.5	-2.0	-1.4
455	71	21.4	39.7	38.8	-0.9	-2.0	1.1
365	71	21.7	39.9	39.3	-0.7	-2.0	1.4
172	71	22.4	40.6	39.0	-1.6	-2.0	0.4
456	71	20.7	39.0	37.4	-1.6	-2.0	0.4
169	71	20.4	38.7	39.1	0.4	-2.0	2.4

## Table D.03 Tonality Assessment Table - 8.5 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 4 of 14

Created on: 2/22/2019

476	72	22.0	40.3	35.1	-5.2	-2.0	-3.2
644	72	23.5	41.7	38.1	-3.6	-2.0	-1.6
311	72	21.7	40.0	38.1	-1.9	-2.0	0.1
590	74	23.8	42.1	37.8	-4.2	-2.0	-2.2
Average	70				-1.9	-2.0	0.1

**Table D.04 Tonality Assessment Table - 9 m/s**

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 5 of 13

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
652	57	22.2	40.5	41.0	0.6	-2.0	2.6
586	58	25.4	43.6	35.5	-8.1	-2.0	-6.1
584	58	25.2	43.4	34.7	-8.7	-2.0	-6.7
164	58	23.7	42.0	35.0	-7.0	-2.0	-5.0
1021	68	25.8	44.0	32.1	-11.9	-2.0	-9.9
682	69	25.1	43.4	34.6	-8.8	-2.0	-6.8
299	69	18.4	36.6	38.6	2.0	-2.0	4.0
558	69	22.4	40.7	38.5	-2.2	-2.0	-0.2
450	69	19.4	37.6	37.7	0.1	-2.0	2.1
660	69	24.1	42.4	37.4	-5.0	-2.0	-3.0
585	69	24.3	42.5	38.7	-3.9	-2.0	-1.8
296	69	20.7	39.0	38.8	-0.2	-2.0	1.8
947	69	26.6	44.8	36.3	-8.6	-2.0	-6.6
326	69	18.7	36.9	38.8	1.9	-2.0	3.9
643	69	22.2	40.5	38.0	-2.5	-2.0	-0.5
817	69	23.1	41.3	37.1	-4.3	-2.0	-2.3
818	69	23.4	41.7	39.6	-2.1	-2.0	-0.1
587	69	25.1	43.4	36.4	-7.0	-2.0	-5.0
300	69	19.4	37.6	38.5	0.8	-2.0	2.8
952	69	24.0	42.3	36.1	-6.1	-2.0	-4.1
428	70	20.4	38.7	37.9	-0.8	-2.0	1.2
819	70	23.1	41.3	40.2	-1.1	-2.0	0.9
482	70	19.9	38.1	38.3	0.3	-2.0	2.3
263	70	21.4	39.6	38.5	-1.1	-2.0	0.9
506	70	21.2	39.4	37.1	-2.4	-2.0	-0.3
445	70	20.4	38.6	38.2	-0.4	-2.0	1.6
479	70	19.3	37.5	38.1	0.6	-2.0	2.6
327	70	19.0	37.2	39.4	2.2	-2.0	4.2
559	70	22.6	40.9	40.1	-0.7	-2.0	1.3
385	70	21.5	39.7	37.8	-1.9	-2.0	0.1
67	70	22.5	40.7	38.8	-1.9	-2.0	0.1
653	70	22.3	40.6	39.6	-1.0	-2.0	1.0
320	70	20.6	38.9	39.4	0.5	-2.0	2.5
505	70	18.5	36.8	38.2	1.4	-2.0	3.4
446	70	19.5	37.7	38.3	0.6	-2.0	2.6
321	70	21.6	39.8	37.9	-1.9	-2.0	0.2
39	70	21.5	39.8	37.8	-1.9	-2.0	0.1
451	70	20.8	39.0	38.4	-0.6	-2.0	1.4
325	70	20.2	38.5	39.3	0.8	-2.0	2.8
298	70	18.8	37.0	38.8	1.8	-2.0	3.8
443	70	20.9	39.1	37.4	-1.7	-2.0	0.3
182	70	24.1	42.3	37.7	-4.6	-2.0	-2.6
594	71	23.8	42.0	39.3	-2.7	-2.0	-0.7
659	71	23.3	41.6	37.8	-3.8	-2.0	-1.8
159	71	22.1	40.4	39.4	-0.9	-2.0	1.1
862	71	24.2	42.5	38.9	-3.5	-2.0	-1.5
386	71	21.2	39.4	39.4	-0.1	-2.0	1.9
68	71	22.1	40.3	39.7	-0.6	-2.0	1.4
361	71	22.9	41.2	39.1	-2.1	-2.0	0.0
421	71	19.8	38.1	38.7	0.7	-2.0	2.7
425	71	20.5	38.7	39.2	0.4	-2.0	2.4
478	71	19.5	37.7	37.0	-0.7	-2.0	1.3
157	71	21.8	40.0	37.9	-2.1	-2.0	-0.1

## Table D.04 Tonality Assessment Table - 9 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 6 of 13

Created on: 2/22/2019

422	71	20.5	38.7	38.1	-0.6	-2.0	1.4
174	71	21.6	39.8	38.3	-1.5	-2.0	0.5
323	71	20.0	38.3	37.8	-0.5	-2.0	1.5
329	71	21.6	39.9	38.5	-1.4	-2.0	0.6
364	71	21.9	40.1	38.9	-1.2	-2.0	0.8
328	71	20.4	38.6	38.1	-0.5	-2.0	1.5
424	72	19.8	38.0	39.2	1.1	-2.0	3.1
549	72	24.4	42.7	33.6	-9.0	-2.0	-7.0
359	72	20.5	38.7	39.2	0.5	-2.0	2.5
593	72	23.5	41.8	38.1	-3.6	-2.0	-1.6
318	72	21.0	39.3	38.2	-1.1	-2.0	0.9
158	72	22.6	40.8	38.7	-2.2	-2.0	-0.2
387	72	24.0	42.3	38.7	-3.6	-2.0	-1.6
447	72	19.6	37.9	38.3	0.4	-2.0	2.4
477	72	21.3	39.6	37.3	-2.3	-2.0	-0.3
337	72	20.8	39.1	38.1	-1.0	-2.0	1.0
363	72	21.7	39.9	39.8	-0.2	-2.0	1.8
335	72	20.5	38.8	36.7	-2.1	-2.0	-0.1
423	72	19.6	37.9	37.9	0.0	-2.0	2.0
821	73	25.1	43.3	36.6	-6.7	-2.0	-4.7
165	74	24.1	42.4	38.3	-4.0	-2.0	-2.0
Average	70				-1.2	-2.0	0.8

**Table D.05 Tonality Assessment Table - 9.5 m/s**

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 7 of 13

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
861	58	25.3	43.6	35.1	-8.4	-2.0	-6.4
583	58	23.5	41.7	37.7	-4.1	-2.0	-2.1
181	58	22.2	40.4	35.8	-4.6	-2.0	-2.6
946	58	27.2	45.4	33.8	-11.6	-2.0	-9.6
651	63	24.6	42.8	37.4	-5.4	-2.0	-3.4
288	69	20.2	38.4	38.1	-0.3	-2.0	1.7
152	69	19.0	37.2	37.8	0.5	-2.0	2.5
151	69	19.9	38.1	38.0	-0.1	-2.0	1.9
282	69	22.3	40.6	37.0	-3.6	-2.0	-1.6
286	69	19.4	37.6	36.7	-0.9	-2.0	1.1
825	69	26.2	44.5	36.0	-8.5	-2.0	-6.5
639	69	23.4	41.7	38.7	-2.9	-2.0	-0.9
372	69	22.8	41.0	37.5	-3.5	-2.0	-1.5
153	69	19.0	37.2	37.7	0.5	-2.0	2.5
642	69	22.6	40.9	38.5	-2.4	-2.0	-0.4
556	69	23.9	42.1	36.5	-5.6	-2.0	-3.6
295	69	20.0	38.2	37.2	-1.0	-2.0	1.0
411	69	19.4	37.7	38.2	0.5	-2.0	2.5
259	69	20.9	39.2	37.3	-1.8	-2.0	0.2
637	69	21.6	39.8	39.0	-0.9	-2.0	1.1
261	69	21.3	39.5	38.0	-1.5	-2.0	0.5
155	69	19.4	37.7	37.5	-0.2	-2.0	1.8
114	69	20.7	39.0	37.4	-1.6	-2.0	0.4
419	69	19.2	37.4	37.5	0.1	-2.0	2.1
1010	69	24.3	42.5	35.5	-7.0	-2.0	-5.0
681	69	24.2	42.4	34.4	-8.0	-2.0	-6.0
258	69	20.7	39.0	36.3	-2.7	-2.0	-0.7
293	69	18.7	37.0	37.3	0.4	-2.0	2.4
636	69	26.0	44.2	34.2	-10.0	-2.0	-8.0
688	69	23.7	42.0	37.5	-4.5	-2.0	-2.5
566	69	25.2	43.4	36.7	-6.8	-2.0	-4.8
384	70	21.6	39.8	37.5	-2.3	-2.0	-0.3
294	70	18.5	36.7	37.6	0.9	-2.0	2.9
689	70	22.5	40.7	37.4	-3.3	-2.0	-1.3
783	70	25.3	43.5	38.0	-5.5	-2.0	-3.5
641	70	24.4	42.7	37.3	-5.4	-2.0	-3.4
142	70	20.4	38.6	37.3	-1.3	-2.0	0.7
154	70	20.0	38.3	38.7	0.4	-2.0	2.4
638	70	21.9	40.1	38.5	-1.7	-2.0	0.4
412	70	19.0	37.2	38.3	1.2	-2.0	3.2
431	70	21.1	39.3	38.2	-1.1	-2.0	0.9
546	70	25.0	43.3	34.7	-8.5	-2.0	-6.5
547	70	23.5	41.7	37.7	-4.0	-2.0	-2.0
440	70	20.6	38.8	37.7	-1.1	-2.0	0.9
481	70	19.2	37.5	37.9	0.4	-2.0	2.4
260	70	22.5	40.7	34.4	-6.3	-2.0	-4.3
297	70	20.1	38.3	38.3	0.0	-2.0	2.0
782	70	23.4	41.6	37.5	-4.1	-2.0	-2.1
430	70	21.6	39.8	38.8	-1.0	-2.0	1.0
144	70	21.5	39.7	38.0	-1.7	-2.0	0.3
271	70	21.1	39.3	35.9	-3.4	-2.0	-1.4
115	70	22.4	40.7	38.9	-1.8	-2.0	0.2
256	70	19.5	37.7	36.9	-0.8	-2.0	1.2

## Table D.05 Tonality Assessment Table - 9.5 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 8 of 13

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
449	70	18.4	36.7	38.1	1.4	-2.0	3.4
661	70	23.2	41.4	38.2	-3.2	-2.0	-1.2
560	70	22.9	41.2	37.3	-3.8	-2.0	-1.8
292	70	18.9	37.1	37.1	0.0	-2.0	2.0
420	70	19.2	37.5	37.8	0.3	-2.0	2.3
287	70	19.7	38.0	37.5	-0.5	-2.0	1.5
35	70	20.7	38.9	38.4	-0.5	-2.0	1.5
951	70	26.7	45.0	36.0	-9.0	-2.0	-7.0
38	71	21.2	39.4	38.6	-0.9	-2.0	1.1
441	71	20.1	38.3	38.0	-0.3	-2.0	1.7
400	71	19.5	37.7	38.0	0.3	-2.0	2.3
683	71	23.5	41.8	38.2	-3.5	-2.0	-1.5
389	71	22.8	41.0	37.0	-4.0	-2.0	-2.0
40	71	22.2	40.5	39.4	-1.1	-2.0	0.9
143	71	20.5	38.8	37.5	-1.3	-2.0	0.7
396	71	21.3	39.5	38.6	-1.0	-2.0	1.0
390	71	21.7	40.0	39.4	-0.6	-2.0	1.4
145	71	22.2	40.4	38.7	-1.7	-2.0	0.3
550	71	24.9	43.2	37.9	-5.3	-2.0	-3.3
395	71	21.5	39.7	38.5	-1.2	-2.0	0.8
551	71	23.5	41.7	36.7	-5.0	-2.0	-3.0
415	71	18.6	36.9	39.1	2.3	-2.0	4.3
442	71	19.4	37.7	38.1	0.4	-2.0	2.4
255	71	22.5	40.7	37.8	-3.0	-2.0	-1.0
36	71	21.5	39.7	38.6	-1.1	-2.0	0.9
398	71	20.2	38.5	39.3	0.9	-2.0	2.9
324	71	19.9	38.1	37.4	-0.7	-2.0	1.3
820	72	24.3	42.6	39.7	-2.9	-2.0	-0.8
416	72	18.5	36.8	38.1	1.3	-2.0	3.3
826	72	25.6	43.8	35.6	-8.2	-2.0	-6.2
69	72	22.6	40.8	38.6	-2.2	-2.0	-0.2
367	72	23.0	41.2	38.4	-2.8	-2.0	-0.8
429	72	21.4	39.7	39.1	-0.6	-2.0	1.4
37	72	22.1	40.3	39.0	-1.3	-2.0	0.7
360	72	21.7	40.0	38.4	-1.6	-2.0	0.4
388	72	22.3	40.5	38.0	-2.5	-2.0	-0.5
444	72	19.9	38.2	38.9	0.7	-2.0	2.7
319	72	19.9	38.1	38.1	-0.1	-2.0	1.9
480	72	19.3	37.5	37.4	-0.1	-2.0	1.9
146	72	22.5	40.7	37.8	-2.9	-2.0	-0.9
414	72	19.3	37.5	39.4	1.9	-2.0	3.9
448	72	19.3	37.6	37.7	0.1	-2.0	2.1
427	73	20.8	39.1	38.0	-1.1	-2.0	0.9
548	73	25.7	43.9	35.1	-8.8	-2.0	-6.8
687	73	26.2	44.4	32.8	-11.6	-2.0	-9.6
561	73	26.1	44.3	34.0	-10.3	-2.0	-8.3
262	73	21.4	39.7	36.3	-3.4	-2.0	-1.4
413	74	20.6	38.9	38.2	-0.6	-2.0	1.4
557	74	23.9	42.1	37.8	-4.4	-2.0	-2.4
645	74	24.6	42.9	39.7	-3.2	-2.0	-1.2
426	74	20.5	38.8	38.4	-0.4	-2.0	1.6
Average	70				-1.7	-2.0	0.3

## Table D.06 Tonality Assessment Table - 10 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 9 of 13

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
604	58	24.0	42.2	30.2	-12.0	-2.0	-10.0
596	58	23.9	42.1	35.4	-6.7	-2.0	-4.7
663	58	23.6	41.9	37.7	-4.2	-2.0	-2.2
148	58	19.6	37.9	36.2	-1.6	-2.0	0.4
106	58	21.5	39.8	33.2	-6.6	-2.0	-4.6
133	58	20.4	38.7	34.1	-4.6	-2.0	-2.6
254	58	21.9	40.1	36.3	-3.9	-2.0	-1.9
680	58	24.7	43.0	34.5	-8.5	-2.0	-6.5
669	58	25.2	43.4	36.8	-6.6	-2.0	-4.6
695	58	23.4	41.7	34.9	-6.8	-2.0	-4.8
640	58	21.7	39.9	38.5	-1.5	-2.0	0.5
816	58	23.8	42.0	37.7	-4.3	-2.0	-2.3
140	58	22.3	40.5	35.4	-5.1	-2.0	-3.1
257	69	21.1	39.3	36.7	-2.6	-2.0	-0.6
270	69	20.3	38.6	35.0	-3.6	-2.0	-1.6
113	69	19.2	37.5	35.8	-1.7	-2.0	0.3
379	69	21.4	39.6	36.4	-3.3	-2.0	-1.3
150	69	19.7	37.9	36.5	-1.4	-2.0	0.6
1028	69	25.2	43.4	33.8	-9.6	-2.0	-7.6
524	69	27.9	46.1	34.1	-11.9	-2.0	-9.9
1008	69	22.5	40.7	36.3	-4.4	-2.0	-2.4
595	69	22.9	41.2	37.9	-3.3	-2.0	-1.3
283	69	18.9	37.1	37.0	-0.1	-2.0	1.9
1007	69	23.5	42	36	-5.5	-2.0	-3.5
607	69	22.7	40.9	37.4	-3.5	-2.0	-1.5
281	69	20.3	38.5	34.5	-4.0	-2.0	-2.0
603	69	23.6	41.8	35.7	-6.1	-2.0	-4.1
291	69	18.9	37.1	35.8	-1.4	-2.0	0.6
273	69	20.0	38.2	35.8	-2.4	-2.0	-0.4
64	69	20.6	38.8	36.5	-2.4	-2.0	-0.4
781	69	22.8	41.0	37.6	-3.4	-2.0	-1.4
984	69	24.0	42.2	32.1	-10.2	-2.0	-8.2
1009	69	22.7	40.9	37.1	-3.8	-2.0	-1.8
371	70	22.9	41.1	33.4	-7.7	-2.0	-5.7
272	70	20.1	38.3	36.3	-2.1	-2.0	-0.1
280	70	21.7	39.9	34.0	-5.9	-2.0	-3.9
438	70	21.0	39.2	35.8	-3.4	-2.0	-1.4
65	70	21.9	40.2	36.7	-3.5	-2.0	-1.5
405	70	20.8	39.0	34.4	-4.6	-2.0	-2.6
75	70	21.9	40.2	35.8	-4.3	-2.0	-2.3
34	70	19.9	38.1	35.6	-2.5	-2.0	-0.5
664	70	24.0	42.2	39.5	-2.8	-2.0	-0.8
274	70	20.8	39.0	35.8	-3.2	-2.0	-1.2
71	70	19.9	38.2	37.8	-0.4	-2.0	1.6
66	70	21.6	39.8	36.9	-2.9	-2.0	-0.9
858	70	26.4	44.6	37.0	-7.6	-2.0	-5.6
285	70	20.2	38.5	35.0	-3.4	-2.0	-1.4
394	70	21.6	39.8	34.1	-5.7	-2.0	-3.7
439	70	19.5	37.8	36.1	-1.7	-2.0	0.3
97	70	21.7	39.9	35.5	-4.4	-2.0	-2.4
983	70	24.8	43.0	31.0	-12.1	-2.0	-10.1
410	70	19.0	37.2	35.6	-1.6	-2.0	0.4
418	71	18.6	36.9	36.3	-0.6	-2.0	1.4
662	71	21.8	40.1	38.3	-1.8	-2.0	0.2

## Table D.06 Tonality Assessment Table - 10 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 10 of 13

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
149	71	20.7	39.0	37.5	-1.5	-2.0	0.5
380	71	21.6	39.8	35.9	-4.0	-2.0	-2.0
134	71	20.9	39.2	37.3	-1.9	-2.0	0.1
98	71	20.5	38.7	37.4	-1.3	-2.0	0.7
46	71	22.3	40.6	36.6	-4.0	-2.0	-2.0
401	71	19.1	37.4	38.0	0.6	-2.0	2.6
399	72	20.7	38.9	38.4	-0.6	-2.0	1.4
822	72	25.4	43.6	35.8	-7.8	-2.0	-5.8
368	72	22.5	40.7	36.5	-4.2	-2.0	-2.2
417	72	18.6	36.8	38.4	1.6	-2.0	3.6
552	72	22.4	40.6	37.5	-3.1	-2.0	-1.1
784	72	24.5	42.7	38.0	-4.7	-2.0	-2.7
70	73	21.0	39.2	37.9	-1.3	-2.0	0.7
179	74	21.5	39.8	37.6	-2.2	-2.0	-0.2
Average	68				-3.2	-2.0	-1.2

## Table D.07 Tonality Assessment Table - 10.5 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 11 of 13

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
32	57	20.0	38.2	36.2	-2.0	-2.0	0.0
15	58	18.7	36.9	32.7	-4.2	-2.0	-2.2
96	58	21.0	39.2	33.2	-6.0	-2.0	-4.0
199	58	17.0	35.2	34.8	-0.4	-2.0	1.6
543	58	26.4	44.7	32.6	-12.1	-2.0	-10.1
200	58	17.4	35.7	31.6	-4.0	-2.0	-2.0
74	58	20.8	39.0	34.4	-4.6	-2.0	-2.6
84	58	20.1	38.3	34.2	-4.1	-2.0	-2.1
198	58	17.7	35.9	35.8	-0.1	-2.0	1.9
16	58	19.7	37.9	34.9	-3.0	-2.0	-1.0
191	58	19.3	37.5	35.3	-2.2	-2.0	-0.2
78	58	20.0	38.2	36.4	-1.9	-2.0	0.1
103	58	20.5	38.7	32.2	-6.5	-2.0	-4.5
12	58	19.1	37.3	32.7	-4.7	-2.0	-2.7
30	58	18.7	36.9	34.1	-2.8	-2.0	-0.8
107	58	21.2	39.5	35.6	-3.9	-2.0	-1.9
1	58	22.3	40.5	32.8	-7.7	-2.0	-5.7
203	58	18.2	36.4	34.0	-2.4	-2.0	-0.4
90	58	19.2	37.5	35.7	-1.8	-2.0	0.2
188	58	19.4	37.6	31.8	-5.9	-2.0	-3.9
185	58	20.7	39.0	32.8	-6.1	-2.0	-4.1
79	58	19.8	38.0	35.0	-3.1	-2.0	-1.1
186	58	21.1	39.4	32.8	-6.5	-2.0	-4.5
47	58	20.5	38.8	33.2	-5.6	-2.0	-3.6
108	58	22.1	40.3	33.1	-7.2	-2.0	-5.2
89	58	17.7	35.9	33.9	-2.0	-2.0	0.0
91	58	19.3	37.5	34.3	-3.2	-2.0	-1.2
184	58	20.7	39.0	34.5	-4.5	-2.0	-2.5
4	69	20.1	38.3	34.5	-3.8	-2.0	-1.8
275	69	21.4	39.7	35.8	-3.9	-2.0	-1.9
542	69	24.5	42.7	38.4	-4.3	-2.0	-2.3
63	69	20.3	38.6	35.0	-3.6	-2.0	-1.6
780	69	25.5	43.7	37.2	-6.5	-2.0	-4.5
290	70	20.4	38.6	32.1	-6.5	-2.0	-4.5
289	70	20.6	38.9	34.9	-4.0	-2.0	-2.0
24	70	18.8	37.1	34.0	-3.0	-2.0	-1.0
86	70	17.6	35.8	35.2	-0.6	-2.0	1.4
433	71	19.6	37.9	33.8	-4.1	-2.0	-2.1
180	71	22.5	40.8	34.8	-6.0	-2.0	-4.0
42	71	21.9	40.2	36.0	-4.1	-2.0	-2.1
41	71	21.8	40.0	37.9	-2.1	-2.0	-0.1
408	71	18.3	36.6	33.5	-3.0	-2.0	-1.0
406	71	19.1	37.3	35.2	-2.1	-2.0	-0.1
393	71	20.2	38.4	33.6	-4.8	-2.0	-2.8
83	71	17.8	36.1	35.6	-0.4	-2.0	1.6
45	71	21.7	39.9	33.8	-6.1	-2.0	-4.1
94	71	19.6	37.8	35.5	-2.3	-2.0	-0.3
432	71	19.4	37.7	36.6	-1.0	-2.0	1.0
93	71	20.1	38.4	33.8	-4.6	-2.0	-2.6
381	71	22.2	40.5	35.4	-5.0	-2.0	-3.0
276	72	19.7	37.9	33.1	-4.8	-2.0	-2.8
81	72	20.8	39.1	33.8	-5.3	-2.0	-3.3
123	72	18.2	36.5	35.7	-0.7	-2.0	1.3
190	72	18.9	37.2	35.1	-2.1	-2.0	-0.1

## Table D.07 Tonality Assessment Table - 10.5 m/s

Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2

Page 12 of 13

Created on: 2/22/2019

Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
2	72	20.0	38.3	35.3	-3.0	-2.0	-0.9
122	72	18.9	37.1	34.2	-3.0	-2.0	-1.0
109	72	22.4	40.7	35.9	-4.8	-2.0	-2.8
111	72	17.5	35.8	32.8	-3.0	-2.0	-1.0
863	72	23.2	41.4	38.7	-2.7	-2.0	-0.7
392	73	19.4	37.6	35.3	-2.3	-2.0	-0.3
944	78	23.2	41.4	31.4	-10.0	-2.0	-8.0
633	78	24.8	43.1	31.3	-11.8	-2.0	-9.8
574	78	23.3	41.5	33.0	-8.5	-2.0	-6.5
804	78	23.9	42.1	31.0	-11.2	-2.0	-9.1
573	78	21.8	40.1	31.4	-8.7	-2.0	-6.7
786	78	24.1	42.4	33.9	-8.4	-2.0	-6.4
801	78	22.5	40.7	34.8	-6.0	-2.0	-4.0
809	78	24.6	42.8	31.3	-11.5	-2.0	-9.5
Average	66				-3.8	-2.0	-1.8

## Table D.08 Tonality Assessment Table - 11 m/s


Project: North Kent Wind Power Project - Turbine T36 - IEC 61400-11 Measurement

Report ID: 17283.01.T36.RP2


Page 13 of 13

Created on: 2/22/2019


Measurement #	Centre frequency (Hz)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
104	58	20.7	39.0	34.9	-4.1	-2.0	-2.1
668	58	24.5	42.8	32.1	-10.6	-2.0	-8.6
189	58	18.7	36.9	33.7	-3.2	-2.0	-1.2
3	58	19.1	37.3	33.1	-4.2	-2.0	-2.2
10	58	19.0	37.2	33.2	-4.0	-2.0	-2.0
121	58	17.5	35.7	31.5	-4.2	-2.0	-2.2
949	58	26.6	44.8	32.7	-12.1	-2.0	-10.1
11	58	17.7	36.0	33.8	-2.2	-2.0	-0.2
28	58	21.3	39.5	33.2	-6.3	-2.0	-4.3
26	58	18.7	37.0	34.1	-2.9	-2.0	-0.9
50	58	18.2	36.4	34.5	-1.9	-2.0	0.1
124	58	17.5	35.7	36.6	0.8	-2.0	2.8
613	58	22.8	41.0	31.2	-9.9	-2.0	-7.9
671	58	24.5	42.7	34.5	-8.2	-2.0	-6.2
20	58	19.2	37.5	35.4	-2.1	-2.0	-0.1
8	58	19.3	37.5	32.4	-5.1	-2.0	-3.1
60	58	18.9	37.2	33.7	-3.5	-2.0	-1.5
19	58	20.7	39.0	31.9	-7.1	-2.0	-5.1
187	58	21.0	39.2	32.7	-6.5	-2.0	-4.5
119	58	19.2	37.4	31.9	-5.5	-2.0	-3.5
14	58	19.5	37.7	32.5	-5.2	-2.0	-3.2
59	58	18.6	36.9	34.7	-2.1	-2.0	-0.1
843	58	24.6	42.8	34.6	-8.2	-2.0	-6.2
73	58	21.1	39.3	33.4	-5.9	-2.0	-3.9
131	58	18.7	37.0	33.2	-3.7	-2.0	-1.7
53	58	17.3	35.6	35.4	-0.1	-2.0	1.9
127	58	16.3	34.6	34.3	-0.3	-2.0	1.7
128	58	16.9	35.1	33.6	-1.5	-2.0	0.5
625	58	22.3	40.5	34.8	-5.8	-2.0	-3.8
126	60	18.9	37.2	38.0	0.9	-2.0	2.9
1040	69	26.2	44.4	34.6	-9.9	-2.0	-7.9
635	69	23.7	41.9	35.3	-6.6	-2.0	-4.6
52	69	19.0	37.3	36.8	-0.5	-2.0	1.5
580	69	22.2	40.5	37.7	-2.8	-2.0	-0.8
13	69	20.0	38.2	35.2	-3.0	-2.0	-1.0
523	69	24.5	42.7	38.5	-4.3	-2.0	-2.3
941	69	23.3	41.5	35.1	-6.5	-2.0	-4.4
378	69	20.6	38.9	34.3	-4.5	-2.0	-2.5
520	69	24.1	42.4	36.9	-5.4	-2.0	-3.4
938	69	25.9	44.1	38.3	-5.9	-2.0	-3.9
1006	70	23.4	41.6	34.0	-7.6	-2.0	-5.6
87	70	17.7	36.0	36.0	0.1	-2.0	2.1
407	70	18.7	36.9	33.6	-3.4	-2.0	-1.4
536	70	20.9	39.1	35.0	-4.2	-2.0	-2.2
996	71	25.4	43.6	33.4	-10.2	-2.0	-8.2
541	71	25.9	44.1	34.9	-9.2	-2.0	-7.2
694	71	22.6	40.8	35.0	-5.8	-2.0	-3.8
402	71	19.4	37.6	34.8	-2.8	-2.0	-0.8
43	71	21.8	40.1	33.5	-6.6	-2.0	-4.6
529	71	22.6	40.9	36.5	-4.4	-2.0	-2.4
987	71	25.9	44.2	32.2	-12.0	-2.0	-10.0
540	71	23.5	41.8	33.6	-8.2	-2.0	-6.2
95	71	20.6	38.9	33.7	-5.2	-2.0	-3.2
374	71	20.8	39.0	33.6	-5.4	-2.0	-3.4




 <span>aercoustics</span>	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 7.5 m/s
		<b>Figure D.01</b>




 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 8.0 m/s
<b>Figure D.02</b>		




 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 8.5 m/s
		<b>Figure D.03</b>




 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 9.0 m/s
<b>Figure D.04</b>		




 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 9.5 m/s
		<b>Figure D.05</b>




 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 10.0 m/s
<b>Figure D.06</b>		




 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 10.5 m/s
<b>Figure D.07</b>		




 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 11.0 m/s
<b>Figure D.08</b>		



 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 11.5 m/s
<b>Figure D.09</b>		



 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 12.0 m/s
<b>Figure D.10</b>		



 aercoustics	17283.01.T36.RP2	<b>Project Name</b> North Kent Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T36
	Scale: NTS Drawn by: DEA Reviewed by: MAD Date: Feb 2019 Revision: 1	<b>Figure Title</b> Plot of narrow band spectra - Turbine ON vs. Background at 12.5 m/s
<b>Figure D.11</b>		

---

## Appendix E Measurement Data

---













# Table E.01 Measurement data - Turbine ON

Project: North Kent Wind Farm - Turbine T36 - IEC 61400-11 Measurement

Report ID:17283.01.T36.RP2

Page 7 of 7

Created on: 2/22/2019

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
1057	10.3	52.6	2736	310.0	316.3	1.9	13.0	10.6	8.5	-3.1	99340.9	49
1058			2749	310.0	315.8	1.8	13.1	10.5	7.7	-3.1	99339.6	49

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (kPa)	Relative Humidity (%)
1145												
1146												









---

## **Appendix F**

### **Supplementary Information for the Regulator**

---

---

## Appendix F.01 Calibration Certificates

---

Certificate number: **2018-22163146**

# Adjustment report

**Product type: LMS SCADAS**

Calibration Suite: **Calibration Software**  
Calibration Suite Version: **2.10.0001**

**Customer:**

Company name :Aeroustics Engineering Limited  
Location (city / country) : Mississauga / ON  
Contact person : Iwona Stasiewicz

**System:**

System type(s) : SCR202  
Serial number(s) : 22163146

**Adjustment conditions:**

TAC reference number : 8946966  
Location (factory, office or on-site) : factory  
Date : February 27, 2018  
Ambient temperature : 23,4 °C  
Previous adjustment / calibration date : August 2016

**Adjustment results** (refer to page 2 for details) :

Adjustment successful : YES  
Within published specification : YES  
Within test specification : YES

**Report approved by:**

Name : Mr. H. Dam



(Signature).....



## ISO 17025

## As Left RECALIBRATION CERTIFICATE

Sales Region:	NA
Account:	Aercoustics Engineering Limited
Instrument:	LMS SCADAS
Manufacturer:	Siemens Industry Software B.V.
Type:	SCR202
Serial number(s):	22163146
Calibration method:	Two calibrated external standards (DC voltage and frequency) are used to calibrate the internal LMS SCADAS references: time/frequency accuracy of the internal system clock and amplitude accuracy of the internal signal sources. All input channels are calibrated against the internal references.
Ambient conditions:	The calibrations have been carried out in a controlled environment, at an ambient temperature of $23.3^{\circ}\text{C} \pm 0.3^{\circ}\text{C}$ and a relative humidity of $21\% \pm 5\%$ .
Calibration date:	February 27, 2018
Results:	The calibration results, together with their associated uncertainties, are included in this calibration certificate. <i>Calibration results within specification.</i>
Uncertainty:	The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$ , which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty of measurement has been determined in accordance with publication EA-4/02.
Traceability:	The measurements have been executed using methods for which the traceability to international standards has been demonstrated towards the Raad voor Accreditatie.

Breda, February 27, 2018

Calibration performed by:

Hans Dam, Customer Service Engineer

Certificate approved by:

F. Lemmens, Production Manager

The Raad voor Accreditatie is one of the signatories of the Multilateral Agreement of the European Cooperation for Accreditation (EA) for the mutual recognition of calibration certificates.

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.

This certificate is issued provided that neither Siemens Industry Software B.V. nor the Raad voor Accreditatie assumes any liability.

Certificate number: 22163146-20180227-1

Page: 1 of 16



## ISO 17025

## As Found RECALIBRATION CERTIFICATE

Sales Region:	NA
Account:	Aeracoustics Engineering Limited
Instrument:	LMS SCADAS
Manufacturer:	Siemens Industry Software B.V.
Type:	SCR202
Serial number(s):	22163146
Calibration method:	Two calibrated external standards (DC voltage and frequency) are used to calibrate the internal LMS SCADAS references: time/frequency accuracy of the internal system clock and amplitude accuracy of the internal signal sources. All input channels are calibrated against the internal references.
Ambient conditions:	The calibrations have been carried out in a controlled environment, at an ambient temperature of $23.4^{\circ}\text{C} \pm 0.3^{\circ}\text{C}$ and a relative humidity of $19\% \pm 5\%$ .
Calibration date:	February 27, 2018
Results:	The calibration results, together with their associated uncertainties, are included in this calibration certificate. <i>Calibration results within specification.</i>
Uncertainty:	The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$ , which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty of measurement has been determined in accordance with publication EA-4/02.
Traceability:	The measurements have been executed using methods for which the traceability to international standards has been demonstrated towards the Raad voor Accreditatie.

Breda, February 27 2018

Calibration performed by:

Hans Dam, Customer Service Engineer

Certificate approved by:

Frank Lemmens, Production Manager

The Raad voor Accreditatie is one of the signatories of the Multilateral Agreement of the European Cooperation for Accreditation (EA) for the mutual recognition of calibration certificates.

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.

This certificate is issued provided that neither Siemens Industry Software B.V. nor the Raad voor Accreditatie assumes any liability.

Certificate number: 22163146-20180227-0

Page: 1 of 16

# West Caldwell Calibration Laboratories Inc.

## Certificate of Calibration

for

### MICROPHONE UNIT

Manufactured by: BRUEL & KJAER  
Model No: 4189-A-021  
Serial No: 2622169  
Calibration Recall No: 28016

Submitted By:

Customer:

Company: Aercoustics Engineering LTD.  
Address:

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. 4189-A-021 BRUE

Upon receipt for Calibration, the instrument was found to be:

Within ( X )

tolerance of the indicated specification. See attached Report of Calibration.

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by: *FC*

Calibration Date: 05-Sep-17

Felix Christopher (QA Mgr.)

Certificate No: 28016 - 1

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

ISO/IEC 17025:2005

uncompromised calibration  
West Caldwell  
Calibration  
Laboratories, Inc.  
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01

**West Caldwell  
Calibration  
Laboratories, Inc.**  
uncompromised calibration  
1575 State Route 96, Victor NY 14564



Calibration Lab. Cert. # 1533.01

## REPORT OF CALIBRATION

for

Brüel &amp; Kjær Microphone Unit

Model No.: 4189-A-021

Serial No.: 2622169

Mic. Model No.: 4189

Serial No.: 2625417

Preamp. Model No.: 2671

Serial No.: 2614900

Company: Aercoustics Engineering LTD.

I. D. No.: XXXX

## Calibration results:

Before & after data same: ...X...  
 Combined Sensitivity @ 250 Hz and pressure of 98.432 kPa Ambient Temperature: 21.8 °C  
 (Sens. with mic. and preamp.) 0 Volts Polarization voltage (External): Ambient Humidity: 56.4 % RH  
 -26.54 dB re.1V/Pascal Ambient Pressure: 98.432 kPa  
 47.10 mV/Pascal Calibration Date: 5-Sep-2017  
 0.54 Ko (- dB re 50 mV/Pascal) Calibration Due: 5-Sep-2018  
 Sensitivity: Pass Report Number: 28016 -1  
 Freq. Response: Pass Control Number: 28016  
 All tests: Pass

The above listed instrument meets or exceeds the tested manufacturer's specifications.


The IEC 651:1979 &amp; 1993 Type 1 specification passed.

This Calibration is traceable through NIST test numbers: 683/284413-14

The expanded uncertainty of calibration: 0.079dB at 95% confidence level with a coverage factor of k=2.

The pressure response recorded with electroacoustic method.

## Frequency Response



The above listed instrument was checked using calibration procedure documented in West Caldwell

Calibration Laboratories Inc. procedure : Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189A021B&amp;K

Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures

intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Measurements performed by: .....

James Zhu

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189A021B&amp;K

**West Caldwell Calibration Laboratories Inc.**

1575 State Route 96, Victor NY 14564

Tel. (585) 586-3900 FAX (585) 586-4327

***Calibration Data Record***

for

Model No.: 4189-A-021

Brüel &amp; Kjær Microphone Unit

Company: Aercoustics Engineering LTD.

Serial No.: 2622169

I. D. No.: XXXX

**Frequency Response ( Reference = 0 dB @ 250Hz )**

Frequency [Hz]	Pressure [dB]	Free Field (dB)	Random (dB)
19.95	-0.85	-0.85	-0.85
25.12	-0.51	-0.51	-0.51
31.62	-0.28	-0.28	-0.28
39.81	-0.14	-0.14	-0.14
50.12	-0.06	-0.06	-0.06
63.10	-0.02	-0.02	-0.02
79.43	-0.01	-0.01	-0.01
100.00	0.00	0.00	0.00
125.89	0.00	0.00	0.00
158.49	0.00	0.00	0.00
199.53	0.01	0.01	0.01
251.19	0.00	0.00	0.00
316.23	0.00	0.00	0.00
398.11	-0.01	0.00	-0.01
501.19	-0.01	0.01	-0.01
630.96	-0.02	0.01	-0.02
794.33	-0.05	0.02	-0.05
1000.00	-0.09	0.01	-0.11
1258.93	-0.14	0.01	-0.17
1584.89	-0.23	-0.01	-0.29
1995.26	-0.39	-0.06	-0.39
2511.89	-0.59	-0.11	-0.55
3162.28	-0.94	-0.23	-0.91
3981.07	-1.51	-0.45	-1.42
5011.87	-2.11	-0.53	-1.97
6309.57	-3.15	-0.87	-2.83
7943.28	-4.38	-1.00	-3.63
10000.00	-5.92	-0.80	-4.39
12589.25	-7.13	0.07	-4.62
15848.93	-9.80	-1.21	-7.22
19952.62	-12.02	-1.97	-9.54

Freq. response: Expanded Uncertainty (dB) with coverage factor K = 2

20 to 63Hz 0.1dB, 63 to 12.5kHz 0.094dB, 12.5k to 16kHz 0.10dB, 16k to 20kHz 0.5dB.

Instruments used for calibration:		Date of Cal.	Traceability No.	Re-cal. Due Date
Brüel & Kjær	4226	S/N 1445428	3-Nov-2016	683/284413-14
Brüel & Kjær	3560	S/N 2202374	3-Nov-2016	683/284413-14
HP	33120A	S/N 36043716	1-Oct-2016	,287708
HP	34401A	S/N 36064102	1-Oct-2016	,287708

Cal. Date: 5-Sep-2017

Tested by: James Zhu

Calibrated on WCCL system type 9700

This document shall not be reproduced except in full without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189A021B&amp;K

# West Caldwell Calibration Laboratories Inc.

## Certificate of Calibration

for

### ACOUSTICAL CALIBRATOR

Manufactured by: BRUEL & KJAER  
Model No: 4231  
Serial No: 3012380  
Calibration Recall No: 28460

Submitted By:

Customer:

Company: Aeroustics Engineering Ltd.  
Address:

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. 4231 BRUE

Upon receipt for Calibration, the instrument was found to be:

Within ( X )

tolerance of the indicated specification. See attached Report of Calibration.

The information supplied relates to the calibrated item listed above.

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by: 

Calibration Date: 30-Jan-18

Felix Christopher (QA Mgr.)

Certificate No: 28460 - 2

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

ISO/IEC 17025:2005

uncompromised calibration  
West Caldwell  
Calibration  
Laboratories, Inc.  
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01

**West Caldwell  
Calibration  
Laboratories, Inc.**  
uncompromised calibration  
1575 State Route 96, Victor NY 14564



Calibration Lab. Cert. # 1533.01

## REPORT OF CALIBRATION

for

**Brüel & Kjær Acoustical Calibrator  
Company: Aercoustics Engineering Ltd.**

Model No.: 4231

Serial No.: 3012380  
ID No.: XXXX

## Calibration results:

Before data: ..... After data: .....

Before &amp; after data same: ...X...

Sound Pressure Level at 1000.0 Hz and pressure of 1013 hPa (mbar)  
was 114.03 dB re 20  $\mu$ Pa

(Calibrator tested with 1/2" adaptor UC 0210)

IEC 1094-4 Type WS 2 P Microphone was used for measurement.

114 dB 94 dB

Sound Pressure Level: Pass Pass

Frequency: Pass Pass

Distortion: Pass Pass

Stability: Pass Pass

All tested parameters: Pass

## Laboratory Environment:

Ambient Temperature: 22.0 °C

Ambient Humidity: 30.9 % RH

Ambient Pressure: 99.768 kPa

Calibration Date: 30-Jan-2018

Calibration Due: 30-Jan-2019

Report Number: 28460 -2

Control Number: 28460

The above listed instrument meets or exceeds the tested manufacturer's specifications


The IEC 942:1988 Class 1 specifications, passed.

The ANSI S1.4-1984 specifications, passed.

This Calibration is traceable through NIST test numbers: 822/275722-14

The expanded uncertainty of calibration: 0.11 dB at 95% confidence level with a coverage factor of k=2.

Graph represents six samples of Sound Pressure Level measured at 5 sec. interval.



The above listed instrument was checked using calibration procedure documented in West Caldwell Calibration Laboratories Inc. procedure :

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&amp;K

Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures

intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Cal. Date: 30-Jan-2018

Measurements performed by: .....

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&amp;K

**West Caldwell Calibration Laboratories Inc.**

1575 State Route 96, Victor NY 14564

Tel. (585) 586-3900 FAX (585) 586-4327

**Calibration Data Record**

**Brüel & Kjær Acoustical Calibrator**  
**Company: Aercoustics Engineering Ltd.**

for  
**Model No.: 4231**

**Serial No.: 3012380****All tested parameters: Pass****Measured Sound Pressure Level ( Six samples measured at 5 sec. interval)**

Sample	1	114.03 dB re 20 µPa	94.05 dB re 20 µPa
	2	114.03	94.05
	3	114.03	94.05
	4	114.03	94.05
	5	114.03	94.04
	6	114.03	94.05
<b>Average</b>	<b>114.03</b>	Spec. 114dB ± 0.2dB	<b>94.05</b>
			Spec. 94 dB ± 0.2 dB

**Frequency measured (Three samples at 30 sec. Interval)**

Sample	1	999.99 Hz	999.99 Hz
	2	999.99	999.99
	3	999.99	999.98
<b>Average</b>	<b>999.99</b>	<b>999.99</b>	Spec. 1000 Hz ±0.1%

The Frequency expanded uncertainty of calibration:45 µHz/Hz at 95% confidence level with a coverage factor of k=2.

<b>Distortion measured</b>	-56.2 dB	-54.9 dB	Spec. ≤40 dB
----------------------------	----------	----------	--------------

Instruments used for calibration:			Date of Cal.	Traceability No.	Re-cal. Due Date
Brüel & Kjær	4231	S/N 2308998	1-Aug-2017	822/275722-14	1-Aug-2018
Brüel & Kjær	4134	S/N 854464	1-Aug-2017	822/275722-14	1-Aug-2018
Brüel & Kjær	2669	S/N 2148476	1-Aug-2017	683/281764-14	1-Aug-2018
HP	34401A	S/N US360980	1-Aug-2017	,205342	1-Aug-2018
Brüel & Kjær	2636	S/N 1323964	1-Aug-2017	822/275722-14	1-Aug-2018
HP	33120A	S/N US360458	1-Aug-2017	,205342	1-Aug-2018

Cal. Date: 30-Jan-2018

Tested by: James Zhu

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&amp;K



# SOH Wind Engineering LLC

141 Leroy Road · Williston, VT 05495 · USA

Tel 802.316.4368 · Fax 802.735.9106 · [www.sohwind.com](http://www.sohwind.com)

## CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

**Certificate number:** 17.US1.10370

**Date of issue:** November 16, 2017

**Type:** Vaisala Weather Transmitter, WXT520

**Serial number:** G4420002

**Manufacturer:** Vaisala, Oyj, Pl 26, FIN-00421 Helsinki, Finland

**Client:** Aeroustics Engineering Ltd., 1004 Middlegate RD, Suite 1100, S.Tower, Mississauga, ON L4Y 1M4, Canada

**Anemometer received:** November 15, 2017

**Anemometer calibrated:** November 15, 2017

**Calibrated by:** MEJ

**Procedure:** MEASNET, IEC 61400-12-1:2017 Annex F

**Certificate prepared by:** EJF

**Approved by:** Calibration engineer, EJF

**Calibration equation obtained:**  $v [\text{m/s}] = 1.00118 \cdot f [\text{m/s}] + 0.06286$

**Standard uncertainty, slope:** 0.00077

**Standard uncertainty, offset:** 0.13048

**Covariance:** -0.0000059  $(\text{m/s})^2/\text{m/s}$



**Coefficient of correlation:**  $\rho = 0.999997$

**Absolute maximum deviation:** -0.019 m/s at 3.969 m/s

**Barometric pressure:** 1011.5 hPa

**Relative humidity:** 21.9%

Succession	Velocity pressure, q. [Pa]	Temperature in wind tunnel [°C]	Wind velocity, v. [m/s]	Anemometer Output, f. [m/s]	Deviation, d. [m/s]	Uncertainty $u_c (k=2)$ [m/s]
2	9.39	22.0	26.0	3.969	3.9200	-0.019
4	14.85	22.0	26.0	4.992	4.9103	0.013
6	21.38	22.0	26.0	5.990	5.9100	0.011
8	29.13	22.1	26.0	6.993	6.9333	-0.011
10	38.09	22.1	26.0	7.996	7.9200	0.004
12	48.35	22.1	26.0	9.010	8.9233	0.013
13-last	59.50	22.1	26.0	9.996	9.9172	0.004
11	72.14	22.0	26.0	11.006	10.9400	-0.010
9	85.76	22.0	26.0	12.000	11.9300	-0.007
7	100.55	22.0	26.0	12.993	12.9200	-0.005
5	116.73	22.0	26.0	14.000	13.9150	0.006
3	133.56	22.0	26.0	14.974	14.8900	0.004
1-first	152.12	21.9	26.0	15.979	15.9000	-0.003



AC-1746



## EQUIPMENT USED

Serial Number	Description
Njord1	Wind tunnel, blockage factor = 1.0035
2254	Control cup anemometer
-	Mounting tube, D = 19 mm
TT003	Summit Electronics, 1XPT100, 0-10V Output, wind tunnel temp.
TP001	PR Electronics 5102, 0-10V Output, differential pressure box temp.
DP004	Setra Model 239, 0-1inWC, differential pressure transducer
HY002	Dwyer RHP-2D20, 0-10V Output, humidity transmitter
BP001	Setra Model 278, barometer
PL8	Pitot tube
XB002	Computer Board. 16 bit A/D data acquisition board
9PRZRW1	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Atlantic Scale, Esco Calibration Labs & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.



*Photo of the wind tunnel setup. The cross-sectional area is 2.5m x 2.5m.*

## UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ( $k=2$ ) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.12.01.004 for further details.

## COMMENTS

This sensor was calibrated at 0° for this certificate.

Certificate number: 17.US1.10370

All calibrations are done in the "As Left" condition unless otherwise noted.

This certificate must not be reproduced, except in full, without the approval of SOH Wind Engineering LLC



# SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.316.4368 • Fax 802.735.9106 • [www.sohwind.com](http://www.sohwind.com)

## CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

**Certificate number:** 17.US1.10369

**Date of issue:** November 16, 2017

**Type:** Vaisala Weather Transmitter, WXT520

**Serial number:** G4420002

**Manufacturer:** Vaisala, Oyj, PI 26, FIN-00421 Helsinki, Finland

**Client:** Aeroustics Engineering Ltd., 1004 Middlegate RD, Suite 1100, S.Tower, Mississauga, ON L4Y 1M4, Canada

**Anemometer received:** November 15, 2017

**Anemometer calibrated:** November 15, 2017

**Calibrated by:** MEJ

**Procedure:** MEASNET, IEC 61400-12-1:2017 Annex F

**Certificate prepared by:** EJF

**Approved by:** Calibration engineer, EJF

**Calibration equation obtained:**  $v [m/s] = 1.02399 \cdot f [m/s] + 0.09265$

**Standard uncertainty, slope:** 0.00156

**Standard uncertainty, offset:** 0.17838

**Covariance:** -0.0000247 (m/s)<sup>2</sup>/m/s



**Coefficient of correlation:**  $\rho = 0.999987$

**Absolute maximum deviation:** -0.046 m/s at 15.979 m/s

**Barometric pressure:** 1011.1 hPa

**Relative humidity:** 22.0%

Succession	Velocity pressure, q. [Pa]	Temperature in wind tunnel [°C]	Temperature in d.p. box [°C]	Wind velocity, v. [m/s]	Anemometer Output, f. [m/s]	Deviation, d. [m/s]	Uncertainty $u_c (k=2)$ [m/s]
2	9.41	22.0	26.0	3.975	3.8100	-0.019	0.024
4	14.86	22.0	26.0	4.996	4.7897	-0.002	0.025
6	21.40	22.1	26.0	5.994	5.7700	-0.007	0.027
8	29.14	22.1	26.0	6.996	6.7533	-0.012	0.029
10	38.16	22.1	26.0	8.006	7.7300	-0.002	0.032
12	48.35	22.1	26.0	9.012	8.6900	0.021	0.035
13-last	59.54	22.1	26.0	10.001	9.6448	0.032	0.038
11	72.13	22.1	26.0	11.009	10.6533	0.007	0.041
9	85.87	22.1	26.0	12.012	11.6300	0.010	0.044
7	100.56	22.1	26.0	12.998	12.6100	-0.008	0.047
5	116.94	22.0	26.0	14.015	13.5767	0.020	0.050
3	133.53	22.0	26.0	14.976	14.5300	0.005	0.053
1-first	152.03	22.0	26.0	15.979	15.5600	-0.046	0.057



AC-1746



Page 1 of 2

## EQUIPMENT USED

Serial Number	Description
Njord1	Wind tunnel, blockage factor = 1.0035
2254	Control cup anemometer
-	Mounting tube, D = 19 mm
TT003	Summit Electronics, 1XPT100, 0-10V Output, wind tunnel temp.
TP001	PR Electronics 5102, 0-10V Output, differential pressure box temp.
DP004	Setra Model 239, 0-1inWC, differential pressure transducer
HY002	Dwyer RHP-2D20, 0-10V Output, humidity transmitter
BP001	Setra Model 278, barometer
PL8	Pitot tube
XB002	Computer Board. 16 bit A/D data acquisition board
9PRZRW1	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Atlantic Scale, Esco Calibration Labs & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.



*Photo of the wind tunnel setup. The cross-sectional area is 2.5m x 2.5m.*

## UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ( $k=2$ ) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.12.01.004 for further details.

## COMMENTS

This sensor was calibrated at 90° for this certificate.

Certificate number: 17.US1.10369

All calibrations are done in the "As Left" condition unless otherwise noted.

This certificate must not be reproduced, except in full, without the approval of SOH Wind Engineering LLC

# CERTIFICATE OF CALIBRATION

Customer: AEROCOUSTICS ENGINEERING LTD  
1004 MIDDLEGATE ROAD  
SUITE 1100  
MISSISSAUGA, ON L4Y 1M4  
PO Number: TR2018-02-14

Manufacturer: Noveval  
Model Number: 7470  
Description: Serial to Analog Converter  
Serial Number: A159784  
ID: NONE

**Certificate/ISO Number: 33-Q0W0C-20-1 Revision 0**

As-Found: In Tolerance  
As-Left: In Tolerance

Calibration Date: Feb 20, 2018  
Due Date: Feb 20, 2020

Calibrated To: Manufacturer Specification

Calibration Procedure: 1-AC58014-0



SCC Lab No 827

Transcat Calibration Laboratories have been audited and found in compliance with ISO/IEC 17025:2005. Accredited calibrations performed within the Lab's Scope of Accreditation are indicated by the presence of the Accrediting Body's Logo and Certificate Number. Any measurements on an accredited calibration not covered by that Lab's Scope of Accreditation are listed in the notes section of the certificate. SCC, NRC, CLAS or ANAB do not guarantee the accuracy of an individual calibration by accredited laboratories.

Transcat calibrations, as applicable, are performed in compliance with the requirements of the Transcat Quality Manual QAC-P01-000 Revision 1.0, the customer's Purchase Order and/or Quality Agreement requirements, ISO 9001:2008, ANSI/NCSL Z540.1-1994 (R2002). Complete records of work performed are maintained by Transcat and are available for inspection. Laboratory standards used in the performance of this calibration are listed below.

Transcat documents the traceability of measurements to the SI units through the National Institute of Standards and Technology (NIST), or the National Research Council of Canada (NRC), or other national measurement institutes (NMI) that are signatories to the CIPM Mutual Recognition Arrangement, or accepted fundamental and/or natural physical constants, or by the use of specified methods, consensus standards or ratio type measurements. Documentation supporting traceability information is available for review upon written request at a Transcat facility. The measured quantity and the measurement uncertainty are required for further dissemination of traceability.

Uncertainties are reported with a coverage factor  $k=2$ , providing a level of confidence of approximately 95%. All calibrations have been performed using processes having a TUR of 4:1 or better (3:1 for mass calibrations), unless otherwise noted. The Test Uncertainty Ratio (TUR) is calculated in accordance with NCSL International RP-18. For mass calibrations: Conventional mass referenced to 8.0 g/cm<sup>3</sup>.

The results in this report relate only to the item calibrated or tested. Recorded calibration data is valid at the time of calibration within the stated uncertainties at the environmental conditions noted. The determination of compliance to the specification is specific to the model/serial no./ID no. referenced above based on the tolerances shown; these tolerances are either the original equipment manufacturers (OEM's) warranted specifications or the client's requested specifications. This certificate may not be reproduced except in full, without the written approval of Transcat. Additional information, if applicable may be included on separate report(s).

# CERTIFICATE OF CALIBRATION

Customer: AEROACOUSTICS ENGINEERING LTD  
 1004 MIDDLEGATE ROAD  
 SUITE 1100  
 MISSISSAUGA, ON L4Y 1M4  
 PO Number: TR2018.02.14

Date Received: February 15, 2018  
 Service Level: R9

Certificate/SO Number: 33-Q0W0C-20-1 Revision 0

SCC Lab No 827



## As Found/As Left Data

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	Cal Process O Uncertainty (k=2; ±)	Measurement Uncertainty (k=2; ±)	Units	TUR
<b>DC Current % Source - 4-20mA Ch #1</b>									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	3.996 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	7.995 mA	2.7e-004	1.9e-003	mA	59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	12.000 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	15.999 mA	1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	19.998 mA	1.4e-003	2.3e-003	mA	11.4 : 1
<b>DC Current % Source - 4-20mA Ch #2</b>									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	3.996 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	7.999 mA	2.7e-004	1.9e-003	mA	59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	11.997 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.002 mA	1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	19.999 mA	1.4e-003	2.3e-003	mA	11.4 : 1
<b>DC Current % Source - 4-20mA Ch #3</b>									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	3.996 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	7.996 mA	2.7e-004	1.9e-003	mA	59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	11.996 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.002 mA	1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.002 mA	1.4e-003	2.3e-003	mA	11.4 : 1
<b>DC Current % Source - 4-20mA Ch #4</b>									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	3.997 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	7.995 mA	2.7e-004	1.9e-003	mA	59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	11.999 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	15.997 mA	1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.001 mA	1.4e-003	2.3e-003	mA	11.4 : 1

# CERTIFICATE OF CALIBRATION

Customer: AEROACOUSTICS ENGINEERING LTD  
 1004 MIDDLEGATE ROAD  
 SUITE 1100  
 MISSISSAUGA, ON L4Y 1M4  
 PO Number: TR2018.02.14

Date Received: February 15, 2018  
 Service Level: R9

Certificate/SO Number: 33-Q0W0C-20-1 Revision 0

## As Found/As Left Data

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	Cal Process Uncertainty (k=2; $\pm$ )	Measurement Uncertainty (k=2; $\pm$ )	Units	TUR
<b>DC Current % Source - 0-20mA Ch #1</b>									
0 - 20mA	0%	$\pm(0.1\% \text{ Span})$	-0.020	0.020	0.000 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	$\pm(0.1\% \text{ Span})$	4.980	5.020	4.997 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	$\pm(0.1\% \text{ Span})$	9.980	10.020	9.997 mA	3.2e-004	2.3e-003	mA	62.5 : 1
	75%	$\pm(0.1\% \text{ Span})$	14.980	15.020	14.998 mA	1.2e-003	2.6e-003	mA	16.7 : 1
	100%	$\pm(0.1\% \text{ Span})$	19.980	20.020	19.998 mA	1.4e-003	2.7e-003	mA	14.3 : 1
<b>DC Current % Source - 0-20mA Ch #2</b>									
0 - 20mA	0%	$\pm(0.1\% \text{ Span})$	-0.020	0.020	0.002 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	$\pm(0.1\% \text{ Span})$	4.980	5.020	4.996 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	$\pm(0.1\% \text{ Span})$	9.980	10.020	10.000 mA	3.2e-004	2.3e-003	mA	62.5 : 1
	75%	$\pm(0.1\% \text{ Span})$	14.980	15.020	15.000 mA	1.2e-003	2.6e-003	mA	16.7 : 1
	100%	$\pm(0.1\% \text{ Span})$	19.980	20.020	19.999 mA	1.4e-003	2.7e-003	mA	14.3 : 1
<b>DC Current % Source - 0-20mA Ch #3</b>									
0 - 20mA	0%	$\pm(0.1\% \text{ Span})$	-0.020	0.020	0.001 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	$\pm(0.1\% \text{ Span})$	4.980	5.020	4.996 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	$\pm(0.1\% \text{ Span})$	9.980	10.020	9.996 mA	3.2e-004	2.3e-003	mA	62.5 : 1
	75%	$\pm(0.1\% \text{ Span})$	14.980	15.020	14.996 mA	1.2e-003	2.6e-003	mA	16.7 : 1
	100%	$\pm(0.1\% \text{ Span})$	19.980	20.020	20.001 mA	1.4e-003	2.7e-003	mA	14.3 : 1
<b>DC Current % Source - 0-20mA Ch #4</b>									
0 - 20mA	0%	$\pm(0.1\% \text{ Span})$	-0.020	0.020	0.001 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	$\pm(0.1\% \text{ Span})$	4.980	5.020	4.992 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	$\pm(0.1\% \text{ Span})$	9.980	10.020	9.997 mA	3.2e-004	2.3e-003	mA	62.5 : 1
	75%	$\pm(0.1\% \text{ Span})$	14.980	15.020	14.996 mA	1.2e-003	2.6e-003	mA	16.7 : 1
	100%	$\pm(0.1\% \text{ Span})$	19.980	20.020	20.001 mA	1.4e-003	2.7e-003	mA	14.3 : 1

# CERTIFICATE OF CALIBRATION

Customer: AEROACOUSTICS ENGINEERING LTD  
 1004 MIDDLEGATE ROAD  
 SUITE 1100  
 MISSISSAUGA, ON L4Y 1M4  
 PO Number: TR2018.02.14



PO Number: TR2018.02.14

Certificate/SO Number: 33-Q0W0C-20-1 Revision 0

## As Found/As Left Data

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O Uncertainty (k=2; ±)	Cal Process Uncertainty (k=2; ±)	Measurement Uncertainty (k=2; ±)	Units	TUR
<b>DC Voltage % Source - 0-5V Ch#1</b>										
0 -5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0009 V	5.0e-007	5.8e-004	v	100.0 : 1	
	20%	±(0.1% Span)	0.9950	1.0050	1.0010 V	5.5e-006	5.8e-004	v	100.0 : 1	
	40%	±(0.1% Span)	1.9950	2.0050	2.0001 V	1.1e-005	5.8e-004	v	100.0 : 1	
	60%	±(0.1% Span)	2.9950	3.0050	2.9984 V	1.6e-005	5.8e-004	v	100.0 : 1	
	80%	±(0.1% Span)	3.9950	4.0050	4.0001 V	2.1e-005	5.8e-004	v	100.0 : 1	
	100%	±(0.1% Span)	4.9950	5.0050	4.9988 V	2.6e-005	5.8e-004	v	100.0 : 1	
<b>DC Voltage % Source - 0-5V Ch#2</b>										
0 -5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0002 V	5.0e-007	5.8e-004	v	100.0 : 1	
	20%	±(0.1% Span)	0.9950	1.0050	1.0000 V	5.5e-006	5.8e-004	v	100.0 : 1	
	40%	±(0.1% Span)	1.9950	2.0050	2.0010 V	1.1e-005	5.8e-004	v	100.0 : 1	
	60%	±(0.1% Span)	2.9950	3.0050	2.9980 V	1.6e-005	5.8e-004	v	100.0 : 1	
	80%	±(0.1% Span)	3.9950	4.0050	3.9980 V	2.1e-005	5.8e-004	v	100.0 : 1	
	100%	±(0.1% Span)	4.9950	5.0050	5.0000 V	2.6e-005	5.8e-004	v	100.0 : 1	
<b>DC Voltage % Source - 0-5V Ch#3</b>										
0 -5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0001 V	5.0e-007	5.8e-004	v	100.0 : 1	
	20%	±(0.1% Span)	0.9950	1.0050	0.9985 V	5.5e-006	5.8e-004	v	100.0 : 1	
	40%	±(0.1% Span)	1.9950	2.0050	1.9991 V	1.1e-005	5.8e-004	v	100.0 : 1	
	60%	±(0.1% Span)	2.9950	3.0050	2.9982 V	1.6e-005	5.8e-004	v	100.0 : 1	
	80%	±(0.1% Span)	3.9950	4.0050	4.0008 V	2.1e-005	5.8e-004	v	100.0 : 1	
	100%	±(0.1% Span)	4.9950	5.0050	5.0015 V	2.6e-005	5.8e-004	v	100.0 : 1	

# CERTIFICATE OF CALIBRATION

Customer: AEROACOUSTICS ENGINEERING LTD  
 1004 MIDDLEGATE ROAD  
 SUITE 1100  
 MISSISSAUGA, ON L4Y 1M4  
 PO Number: TR2018.02.14



## Certificate/SO Number: 33-Q0W0C-20-1 Revision 0

### As Found/As Left Data

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O Uncertainty (k=2; ±)	Cal Process O Uncertainty (k=2; ±)	Measurement Uncertainty (k=2; ±)	Units	TUR
<b>DC Voltage % Source - 0-5V Ch#4</b>										
0 - 5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0001 V	5.0e-007	5.8e-004	v	100.0 : 1	
	20%	±(0.1% Span)	0.9950	1.0050	1.0006 V	5.5e-006	5.8e-004	v	100.0 : 1	
	40%	±(0.1% Span)	1.9950	2.0050	1.9991 V	1.1e-005	5.8e-004	v	100.0 : 1	
	60%	±(0.1% Span)	2.9950	3.0050	2.9999 V	1.6e-005	5.8e-004	v	100.0 : 1	
	80%	±(0.1% Span)	3.9950	4.0050	3.9984 V	2.1e-005	5.8e-004	v	100.0 : 1	
	100%	±(0.1% Span)	4.9950	5.0050	4.9996 V	2.6e-005	5.8e-004	v	100.0 : 1	
<b>DC Voltage % Source - 0-10V Ch#1</b>										
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.001 V	5.0e-007	1.2e-003	v	100.0 : 1	
	20%	±(0.1% Span)	1.990	2.010	2.000 V	1.1e-005	1.2e-003	v	100.0 : 1	
	40%	±(0.1% Span)	3.990	4.010	4.000 V	2.1e-005	1.2e-003	v	100.0 : 1	
	60%	±(0.1% Span)	5.990	6.010	6.000 V	3.1e-005	1.2e-003	v	100.0 : 1	
	80%	±(0.1% Span)	7.990	8.010	7.997 V	4.1e-005	1.2e-003	v	100.0 : 1	
	100%	±(0.1% Span)	9.990	10.010	9.997 V	5.2e-005	1.2e-003	v	100.0 : 1	
<b>DC Voltage % Source - 0-10V Ch#2</b>										
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.002 V	5.0e-007	1.2e-003	v	100.0 : 1	
	20%	±(0.1% Span)	1.990	2.010	2.001 V	1.1e-005	1.2e-003	v	100.0 : 1	
	40%	±(0.1% Span)	3.990	4.010	3.998 V	2.1e-005	1.2e-003	v	100.0 : 1	
	60%	±(0.1% Span)	5.990	6.010	5.998 V	3.1e-005	1.2e-003	v	100.0 : 1	
	80%	±(0.1% Span)	7.990	8.010	7.998 V	4.1e-005	1.2e-003	v	100.0 : 1	
	100%	±(0.1% Span)	9.990	10.010	9.997 V	5.2e-005	1.2e-003	v	100.0 : 1	

# CERTIFICATE OF CALIBRATION

Customer: AEROACOUSTICS ENGINEERING LTD  
 1004 MIDDLEGATE ROAD  
 SUITE 1100  
 MISSISSAUGA, ON L4Y 1M4  
 PO Number: TR2018.02.14



Certificate/SO Number: 33-Q0W0C-20-1 Revision 0

## As Found/As Left Data

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	Cal Process O	Measurement Uncertainty (k=2; $\pm$ )	Units	TUR
<b>DC Voltage % Source - 0-10V Ch#3</b>									
0 - 10V	0%	$\pm$ (0.1% Span)	-0.010	0.010	0.000 V	5.0e-007	1.2e-003	V	100.0 : 1
	20%	$\pm$ (0.1% Span)	1.990	2.010	1.999 V	1.1e-005	1.2e-003	V	100.0 : 1
	40%	$\pm$ (0.1% Span)	3.990	4.010	4.001 V	2.1e-005	1.2e-003	V	100.0 : 1
	60%	$\pm$ (0.1% Span)	5.990	6.010	6.000 V	3.1e-005	1.2e-003	V	100.0 : 1
	80%	$\pm$ (0.1% Span)	7.990	8.010	7.999 V	4.1e-005	1.2e-003	V	100.0 : 1
	100%	$\pm$ (0.1% Span)	9.990	10.010	9.998 V	5.2e-005	1.2e-003	V	100.0 : 1
<b>DC Voltage % Source - 0-10V Ch#4</b>									
0 - 10V	0%	$\pm$ (0.1% Span)	-0.010	0.010	0.001 V	5.0e-007	1.2e-003	V	100.0 : 1
	20%	$\pm$ (0.1% Span)	1.990	2.010	1.999 V	1.1e-005	1.2e-003	V	100.0 : 1
	40%	$\pm$ (0.1% Span)	3.990	4.010	3.998 V	2.1e-005	1.2e-003	V	100.0 : 1
	60%	$\pm$ (0.1% Span)	5.990	6.010	6.000 V	3.1e-005	1.2e-003	V	100.0 : 1
	80%	$\pm$ (0.1% Span)	7.990	8.010	8.000 V	4.1e-005	1.2e-003	V	100.0 : 1
	100%	$\pm$ (0.1% Span)	9.990	10.010	9.998 V	5.2e-005	1.2e-003	V	100.0 : 1

# CERTIFICATE OF CALIBRATION

Customer: AEROACOUSTICS ENGINEERING LTD  
 1004 MIDDLEGATE ROAD  
 SUITE 1100  
 MISSISSAUGA, ON L4Y 1M4  
 PO Number: TR2018.02.14



Certificate/SO Number: 33-Q0W0C-20-1 Revision 0

## Traceable Standards

Asset	Manufacturer	Model Number	Description	Cal Date	Due Date	Traceability Number	Use
N0150	Fluke Corporation	5700A	Calibrator	23-Jun-17	31-May-18	5-&ND150-14-1	AF
N0436	Agilent Technologies	3458A Opt 002	Digital Multimeter, 8.5 Digit	19-Apr-17	30-Apr-18	5-&ND436-14-1	AF/AL

The use of the standard is defined as: AF - used for as-found readings, AL - used for as-left readings.

## Environmental Data

Temperature	Relative Humidity	Temp / RH Asset
71.35°F /21.86°C	33.50%	N0457

Calibrated At:  
 4043 Carling Avenue  
 Ottawa, ON K2K 2A4  
 Facility Responsible:  
 4043 Carling Avenue  
 Ottawa, ON K2K 2A4  
 800-828-1470

Unit Barcode:  
 901B0150195

Date Received: February 15, 2018  
 Service Level : R9

Calibrated By:  
 Electronically Signed By:  
 Mark King

Reviewed By:  
 Electronically Signed By:  
 Francis Kane

Customer Number: 9-322110-000  
 OPS-F20-014R1 01/23/2017 FP001R1 10/12/2017

---

## **Appendix F.02**

### **Summary of Measurement Results**

---

## Summary of Measurement Results

### 1.1 Sound Power Levels

*From Table 12 of IEC test report 17283.01.T36.RP2:*

Wind Speed (m/s)	Apparent L <sub>WA</sub> , (dBA)	Maximum Sound Power Level (dBA)* REA # 5272-A9FHRL
7.5	101.4	104.5
8	102.9	104.5
8.5	103.3	104.5
9	103.3	104.5
9.5	103.2	104.5
10	103.1	104.5
10.5	103.0	104.5
11	102.6	104.5
11.5	102.4	104.5
12	102.4	104.5
12.5	102.1	104.5

\*Includes +0.5 dB, per Section E3.1 of the MECP Compliance Protocol for Wind Turbine Noise

### 1.2 Tonal Audibility Values

*From Table 14 of IEC test report 17238.01.T36.RP2:*

Wind Speed (m/s)	Frequency (Hz)	Tonal audibility, ΔL <sub>a</sub> (dB)	Tonal Audibility from AAR* (dB)
7.5	64	-2.7	3
8	71	0.0	
8.5	70	0.1	
9	70	0.8	
9.5	70	0.3	
10	68	-1.2	
10.5	66	-1.8	
11	66	-2.2	

\*North Kent Wind Project Noise Impact Assessment Report (May 9, 2016)

### 1.3 Statement of Compliance

Based on the results in Table 12 of the IEC 61400-11 test report to which this statement is attached, the maximum apparent sound power level of the test turbine complies with the sound level in REA # 5272-A9FHRL and Section E3.1 of the MECP Compliance Protocol for Wind Turbine Noise.

Based on the results in Table 14 of the IEC 61400-11 to which this statement is attached, the tonal audibility of the test turbine complies with the maximum tonal audibility of 3 dB as indicated in the statement from the manufacturer dated July 15, 2015, found in Appendix E of the Noise Impact Assessment Report dated May 9, 2016.

---

## **Appendix F.03**

### **E-Audit Checklist**

---

**Appendix F.03 - (2017 Compliance Protocol Appendix F6): E-Audit checklist for IEC 61400-11:2013**

Wind Energy Project – Screening Document – Acoustic Audit Report – Emission IEC61400-11:2013 Standard

Information Required in the Acoustic Audit Report – Emission

Item #	Description	Complete?	Comment
1	Characterization of the wind turbine Items 1 to 26; IEC61400-11:2013, Section 10.2	✓	Report Section 2.1
2	Physical environment Items 27 to 33; IEC61400-11:2013, Section 10.3, Physical Environment	✓	Report Section 2.2, 3.2, 4.2, Appendix A
3	Measurement instrumentation Items 34 to 39; IEC61400-11:2013, Section 10.4, Instrumentation	✓	Report Section 3, Appendix F.01
4	Acoustic data Items 40 to 52; IEC61400-11:2013, Section 10.5, Acoustic Data	✓	Report Section 4, 3.3, Appendix C, Appendix D,
5	Non-acoustic data Items 50 to 53, and 56; IEC61400-11:2003 Section 10.6, Non-Acoustic Data Items 59 and 60; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 8, All necessary and supporting calculations	✓	Report Section 3, Appendix E
6	Uncertainty the apparent sound power level at integer wind speeds one-third octave band spectrum of the noise at the reference position at each integer wind speed the Tonality of the sound emissions of the wind turbine measured at the reference position	✓	Report Section 4, Appendix C
7	Additional information Item 60; NPC-233, Section 10, Report Format, bullet point number 4, Conclusions and Recommendations Item 61; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 8, All necessary and supporting calculations Item 62; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 3, Details of measurement procedure	✓	Report Section 3, Appendix F, data in Excel provided separately
8	Items 68 to 72; IEC61400-11:2013, Section 10.5, Acoustic Data	∅	Optional information, not provided in this report
9	Non-acoustic data Items 73 to 74 are from IEC61400-11:2013, Section 10.6, Non-Acoustic Data	∅	Optional information, not provided in this report

---

## End of Report

---