

REPORT ID: **17095.01.T53.RP2**

Belle River Wind Power Project – Turbine T53 IEC 61400-11 Edition 3.0 Measurement Report

Prepared for:

Belle River Wind LP
2050 Derry Road West, 2nd Floor
Mississauga, Ontario
L5N 0B9


Prepared by:



Alexandra Davidson, B.A.Sc.



Addie Denison, B.A.Sc., P.Eng.



Payam Ashtiani, B.A.Sc., P.Eng.

Original Issue Date: 26 November 2018
Revision Date: 21 May 2019



Revision History

Revision Number	Description	Date
1	Issued test report	26 November 2018
2	Revised Tonality Table to include results at 7.5 and 12.5 m/s	21 May 2019

This report in its entirety, including appendices contains 100 pages.

Statement Qualifications and Limitations

This report was prepared by Aercoustics Engineering Limited in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), "Wind turbine generator systems – Part 11: Acoustic noise measurement techniques". This report is specific only to the Wind Turbine identified in this report.

Aercoustics Engineering Limited shall not be responsible for any events or circumstances that may have occurred since the date on which the Wind Turbine was tested and/or this report was prepared, or for any inaccuracies contained in information that was provided to Aercoustics Engineering Limited. Further, Aercoustics Engineering Limited agrees that this report represents test data analysed as per the above described standard for the specific Wind Turbine described in this report, but Aercoustics Engineering Limited makes no other representations with respect to this report or any part thereof.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Aercoustics Engineering Limited accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Any use of this report is subject to this Statement of Qualifications and Limitations. Any damages arising from improper use of this report or parts thereof shall be borne by the party making such use.

This Statement of Qualifications and Limitations is attached to and forms part of this report.

Table of Contents

Revision History	2
Statement Qualifications and Limitations	2
List of Appendices	4
1 Introduction	6
2 Wind Turbine Information	6
2.1 Wind Turbine Equipment Details.....	6
2.2 Wind Turbine Location.....	7
3 Measurement Details	8
3.1 Measurement Equipment.....	8
3.1.1 Acoustic Measurement Equipment.....	8
3.1.2 Non-Acoustic Measurement Equipment	8
3.2 Measurement Setup	8
3.2.1 Microphone Placement	8
3.2.2 Double Windscreen Setup.....	9
3.3 Measurement Periods.....	9
3.4 Meteorological Conditions.....	9
3.5 Turbine operational information	10
4 Measurement Results	10
4.1 Deviations from IEC-61400-11 Edition 3.0	10
4.2 Special Notes & Considerations.....	10
4.3 Analysis Methodology	10
4.3.1 Double Windscreen Adjustment	10
4.3.2 Wind Speed Correction	10
4.4 Type B uncertainties	11
4.5 Sound Pressure Level Measurements	11
4.6 Sound Power Level of Turbine.....	12
4.7 Tonality Analysis.....	12
5 Closure	13
6 References	13

List of Appendices

Appendix A Site Details	
Figure A.01	Site Plan
Figure A.02	Site Photos
Appendix B Turbine Information	
Figure B.01	Power Curve
Figure B.02	Rotor RPM vs. Wind Speed
Table B.01	Allowed range of power curve and required wind speeds
Appendix C Apparent Sound Power Level	
Figure C.01	Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)
Figure C.02	Plot of measured total noise vs. electrical power output
Figure C.03	Plot of power curve relative to nacelle anemometer and 10 m anemometer
Figure C.04	Plot of rotor RPM vs. electrical power output
Figure C.05	Plot of sound pressure spectrum in 1/3 octave at 7.5 m/s
Figure C.06	Plot of sound pressure spectrum in 1/3 octave at 8 m/s
Figure C.07	Plot of sound pressure spectrum in 1/3 octave at 8.5 m/s
Figure C.08	Plot of sound pressure spectrum in 1/3 octave at 9 m/s
Figure C.09	Plot of sound pressure spectrum in 1/3 octave at 9.5 m/s
Figure C.10	Plot of sound pressure spectrum in 1/3 octave at 10 m/s
Figure C.11	Plot of sound pressure spectrum in 1/3 octave at 10.5 m/s
Figure C.12	Plot of sound pressure spectrum in 1/3 octave at 11 m/s
Figure C.13	Plot of sound pressure spectrum in 1/3 octave at 11.5 m/s
Figure C.14	Plot of sound pressure spectrum in 1/3 octave at 12 m/s
Figure C.15	Plot of sound pressure spectrum in 1/3 octave at 12.5 m/s
Table C.01	Detailed apparent sound power level data at hub height
Table C.02	Detailed apparent sound power level data at 10 m height
Table C.03	Type B measurement uncertainty summary
Table C.04	Detailed measurement uncertainty at hub height

List of Appendices (cont'd)

Appendix D Tonality Assessment	
Figure D.01	Plot of narrow band spectra - Turbine ON vs. Background at 7.5 m/s
Figure D.02	Plot of narrow band spectra - Turbine ON vs. Background at 8 m/s
Figure D.03	Plot of narrow band spectra - Turbine ON vs. Background at 8.5 m/s
Figure D.04	Plot of narrow band spectra - Turbine ON vs. Background at 9 m/s
Figure D.05	Plot of narrow band spectra - Turbine ON vs. Background at 9.5 m/s
Figure D.06	Plot of narrow band spectra - Turbine ON vs. Background at 10 m/s
Figure D.07	Plot of narrow band spectra - Turbine ON vs. Background at 10.5 m/s
Figure D.08	Plot of narrow band spectra - Turbine ON vs. Background at 11 m/s
Figure D.09	Plot of narrow band spectra - Turbine ON vs. Background at 11.5 m/s
Figure D.10	Plot of narrow band spectra - Turbine ON vs. Background at 12 m/s
Figure D.11	Plot of narrow band spectra - Turbine ON vs. Background at 12.5 m/s
Table D.01	Tonality Assessment Table – 7.5 m/s
Table D.02	Tonality Assessment Table - 8 m/s
Table D.03	Tonality Assessment Table - 8.5 m/s
Table D.04	Tonality Assessment Table - 9 m/s
Table D.05	Tonality Assessment Table - 9.5 m/s
Table D.06	Tonality Assessment Table - 10 m/s
Table D.07	Tonality Assessment Table - 10.5 m/s
Table D.08	Tonality Assessment Table - 11 m/s
Table D.09	Tonality Assessment Table - 11.5 m/s
Table D.10	Tonality Assessment Table - 12 m/s
Table D.11	Tonality Assessment Table - 12.5 m/s

Appendix E Measurement Data	
Table E.01	Measurement Data - Turbine ON
Table E.02	Measurement Data - Background

Appendix F Supplementary Information for the Regulators	
Appendix F.01	Calibration Certificates
Appendix F.02	Compliance Statement
Appendix F.03	E-Audit Checklist

1 Introduction

Aercoustics Engineering Limited (“Aercoustics”) was retained by Belle River Wind LP to conduct testing per the IEC 61400-11 test standard on one of the wind turbines, designated as T53, located in the Belle River Wind Project. The measurements were carried out in accordance with IEC 61400-11:2012, “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to turbine T53.

Aercoustics is accredited by the Standards Council of Canada under ISO/IEC 17025 to perform testing according to the IEC 61400-11 test standard.

2 Wind Turbine Information

2.1 Wind Turbine Equipment Details

Equipment information specific to turbine T53 was provided by the manufacturer and is summarized in Tables 1 to 5.

Table 1 – Wind Turbine Details

Wind Turbine Details	
Manufacturer	Siemens Gamesa Renewable Energy
Model Number	SWT 2.772-113
Turbine ID	T53

Table 2 – Operating Details

Operating Details	
Vertical or Horizontal axis wind turbine	Horizontal
Upwind or downwind rotor	Upwind rotor
Hub height	99.5 m
Horizontal distance from rotor centre to tower axis	5.5 m
Diameter of rotor	113 m
Tower type (lattice or tube)	Tubular
Passive stall, active stall, or pitch controlled turbine	Pitch controlled turbine
Constant or variable speed	Variable speed
Power curve	Rev 0
Rotational speed at each integer standardised wind speed	Max speed, 13.2 rpm
Rated power output	2772 kW
Control software version	136.1.0.1

Table 3 – Rotor Details

Rotor Details	
Rotor control devices	Pitch control
Presence of aerodynamic add-ons, such as vortex generators, stall strips, serrated trailing edges, etc.	Vortex generators and DinoTails
Blade type	B55
Serial number	Blade A: 550346101 Blade B: 550259701 Blade C: 550259501
Number of blades	3

Table 4 – Gearbox Details

Gearbox Details	
Manufacturer	N/A Direct drive
Model number	N/A Direct drive
Serial number	N/A Direct drive

Table 5 – Generator Details

Generator Details	
Manufacturer	Siemens
Model number	DD22_02
Serial number	5100219311

2.2 Wind Turbine Location

Turbine T53 is located in the town of Lakeshore, Ontario. Nearby roads are Lakeshore Road 125 and Byrnedale Road, approximately 175 m to the east and 920 m to the south, respectively. The area surrounding T53 is flat and consists primarily of farmland and scattered woodlots. The UTM coordinates of the turbine are 363514 m E and 4679229 m N (Zone 17T).

A general layout of the area in which the turbine is located is provided in the site plan (Figure A.01).

3 Measurement Details

3.1 Measurement Equipment

3.1.1 Acoustic Measurement Equipment

Details regarding the acoustic measurement equipment utilized for the test is summarized in Table 6.

Table 6 – Acoustic Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Acoustic Data acquisition system	LMS SCADA Mobile SCR292	22163146
Microphone	B&K 4189	2622169
Pre-amplifier	B&K 2671	2625417
Acoustic calibrator	B&K 4231	2513182

A field calibration of the measurement chain was performed at the beginning and end of each measurement day.

3.1.2 Non-Acoustic Measurement Equipment

Non-acoustic measurement equipment includes an anemometer installed 10 meters above ground level (“10-m AGL”) as well any sensing equipment utilized by the wind turbine to measure and record operational parameters. The 10-m AGL anemometer is provided by Aeroustics while the turbine sensing equipment is a part of the turbine installation.

Details regarding the non-acoustic measurement equipment utilized and controlled by Aeroustics is summarized in Table 7. Equipment used to measure turbine parameters, such as yaw angle and power output, are outside of Aeroustics’ control and are not reported here.

Table 7 – Meteorological Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Anemometer	VAISALA WXT520	K4250007
Serial to Analog Converter	NOKEVAL 7470	A165164

3.2 Measurement Setup

3.2.1 Microphone Placement

The measurement microphone was setup 156 meters from the base of the turbine in a downwind position (Position 1, per IEC 61400-11), at an elevation of 0 meters relative to the base of T53. The slant distance (R_1) from microphone location to rotor centre includes

the distance from rotor center to tower axis ($R_1 = 189.7$ m). The microphone was placed in the centre of a circular, acoustically reflective board.

During the measurement period, data points were used only when the microphone was within 15 degrees of the downwind direction from the turbine. The microphone position relative to downwind is monitored via the turbine yaw angle provided from the turbine SCADA system (discussed further in Section 3.5).

During the test, the land surrounding the turbine was a plowed field. No crops or vegetation were in the nearby area which would influence the results of the measurement. There were no nearby reflecting surfaces (houses, barns etc.); as such the influence from reflecting surfaces is negligible.

Photos of the measurement setup are provided in Figure A.02, Appendix A.

3.2.2 Double Windscreen Setup

A double windscreen setup was not utilized.

3.3 Measurement Periods

Table 8 – Summary of Measurement Periods

Date	Test Type	Start Time	Finish time
October 19, 2018	Background	11:06 am	11:24 am
	Turbine ON	11:29 am	11:43 am
	Turbine ON	11:50 am	12:01 pm
	Background	12:02 pm	12:13 pm
	Turbine ON	1:07 pm	1:12 pm
	Turbine ON	1:23 pm	1:55 pm
	Background	1:56 pm	2:28 pm

3.4 Meteorological Conditions

The normalised hub height wind speed during Turbine ON periods is either derived directly using the turbine power curve and measured power output (Section 8.2.1.1 of [1]) or indirectly using the measured wind speed from the nacelle anemometer and applying a correction factor (Section 8.2.1.2 of [1]). Wind speeds during Background periods are measured using the 10-m AGL anemometer and corrected to hub-height using a correction factor (Section 8.2.2 of [1]). The downwind direction is determined using the turbine yaw angle output, also known as the nacelle position (Section 8.3 of [1]).

Other atmospheric conditions, including ambient temperature and atmospheric pressure, are measured by the 10-m AGL anemometer during the measurement periods.

Detailed meteorological data relevant to the measurement is provided in Appendix E.

3.5 Turbine operational information

Turbine operational parameters – including electrical power, nacelle position (yaw angle), rotational speed, and nacelle wind speed – are acquired from the turbine controller simultaneously with the acoustic and weather measurement data using Aeroustics' data acquisition system.

4 Measurement Results

4.1 Deviations from IEC-61400-11 Edition 3.0

No deviations.

4.2 Special Notes & Considerations

No adjacent turbines were parked during the test.

4.3 Analysis Methodology

The following section outlines any corrections applied to the acoustic or weather measurement data, per IEC 61400-11. Transient events, such as vehicle traffic, wildlife, or air traffic, are excluded from the measurement data set.

4.3.1 Double Windscreen Adjustment

No double wind screen was used in the measurements described in this report and therefore no adjustment for a double windscreens was applied to the measurement data.

4.3.2 Wind Speed Correction

Following the methodology described in Section 8.2 of [1] and summarized in Section 3.4 of this report, two correction factors are derived from the measurement data and used to determine the normalized hub-height wind speed in certain conditions. The first correction factor (k_{nac}) is used to correct nacelle wind speeds measured for intervals that fall outside of the allowable power curve range. The second correction factor (k_Z) is used to correct 10m-AGL wind speeds measured during Background measurement periods up to hub-height.

The k-factors for this measurement set are provided in Table 9.

Table 9 – Calculated nacelle anemometer (k_{nac}) and 10m (k_Z) wind speed k-factor

k_{nac}	k_Z
0.99	1.25

4.4 Type B uncertainties

Type B uncertainties were obtained through interpretation of the information provided in Annex C of [1]. A summary of Type B uncertainties is provided in Table 10, while detailed information, including uncertainties by 1/3 octave band, is provided in Appendix C.

Table 10 – Summary of Type B uncertainties

Component	Typical (dB)	Used (dB)
Calibration	0.2	0.2
Board	0.3	0.3
Distance & direction	0.1	0.1
Air absorption	0	0
Weather conditions	0.5	0.5
Wind speed measured	0.7	0.7
Wind speed derived	0.2	0.2
Wind speed from power curve	0.2	0.2

4.5 Sound Pressure Level Measurements

Average overall sound pressure levels in each wind bin for Turbine ON and Background periods are summarized in Table 11. Average sound levels and uncertainties by 1/3 octave band are provided in Appendix C. A copy of the measurement data used for analysis is provided in Appendix E.

Table 11 – Summary of Sound Pressure Level Measurements

Wind Speed (m/s)	Turbine ON		Background		Turbine ON, Background adjusted L_{eq} , (dBA)
	L_{eq} , (dBA)	# of data pts	L_{eq} , (dBA)	# of data pts	
7.5	52.5	35	44.4	12	51.7
8	53.6	49	44.0	21	53.1
8.5	54.1	61	42.8	23	53.8
9	54.2	93	43.2	26	53.8
9.5	54.1	65	43.1	33	53.7
10	54.0	41	42.4	40	53.7
10.5	53.7	16	43.0	31	53.4
11	53.6	30	42.8	36	53.2
11.5	53.7	30	42.3	26	53.4
12	53.5	26	43.6	19	53.1
12.5	53.6	23	42.9	16	53.2

4.6 Sound Power Level of Turbine

The calculated apparent sound power level at hub height is summarized in Table 12. Corresponding sound power levels for 10-meter height wind speeds are provided in Table 13. Wind speeds at 10 meters are calculated using the wind shear profile described in Section 9.4 of [1].

Sound power levels by 1/3 octave band are provided in Appendix C.

Table 12 – $L_{WA,K}$ at each integer wind speed

Wind Speed (m/s)	Apparent L_{WA} , (dBA)	Uncertainty (dB)
7.5	102.3	0.9
8	103.7	0.9
8.5	104.3	0.8
9	104.4	0.8
9.5	104.3	0.8
10	104.2	0.8
10.5	103.9	0.8
11	103.8	0.8
11.5	104.0	0.8
12	103.6	0.8
12.5	103.8	0.8

Table 13 – $L_{WA,10m,K}$ at each integer wind speed

Wind Speed (m/s)	Apparent L_{WA} , (dBA)	Uncertainty (dB)
5	101.3	0.8
6	104.1	0.8
7	104.2	0.7
8	103.8	0.8
9	103.8	0.8

* denotes a 3 to 6 dB difference between Turbine ON and Background sound level

4.7 Tonality Analysis

The tonality analysis for turbine T53 is summarized in Table 14, while plots of narrow band spectra at each wind speed are provided in Appendix D. All ΔL_{tn} and ΔL_a values reported represent the energy average of all data points with an identified tone that fall within the same frequency of origin (Section 9.5.8 of [1]).

The narrow band spectra provided in the plots represents an energy average of all data points in the given wind speed bin for both Turbine ON and Background.

Table 14 – Tonality Assessment Summary

Wind Speed (m/s)	Frequency (Hz)	Tonality, ΔL_{tn} (dB)	Tonal audibility, ΔL_a (dB)	FFT's with tones	Total # of FFT's	Presence (%)
7.5	-	-	-	-	-	-
8	72	-4.6	-2.6	38	49	78%
8.5	72	-4.7	-2.7	54	61	89%
9	72	-3.7	-1.7	88	93	95%
9.5	71	-3.2	-1.2	61	65	94%
10	71	-4.0	-2.0	36	41	88%
10.5	72	-4.4	-2.4	15	16	94%
11	-	-	-	-	-	-
11.5	73	-4.9	-2.9	21	30	70%
12	73	-4.8	-2.8	21	26	81%
12.5	-	-	-	-	-	-

5 Closure

Measurements and analyses per IEC 61400-11:2012 (Edition 3.0) were performed on turbine T53 of the Belle River Wind Power Project, located in the town of Lakeshore, Ontario. The test turbine was found to have a maximum apparent sound power level of 104.4 dBA and a maximum tonal audibility of -1.2 dB.


Supplementary information to address specific local regulatory requirements are attached separately in Appendix F.

Should you have any questions or comments please contact the authors of this report.

6 References

- [1] IEC 61400-11 , *Wind Turbines - Part 11: Acoustic noise measurement techniques*, International Electrotechnical Commission, 2012.

Appendix A Site Details



 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Site Plan
		Figure A.01




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Site Photo
Figure A.02		

Appendix B

Turbine Information

Belle River T53 - Siemens SWT-2.772-113 Power Curve



17095.01.T53.RP1
Scale: NTS
Drawn by: AED
Reviewed by: MAD
Date: Nov 2018
Revision: 1


Project Name

Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53

Figure Title

Power Curve

Figure B.01



■ Rotor Speed vs. Hub Height Wind Speed

 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Rotor RPM vs. Wind Speed
		Figure B.02

Table B.01 Allowed range of power curve and required wind speeds

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Report ID: 17095.01.T53.RP1


Page 1 of 1

Created on: 11/13/2018


Power Curve & Required Wind Speeds		
Power Curve Tolerance	3%	
Acceptable range min	4	m/s
Acceptable range max	10	m/s
Min allowable range	4	m/s
Max allowable range	10	m/s
Power Output	2772	kW
85% Power	2356	kW
Corresponding wind speed	9.63	m/s
Minimum bin	7.5	m/s
Maximum bin	12.5	m/s


Power Curve (+ value = acceptable)		
Hub Wind Speed (m/s)	Power [kW]	Slope of Power Curve
0	0	-166
1	0	-166
2	0	-103
3	63	-62
4	167	13
5	346	103
6	615	210
7	991	327
8	1484	405
9	2055	312
10	2533	29
11	2728	-126
12	2768	-162
13	2772	-166
14	2772	-166
15	2772	-166
16	2772	-166
17	2772	-166
18	2772	-166
19	2772	-166
20	2772	-166
21	2772	-166
22	2772	-193
23	2745	-194
24	2717	-419
25	2464	

Appendix C Apparent Sound Power Level




 17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Figure Title Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)
	Figure C.01






 aercoustics	17095.01.T53.RP1	Project Name
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Figure Title	Plot of power curve relative to nacelle anemometer and 10 m anemometer

Figure C.03




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of rotor RPM vs. electrical power output
Figure C.04		

7.5 m/s - Hub Height




 17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 7.5 m/s
	Figure C.05

8.0 m/s - Hub Height




 aercoustics 17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 8 m/s
	Figure C.06


8.5 m/s - Hub Height



 17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53	
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s
	Figure C.07	




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 9 m/s
		Figure C.08



 17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s
	Figure C.09

10.0 m/s - Hub Height



aercoustics


17095.01.T53.RP1
Scale: NTS
Drawn by: AED
Reviewed by: MAD
Date: Nov 2018
Revision: 1

Project Name
Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53

Figure Title
Plot of sound pressure spectrum in 1/3 Octave at 10 m/s

Figure C.10

10.5 m/s - Hub Height



aercoustics


17095.01.T53.RP1
Scale: NTS
Drawn by: AED
Reviewed by: MAD
Date: Nov 2018
Revision: 1

Project Name
Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53


Figure Title
Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s

Figure C.11

11.0 m/s - Hub Height




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 11 m/s
		Figure C.12




 aercoustics 17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53	
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s
	Figure C.13	

12.0 m/s - Hub Height



 17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 12 m/s
	Figure C.14

12.5 m/s - Hub Height



 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s
		Figure C.15

Table C.01 Detailed apparent sound power level data at hub height

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Report ID: 17095.01.T53.RP1

Page 1 of 2

Created on: 2018-11-23

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																								Overall							
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000				
7.5	Turbine ON (dBA)	15.5	19.3	23.0	26.3	29.4	34.8	35.9	37.7	39.5	39.2	41.1	41.8	40.2	39.8	41.5	40.8	41.9	41.3	40.5	39.9	39.0	38.2	36.0	33.1	29.0	21.2	14.3	11.5	52.5			
	Background (dBA)	17.0	19.8	21.3	23.3	25.0	27.3	29.8	30.0	32.2	32.3	34.3	35.3	35.3	33.3	34.0	32.1	32.9	31.8	28.8	26.6	24.5	21.5	18.5	17.2	17.1	17.0	15.4	14.3	44.4			
	Turbine ON - background adj (dBA)	[12.5]	[16.3]	[20]	[23.3]	27.5	34.0	34.7	36.9	38.6	38.2	40.1	40.8	38.4	38.6	40.6	40.2	41.3	40.8	40.2	39.6	38.9	38.1	36.0	33.0	28.7	19.2	[11.3]	[8.5]	51.7			
	Signal to noise (dB)	-1.5	-0.5	1.6	3.0	4.4	7.5	6.1	7.7	7.3	6.9	6.8	6.6	4.8	6.4	7.5	8.8	9.0	9.5	11.7	13.3	14.5	16.6	17.5	15.9	12.0	4.2	-1.1	-2.8	8.0			
	Uncertainty (dB)	4.6	3.9	2.7	3.5	1.8	1.1	1.2	1.0	1.1	1.1	0.9	1.0	1.2	1.0	0.8	0.8	0.8	0.8	0.8	0.7	0.8	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9		
	PWL (dBA)	[63]	[66.9]	[70.5]	[73.8]	78.0	84.6	85.3	87.4	89.1	88.7	90.7	91.3	89.0	89.2	91.2	90.8	91.9	91.3	90.7	90.2	89.4	88.6	86.5	83.5	79.3	69.7	[61.9]	[59]	102.3			
8.0	Turbine ON (dBA)	15.1	19.1	23.0	26.3	29.5	35.7	37.7	37.6	39.3	39.6	41.8	42.8	41.3	41.0	42.9	42.2	43.3	43.0	42.0	41.3	40.4	39.4	37.4	34.3	30.1	22.4	15.1	11.8	53.6			
	Background (dBA)	16.9	20.6	22.7	24.4	26.1	27.3	30.2	29.9	30.9	30.7	32.2	33.5	33.6	32.9	34.1	32.8	33.2	31.9	29.2	27.2	26.0	24.0	21.9	20.6	20.0	21.5	23.6	17.5	44.0			
	Turbine ON - background adj (dBA)	[12.1]	[16.1]	[20]	[23.3]	26.9	35.1	36.9	36.8	38.6	39.0	41.2	42.2	40.5	40.2	42.3	41.7	42.9	42.6	41.7	41.1	40.2	39.3	37.2	34.1	29.6	[19.4]	[12.1]	[8.8]	53.1			
	Signal to noise (dB)	-1.8	-1.5	0.3	1.9	3.4	8.4	7.5	7.7	8.4	8.9	9.6	9.3	7.6	8.1	8.8	9.5	10.2	11.0	12.8	14.1	14.4	15.4	15.5	13.8	10.0	0.9	-8.5	-5.8	9.6			
	Uncertainty (dB)	4.7	4.0	2.8	3.6	2.3	1.1	1.0	1.0	1.0	0.8	0.8	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.1	2.9	3.9	4.1	0.9				
	PWL (dBA)	[62.6]	[66.7]	[70.6]	[73.9]	77.4	85.6	87.4	87.3	89.2	89.6	91.8	92.8	91.0	90.8	92.8	92.3	93.4	93.2	92.3	91.7	90.8	89.8	87.8	84.7	80.2	[70]	[62.7]	[59.3]	103.7			
8.5	Turbine ON (dBA)	16.7	20.7	24.0	27.0	30.2	35.9	38.5	38.4	40.3	40.5	42.3	43.2	41.7	41.4	43.3	42.6	43.8	43.5	42.4	41.7	40.8	39.8	37.8	34.6	30.7	23.0	15.8	12.6	54.1			
	Background (dBA)	14.0	16.9	20.2	21.5	23.4	25.8	29.2	28.7	29.6	28.8	30.7	31.7	31.6	31.2	33.0	32.2	33.3	32.3	29.4	27.0	25.2	22.0	19.4	17.5	17.0	16.5	15.0	13.4	42.8			
	Turbine ON - background adj (dBA)	[13.7]	18.3	21.6	25.6	29.2	35.5	38.0	37.9	39.9	40.2	42.0	42.8	41.3	41.0	42.8	42.2	43.3	43.1	42.2	41.5	40.7	39.7	37.7	34.6	30.5	21.9	[12.8]	[9.6]	53.8			
	Signal to noise (dB)	2.6	3.8	3.8	5.5	6.8	10.1	9.3	9.8	10.6	11.7	11.6	11.5	10.1	10.2	10.2	10.5	10.4	11.2	13.0	14.6	15.6	17.8	18.4	17.1	13.7	6.5	0.8	-0.8	11.3			
	Uncertainty (dB)	4.6	3.2	2.2	2.2	1.4	1.1	1.0	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.4	3.2	3.9	0.8				
	PWL (dBA)	[64.2]	[68.9]	[72.2]	[76.1]	79.7	86.0	88.5	88.5	90.4	90.8	92.6	93.4	91.8	91.5	93.4	92.8	93.9	93.7	92.7	92.1	91.2	90.3	88.3	85.1	81.1	72.5	[63.3]	[60.1]	104.3			
9.0	Turbine ON (dBA)	16.8	20.7	24.0	27.1	30.1	36.4	38.9	38.1	39.9	40.4	42.2	43.2	41.8	41.4	43.3	42.8	43.9	43.6	42.5	41.8	40.9	39.9	37.9	34.9	30.7	23.1	16.3	13.3	54.2			
	Background (dBA)	17.2	19.7	22.1	23.8	25.0	26.9	29.9	29.8	30.1	29.7	31.0	31.7	31.6	30.9	33.3	32.2	33.2	32.5	29.9	28.1	26.3	23.2	20.4	18.7	18.3	17.6	15.9	14.6	43.2			
	Turbine ON - background adj (dBA)	[13.8]	[17.7]	[21]	24.4	28.5	35.9	38.3	37.5	39.4	40.0	41.9	42.9	41.3	41.0	42.9	42.4	43.5	43.2	42.2	41.6	40.8	39.8	37.8	34.8	30.5	21.7	[13.3]	[10.3]	53.8			
	Signal to noise (dB)	-0.4	1.0	1.9	3.3	5.1	9.5	9.0	8.4	9.8	10.7	11.3	11.5	10.2	10.5	10.0	10.5	10.7	11.1	12.5	13.7	14.6	17.5	16.2	12.4	5.5	0.4	-1.3	10.9				
	Uncertainty (dB)	4.5	3.8	2.5	3.2	1.6	1.1	1.0	1.0	0.9	0.9	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.1	1.6	3.1	3.9	0.8				
	PWL (dBA)	[64.3]	[68.3]	[71.5]	75.0	79.0	86.4	88.9	88.0	90.0	90.5	92.5	93.4	91.9	91.6	93.4	92.9	94.1	93.8	92.8	92.2	91.3	90.4	88.4	85.4	81.0	72.2	[63.9]	[60.8]	104.4			
9.5	Turbine ON (dBA)	16.7	20.9	23.9	27.0	30.0	36.6	39.0	38.0	39.9	40.3	42.2	43.1	41.6	41.3	43.1	42.6	43.7	43.5	42.3	41.6	40.8	39.9	38.0	35.0	31.0	23.4	16.1	12.9	54.1			
	Background (dBA)	16.0	19.1	21.2	23.2	25.5	26.5	29.1	28.5	29.8	29.2	30.8	31.1	30.7	30.4	32.9	32.4	33.3	32.8	30.7	28.5	26.6	23.6	21.7	20.7	21.2	19.5	17.2	15.3	43.1			
	Turbine ON - background adj (dBA)	[13.7]	[17.9]	[20.9]	24.7	28.1	36.1	38.5	37.5	39.5	39.9	41.9	42.8	41.2	40.9	42.7	42.2	43.3	43.1	42.0	41.4	40.6	39.8	37.9	34.8	30.5	21.1	[13.1]	[9.9]	53.7			
	Signal to noise (dB)	0.7	1.8	2.7	3.8	4.5	10.1	9.9	9.5	10.1	11.1	11.5	12.0	10.9	10.9	10.2	10.3	10.4	10.6	11.6	13.1	14.1	16.3	16.3	14.3	9.8	3.9	-1.1	-2.4	11.0			
	Uncertainty (dB)	4.5	3.8	2.5	2.8	1.8	1.0	0.9	0.9	0.9	0.9	0.7	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.1	2.0	3.1	3.9	0.8				
	PWL (dBA)	[64.2]	[68.5]	[71.4]	75.3	78.7	86.7	89.1	88.1	90.0	90.5	92.5	93.4	91.8	91.4	93.3	92.7	93.9	93.6	92.6	91.9	91.2	90.4	88.4	85.3	81.1	71.6	[63.6]	[60.4]	104.3			
10.0	Turbine ON (dBA)	17.7	21.7	24.7	27.6	30.4	36.5	38.7	38.1	40.0	40.4	42.1	42.9	41.4	41.0	43.0	42.5	43.6	43.4	42.3	41.6	40.7	39.9	37.9	34.7	31.1	23.7	17.3	14.6	54.0			
	Background (dBA)	15.2	17.8	19.9	21.9	24.1	25.9	28.9	27.9	29.6	29.2	30.4	30.8	30.4	29.9	32.6	31.6	32.8	31.8	29.2	26.8	25.0	21.6	18.9	20.3	22.8	16.2	14.2	12.9	42.4			
	Turbine ON - background adj (dBA)	[14.7]	19.5	22.9	26.2	29.3	36.1	38.2	37.7	39.6	40.1	41.8	42.6	41.1	40.7	42.5	42.2	43.2	43.1	42.1	41.4	40.6	39.8	37.9	34.5	30.4	22.9	14.4	[11.6]	53.7			
	Signal to noise (dB)	2.6	3.9	4.8	5.7	6.3	10.7	9.8	10.2	10.4	11.2	11.7	12.1	11.0	11.1	10.3	10.9	10.8	11.6	13.1	14.8	15.8	18.3	19.1	14.4	8.3	7.5	3.1	1.7	11.6			
	Uncertainty (dB)	4.3	2.9	1.6	2.0	1.3	0.9	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	1.0	1.1	1.2	2.8	3.7	0.8
	PWL (dBA)	[65.3]	70.0	73.5	76.7	79.8	86.7	88.8	88.2	90.1	90.6	92.3	93.2	91.6	91.2	93.1	92.7	93.8	93.6	92.6	92.0	91.2	90.4	88.4	85.1	81.0	73.4	65.0	[62.1]</td				

Table C.01 Detailed apparent sound power level data at hub height

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Report ID: 17095.01.T53.RP1

Page 2 of 2

Created on: 2018-11-23

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																				Overall								
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	
10.5	Turbine ON (dBA)	15.6	20.7	22.8	25.9	28.9	34.9	37.9	37.3	39.2	39.7	41.5	42.4	41.2	40.9	42.9	42.5	43.6	43.4	42.4	41.6	40.6	39.9	37.9	34.4	30.9	23.5	16.1	12.8	53.7
	Background (dBA)	14.9	17.7	20.0	21.3	23.6	25.8	28.4	29.0	29.9	29.7	31.2	31.6	31.5	30.6	33.0	32.1	33.3	32.6	30.5	28.0	25.9	22.3	19.4	19.0	23.4	16.8	14.0	12.7	43.0
	Turbine ON - background adj (dBA)	[12.6]	[17.7]	[19.8]	24.0	27.4	34.3	37.4	36.6	38.6	39.3	41.1	42.1	40.7	40.4	42.4	42.0	43.2	43.0	42.1	41.4	40.5	39.8	37.8	34.3	30.0	22.5	[13.1]	[9.8]	53.4
	Signal to noise (dB)	0.8	2.9	2.9	4.5	5.3	9.1	9.5	8.3	9.3	10.1	10.4	10.8	9.7	10.3	9.9	10.3	10.7	11.9	13.6	14.8	17.6	18.5	15.4	7.5	6.7	2.1	0.2	10.7	
	Uncertainty (dB)	4.2	3.5	2.5	2.3	1.5	1.0	0.9	1.0	0.9	0.9	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.7	0.7	0.7	0.9	1.0	1.1	1.2	2.9	3.6	0.8
	PWL (dBA)	[63.2]	[68.2]	[70.4]	74.5	77.9	84.9	87.9	87.2	89.2	89.9	91.7	92.6	91.3	91.0	92.9	92.6	93.7	93.5	92.7	92.0	91.0	90.4	88.4	84.8	80.6	73.0	[63.7]	[60.4]	103.9
11.0	Turbine ON (dBA)	18.8	23.1	25.2	27.5	29.9	34.9	37.5	36.9	39.0	39.2	41.0	42.1	41.0	40.8	42.8	42.4	43.6	43.4	42.5	41.6	40.6	39.8	37.6	34.0	30.8	24.2	18.1	16.0	53.6
	Background (dBA)	15.4	18.4	20.8	22.7	24.6	26.4	28.5	28.6	30.1	30.4	30.4	30.8	31.2	30.0	32.8	32.1	33.3	32.3	30.1	27.9	25.9	22.6	19.6	17.4	17.3	16.4	14.7	13.5	42.8
	Turbine ON - background adj (dBA)	16.1	21.4	23.2	25.8	28.3	34.2	36.9	36.2	38.3	38.6	40.7	41.8	40.5	40.4	42.3	42.0	43.2	43.1	42.2	41.5	40.5	39.7	37.6	33.9	30.6	23.4	15.5	[13]	53.2
	Signal to noise (dB)	3.4	4.7	4.4	4.8	5.3	8.4	9.0	8.3	8.9	8.8	10.6	11.3	9.8	10.8	10.0	10.3	10.4	11.1	12.4	13.8	14.7	17.1	18.0	16.5	13.5	7.7	3.4	2.5	10.8
	Uncertainty (dB)	4.1	2.7	1.9	2.4	1.6	1.1	1.0	1.0	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.8	0.8	0.8	1.1	1.1	1.3	2.8	4.0	0.8	
	PWL (dBA)	66.7	71.9	73.8	76.4	78.9	84.7	87.5	86.7	88.9	89.1	91.2	92.3	91.1	91.0	92.9	92.5	93.7	93.6	92.8	92.0	91.0	90.2	88.1	84.4	81.2	73.9	66.1	[63.6]	103.8
11.5	Turbine ON (dBA)	17.4	22.2	24.2	26.7	29.5	34.4	37.5	37.0	39.1	39.2	40.8	42.0	41.0	41.0	43.0	42.7	43.7	43.6	42.7	41.9	40.9	39.9	37.7	33.8	30.6	23.6	17.2	14.7	53.7
	Background (dBA)	15.3	18.5	20.5	21.9	24.0	26.0	28.5	28.3	29.8	29.0	30.5	30.7	30.4	29.6	32.5	31.5	32.6	31.9	28.8	26.7	25.0	21.8	19.3	18.1	18.4	16.4	14.4	13.1	42.3
	Turbine ON - background adj (dBA)	[14.4]	19.7	21.7	24.9	28.1	33.7	37.0	36.4	38.6	38.8	40.4	41.7	40.6	40.7	42.6	42.4	43.4	43.3	42.5	41.8	40.8	39.8	37.6	33.7	30.3	22.6	[14.2]	[11.7]	53.4
	Signal to noise (dB)	2.1	3.7	3.6	4.8	5.5	8.4	9.1	8.7	9.4	10.2	10.3	11.3	10.6	11.4	10.5	11.2	11.2	11.8	13.9	15.2	15.9	18.1	18.4	15.7	12.1	7.2	2.8	1.6	11.4
	Uncertainty (dB)	4.5	3.2	2.2	2.4	1.6	1.1	1.0	1.0	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	0.7	0.8	1.1	1.1	1.3	3.1	3.9	0.8	
	PWL (dBA)	[64.9]	70.3	72.2	75.5	78.7	84.3	87.5	86.9	89.1	89.3	90.9	92.2	91.2	91.2	93.1	92.9	93.9	93.9	93.1	92.3	91.3	90.4	88.2	84.2	80.9	73.2	[64.7]	[62.2]	104.0
12.0	Turbine ON (dBA)	17.2	22.2	23.5	26.6	29.1	34.1	37.4	36.4	38.5	38.7	40.0	41.1	40.3	40.4	42.5	42.4	43.7	43.8	43.1	42.2	41.0	39.9	37.4	33.3	29.9	23.0	17.0	14.7	53.5
	Background (dBA)	17.9	21.0	23.3	25.2	27.5	29.0	30.3	30.1	30.9	30.7	31.5	31.0	30.6	32.8	32.3	33.2	32.7	30.7	28.6	27.2	24.1	21.1	21.7	25.3	19.6	16.5	15.3	43.6	
	Turbine ON - background adj (dBA)	[14.2]	[19.2]	[20.5]	[23.6]	[26.1]	32.5	36.5	35.3	37.6	37.9	39.3	40.6	39.8	39.9	42.0	42.0	43.3	43.4	42.8	42.1	40.8	39.8	37.3	33.0	28.1	20.4	[14]	[11.7]	53.1
	Signal to noise (dB)	-0.8	1.3	0.3	1.3	1.6	5.2	7.1	6.3	7.6	8.0	8.5	9.6	9.3	9.8	9.7	10.2	10.5	11.1	12.4	13.6	13.8	15.8	16.3	11.6	4.6	3.4	0.6	-0.6	9.9
	Uncertainty (dB)	4.7	4.0	2.8	3.6	2.6	1.5	1.1	1.2	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.9	2.3	3.2	4.0	0.8
	PWL (dBA)	[64.7]	[69.8]	[71.1]	[74.1]	[76.7]	83.1	87.0	85.8	88.2	88.5	89.9	91.2	90.3	90.4	92.6	92.6	93.9	94.0	93.4	92.6	91.4	90.3	87.9	83.5	78.7	70.9	[64.6]	[62.3]	103.6
12.5	Turbine ON (dBA)	18.7	23.4	25.4	28.5	30.4	34.5	37.7	37.1	38.8	38.7	40.2	41.3	40.4	40.4	42.6	42.5	43.8	43.8	43.1	42.2	41.0	39.8	37.4	33.3	30.1	23.6	18.7	16.7	53.6
	Background (dBA)	17.6	20.7	23.0	24.3	26.0	27.5	29.3	29.4	30.0	29.5	31.4	30.9	30.4	30.0	33.0	32.0	32.9	32.1	29.6	27.7	26.1	23.0	20.0	17.8	17.9	17.6	16.0	15.2	42.9
	Turbine ON - background adj (dBA)	[15.7]	[20.4]	[22.4]	26.4	28.5	33.6	37.0	36.3	38.2	38.2	39.6	40.9	40.0	40.0	42.1	42.1	43.4	43.5	42.9	42.1	40.9	39.7	37.3	33.2	29.8	22.3	[15.7]	[13.7]	53.2
	Signal to noise (dB)	1.1	2.7	2.4	4.2	4.5	7.1	8.3	7.6	8.8	9.2	8.8	10.4	10.0	10.4	9.6	10.5	10.9	11.7	13.5	14.5	15.0	16.9	17.4	15.6	12.2	6.0	2.7	1.5	10.7
	Uncertainty (dB)	4.5	3.8	2.6	2.7	1.8	1.2	1.0	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	0.7	0.8	1.0	1.1	1.0	1.5	3.2	4.0	0.8
	PWL (dBA)	[66.3]	[70.9]	[73]	76.9	79.1	84.1	87.5	86.8	88.8	88.7	90.1	91.4	90.5	90.5	92.6	92.6	93.9	94.0	93.5	92.6	91.5	90.3	87.9	83.8	80.4	72.9	[66.3]	[64.2]	103.8

Table C.02 Detailed apparent sound power level data at 10m height

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Report ID: 17095.01.T53.RP1

Page 1 of 1

Created on: 11/13/2018

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

‡ marks values derived from a data set with less than 10 points

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																								Overall					
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
5.0	Turbine ON (dBA)	14.4	18.4	22.0	25.4	29.0	34.1	35.3	37.0	38.5	38.4	40.3	41.0	39.2	38.7	40.5	39.8	40.9	40.3	39.5	39.0	38.2	37.3	35.2	32.4	28.9	21.9	13.9	11.2	51.6	
	Background (dBA)	15.9	18.6	20.7	22.9	24.4	26.8	29.7	29.8	31.6	31.7	33.4	34.5	34.5	32.9	33.6	32.0	32.9	31.9	28.9	26.6	24.6	21.6	18.9	17.3	17.0	16.5	14.8	13.5	44.0	
	Turbine ON - background adj (dBA)	[11.4]	[15.4]	[19]	[22.4]	27.1	33.2	34.0	36.0	37.5	37.4	39.3	39.8	37.3	37.4	39.6	39.0	40.1	39.6	39.1	38.7	38.0	37.2	35.1	32.3	28.6	20.4	[10.9]	[8.2]	50.7	
	Signal to noise (dB)	-1.5	-0.3	1.3	2.4	4.5	7.3	5.7	7.1	6.8	6.7	6.9	6.4	4.6	5.8	6.9	7.8	7.9	8.4	10.6	12.3	13.6	15.7	16.4	15.1	11.9	5.4	-0.9	-2.3	7.6	
	Uncertainty (dB)	3.9	3.3	2.2	3.0	1.5	1.0	1.0	0.9	0.9	0.9	0.8	0.8	1.0	0.9	0.8	0.7	0.7	0.8	0.7	0.7	0.6	0.7	0.9	0.9	1.0	1.6	2.7	3.3	0.8	
	PWL (dBA)	[62]	[65.9]	[69.6]	[72.9]	77.6	83.8	84.5	86.6	88.0	88.0	89.9	90.4	87.9	87.9	90.1	89.5	90.7	90.1	89.7	89.3	88.6	87.8	85.7	82.8	79.2	70.9	[61.5]	[58.7]	101.3	
6.0	Turbine ON (dBA)	16.3	20.3	23.7	26.9	30.0	36.1	38.5	38.1	39.8	40.2	42.1	43.0	41.6	41.2	43.1	42.5	43.6	43.3	42.2	41.6	40.7	39.7	37.7	34.6	30.5	22.9	15.9	12.8	53.9	
	Background (dBA)	16.5	19.5	21.8	23.4	25.4	26.8	29.8	29.4	30.1	29.5	31.1	31.9	32.0	31.6	33.5	32.5	33.4	32.5	30.0	27.9	26.2	23.3	20.8	19.3	19.5	20.2	15.7	43.4		
	Turbine ON - background adj (dBA)	[13.3]	[17.3]	[20.7]	24.2	28.1	35.5	37.8	37.4	39.3	39.8	41.7	42.7	41.0	40.7	42.6	42.1	43.2	42.9	42.0	41.4	40.5	39.6	37.6	34.5	30.2	20.4	[12.9]	[9.8]	53.5	
	Signal to noise (dB)	-0.1	0.9	1.8	3.5	4.5	9.3	8.6	8.6	9.7	10.7	11.0	11.1	9.6	9.7	9.6	10.0	10.2	10.8	12.2	13.6	14.4	16.4	16.9	15.3	11.1	3.6	-4.3	-2.9	10.6	
	Uncertainty (dB)	4.3	3.6	2.3	2.9	1.6	1.0	0.9	0.9	0.9	0.9	0.7	0.7	0.7	0.8	0.7	0.8	0.7	0.8	0.7	0.7	0.8	0.7	0.7	1.0	1.0	1.9	3.0	3.7	0.8	
	PWL (dBA)	[63.9]	[67.9]	[71.2]	74.8	78.6	86.1	88.4	88.0	89.9	90.3	92.3	93.2	91.6	91.3	93.2	92.6	93.8	93.5	92.5	91.9	91.1	90.1	88.1	85.0	80.7	71.0	[63.4]	[60.3]	104.1	
7.0	Turbine ON (dBA)	17.2	21.5	24.2	27.2	30.1	36.2	38.6	37.9	39.8	40.2	41.9	42.8	41.4	41.1	43.0	42.6	43.7	43.4	42.4	42.4	41.6	40.8	39.9	37.9	34.7	31.0	23.5	16.8	13.9	54.0
	Background (dBA)	15.1	18.0	20.1	21.9	23.9	25.9	28.8	28.4	29.7	29.3	30.7	31.1	30.8	30.1	32.7	31.9	33.0	32.2	29.8	27.4	25.6	22.3	19.9	20.0	22.5	17.4	15.2	13.5	42.7	
	Turbine ON - background adj (dBA)	[14.2]	18.9	22.1	25.7	28.9	35.8	38.2	37.4	39.3	39.8	41.6	42.5	41.0	40.7	42.6	42.2	43.3	43.1	42.1	41.5	40.6	39.8	37.8	34.5	30.3	22.3	[13.8]	[10.9]	53.6	
	Signal to noise (dB)	2.1	3.5	4.1	5.3	6.1	10.3	9.9	9.5	10.1	10.8	11.2	11.7	10.6	11.0	10.3	10.7	10.7	11.2	12.6	14.2	15.2	17.6	18.0	14.7	8.5	6.1	1.6	0.4	11.3	
	Uncertainty (dB)	4.1	3.0	1.7	2.0	1.3	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	1.0	1.0	1.1	1.3	2.8	3.5	0.7	
	PWL (dBA)	[64.8]	69.4	72.7	76.2	79.4	86.3	88.7	87.9	89.9	90.3	92.2	93.1	91.6	91.3	93.1	92.7	93.8	93.7	92.7	92.0	91.2	90.4	88.4	85.1	80.9	72.9	[64.3]	[61.4]	104.2	
8.0	Turbine ON (dBA)	17.9	22.6	24.4	27.0	29.6	34.5	37.5	36.8	38.9	39.1	40.7	41.8	40.8	40.8	42.8	42.5	43.7	43.6	42.8	41.9	40.9	39.9	37.6	33.7	30.5	23.6	17.5	15.2	53.6	
	Background (dBA)	15.9	19.0	21.2	23.0	25.2	26.9	28.9	28.8	30.1	30.0	30.6	30.9	30.9	29.9	32.6	31.9	33.0	32.2	29.8	27.6	25.9	22.6	19.8	19.0	21.1	17.3	15.0	13.8	42.8	
	Turbine ON - background adj (dBA)	[14.9]	20.1	21.6	24.8	27.6	33.7	36.9	36.1	38.3	38.5	40.2	41.4	40.4	40.4	42.3	42.1	43.3	43.3	42.5	41.8	40.7	39.8	37.5	33.6	30.0	22.5	[14.5]	[12.2]	53.3	
	Signal to noise (dB)	2.1	3.6	3.2	4.1	4.4	7.6	8.6	8.0	8.8	9.1	10.0	10.9	10.0	10.9	10.1	10.7	10.7	11.4	13.0	14.3	14.9	17.2	17.8	14.8	9.4	6.3	2.5	1.5	10.9	
	Uncertainty (dB)	4.4	3.2	2.3	2.7	1.8	1.1	1.0	1.0	1.0	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.4	3.0	3.8	0.8		
	PWL (dBA)	[65.5]	70.6	72.2	75.4	78.2	84.2	87.4	86.6	88.8	89.0	90.8	92.0	90.9	90.9	92.9	92.7	93.9	93.8	93.1	92.3	91.3	90.3	88.1	84.1	80.5	73.1	[65.1]	[62.8]	103.8	
9.0	Turbine ON (dBA)	18.7	23.5	25.3	28.1	30.6	34.7	38.0	37.1	38.9	38.9	40.0	41.1	40.3	40.2	42.5	42.4	43.7	43.9	43.4	42.5	41.4	40.1	37.5	33.4	30.2	23.5	18.4	16.3	53.7	
	Background (dBA) ‡	16.9	19.7	21.9	23.6	25.3	27.0	29.2	29.1	29.8	30.9	31.5	30.7	30.6	30.1	33.1	32.0	32.9	32.2	29.6	27.6	26.1	22.9	20.1	18.3	18.8	17.5	15.8	14.7	42.9	
	Turbine ON - background adj (dBA) ‡	[15.7]	21.2	22.6	26.1	29.1	33.9	37.4	36.3	38.3	38.1	39.4	40.7	39.9	39.8	41.9	42.0	43.4	43.5	43.2	42.4	41.2	40.0	37.5	33.3	29.9	22.2	[15.4]	[13.3]	53.3	
	Signal to noise (dB)	1.8	3.8	3.4	4.4	5.3	7.7	8.8	8.0	9.1	8.0	8.6	10.4	9.8	10.1	9.4	10.4	10.8	11.7	13.8	14.9	15.3	17.2	17.4	15.1	11.4	6.0	2.6	1.6	10.7	
	Uncertainty (dB)	4.4	3.0	2.2	2.5	1.5	1.1	0.9	1.0	0.9	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.8	1.0	1.0	1.4	3.0	3.8	0.8	
	PWL (dBA) ‡	[66.3]	71.8	73.2	76.7	79.6	84.4	87.9	86.9	88.9	88.7	89.9	91.2	90.4	90.3	92.5	93.9	94.1	93.8	92.9	91.8	90.6	88.0	83.8	80.4	72.8	[66]	[63.9]	103.8		

Table C.03 Type B measurement uncertainty summary

Project: Belle River Wind Power Project- Turbine T53 - IEC 61400-11 Measurement
Report ID: 17095.01.T53.RP1

Page 1 of 1
Created on: 11/13/2018

Overall Equipment Uncertainties		
	Typical values	Used values
Calibration	0.2 dB	0.2 dB
Board	0.3 dB	0.3 dB
Distance	0.1 dB	0.1 dB
Air absorption	0 dB	0 dB
Weather	0.5 dB	0.5 dB

1/3 Octave Band Uncertainties		
Frequency (Hz)	Microphone Uncertainty	Overall (including overall equipment Uncertainties)
20	0.8 dB	2 dB
25	0.8 dB	1.6 dB
31.5	0.5 dB	1.1 dB
40	0.5 dB	1.5 dB
50	0.5 dB	1.1 dB
63	0.5 dB	0.9 dB
80	0.5 dB	0.8 dB
100	0.5 dB	0.8 dB
125	0.5 dB	0.8 dB
160	0.5 dB	0.8 dB
200	0.3 dB	0.7 dB
250	0.3 dB	0.7 dB
315	0.3 dB	0.7 dB
400	0.3 dB	0.7 dB
500	0.3 dB	0.7 dB
630	0.3 dB	0.7 dB
800	0.3 dB	0.7 dB
1000	0.3 dB	0.8 dB
1250	0.3 dB	0.8 dB
1600	0.3 dB	0.8 dB
2000	0.3 dB	0.7 dB
2500	0.5 dB	0.8 dB
3150	0.5 dB	1.1 dB
4000	0.5 dB	1.1 dB
5000	0.5 dB	1 dB
6300	0.5 dB	1.1 dB
8000	0.5 dB	1.4 dB
10000	1.3 dB	1.7 dB

Table C.04 Detailed measurement uncertainty at hub height

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Report ID: 17095.01.T53.RP1

Page 1 of 2

Created on: 2018-11-23

Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																				Overall								
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	
7.5	Turbine ON	7.52	35	Average (dBA)	15.5	19.4	23.0	26.3	29.5	34.8	36.0	37.8	39.5	39.2	41.2	41.9	40.3	39.9	41.6	40.9	42.0	41.4	40.5	39.9	39.1	38.2	36.1	33.2	29.1	21.2	14.3	11.4	52.6
				Uncertainty A (dB)	0.4	0.4	0.4	0.3	0.3	0.2	0.4	0.4	0.3	0.3	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.4	
	Background	7.52	12	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	2.0	1.7	1.1	1.6	1.1	1.0	0.9	0.9	0.9	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
8.0	Turbine ON	7.99	49	Average (dBA)	17.1	20.0	21.4	23.4	25.1	27.3	29.8	30.0	32.2	32.3	34.3	35.3	35.4	33.4	34.0	32.1	32.9	31.8	28.8	26.6	24.5	21.6	18.6	17.2	17.1	17.1	15.5	14.4	44.5
				Uncertainty A (dB)	1.6	1.6	1.2	1.0	0.7	0.5	0.5	0.4	0.6	0.9	1.0	1.1	1.3	1.0	0.5	0.3	0.3	0.2	0.3	0.4	0.4	0.5	0.6	0.6	0.7	0.8	0.8	0.9	
	Background	8.04	21	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	2.6	2.3	1.6	1.8	1.3	1.1	1.0	0.9	1.0	1.2	1.2	1.3	1.5	1.2	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
8.5	Turbine ON	8.50	61	Average (dBA)	15.1	19.1	23.0	26.3	29.5	35.7	37.7	37.6	39.3	39.6	41.7	42.8	41.3	41.0	42.9	42.2	43.3	43.0	42.0	41.3	40.4	39.4	37.4	34.3	30.1	22.4	15.1	11.8	53.6
				Uncertainty A (dB)	0.3	0.3	0.2	0.2	0.2	0.1	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.4	
	Background	8.53	23	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	2.0	1.7	1.1	1.5	1.1	1.0	0.8	0.9	0.9	0.9	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
9.0	Turbine ON	9.00	93	Average (dBA)	16.8	20.7	24.0	27.1	30.1	36.4	38.9	38.1	39.9	40.4	42.2	43.2	41.8	41.4	43.3	42.6	43.8	43.5	42.4	41.7	40.8	39.8	37.8	34.6	30.7	23.0	15.8	12.6	54.1
				Uncertainty A (dB)	0.3	0.2	0.2	0.2	0.2	0.1	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.4	
	Background	9.04	26	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	2.4	2.0	1.5	1.7	1.2	1.0	1.0	0.9	0.9	0.9	0.8	0.9	0.9	0.8	0.9	0.8	0.9	0.8	0.7	0.8	0.9	0.9	0.9	1.0	1.3	1.3	1.6	1.9	
9.5	Turbine ON	9.51	65	Average (dBA)	16.7	20.9	23.9	27.0	30.0	36.6	39.0	38.0	39.9	40.3	42.2	43.1	41.6	41.2	43.1	42.6	43.7	43.5	42.3	41.6	40.8	39.9	38.0	35.0	31.0	23.4	16.1	12.9	54.1
				Uncertainty A (dB)	0.4	0.3	0.3	0.2	0.2	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.4	
	Background	9.52	33	Uncertainty B (dB)	2.0	1.7	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	2.3	2.0	1.4	1.7	1.2	1.0	1.0	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.8	0.7	0.8	0.9	0.9	0.9	1.0	1.3	1.3	1.6	1.9			
10.0	Turbine ON	9.93	41	Average (dBA)	18.0	21.9	24.9	27.8	30.6	36.7	38.8	38.2	40.1	40.5	42.2	43.0	41.5	41.0	43.0	42.5	43.6	43.4	42.3	41.6	40.8	39.9	38.0	34.7	31.2	23.7	17.5	14.8	54.0
				Uncertainty A (dB)	0.5	0.4	0.4	0.3	0.2	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.4	0.5				
	Background	10.02	40	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8		
				Combined Uncertainty (dB)	2.2	1.8	1.2	1.6	1.2	1.0	0.9	0.9	0.9	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.8	0.7	0.8	0.9	0.8	0.8	0.9	1.2	1.4	1.6	1.8		

Table C.04 Detailed measurement uncertainty at hub height

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Report ID: 17095.01.T53.RP1


Page 2 of 2

Created on: 2018-11-23


Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																						Overall						
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	
10.5	Turbine ON	10.60	16	Average (dBA)	15.2	20.5	22.5	25.5	28.6	34.6	37.7	37.1	39.0	39.6	41.4	42.4	41.2	40.8	42.8	42.5	43.6	43.4	42.4	41.6	40.6	39.9	37.9	34.3	30.8	23.4	15.9	12.5	53.7
				Uncertainty A (dB)	0.7	0.5	0.6	0.5	0.6	0.4	0.5	0.6	0.4	0.4	0.4	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.3	0.4	0.6	
	Background	10.50	31	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.1	1.4	1.7	
				Combined Uncertainty (dB)	2.1	1.7	1.2	1.6	1.2	1.0	1.0	1.0	0.9	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.1	1.4	1.8	
11.0	Turbine ON	11.00	30	Average (dBA)	14.9	17.7	20.0	21.3	23.6	25.8	28.4	29.0	29.9	29.7	31.2	31.7	31.5	30.6	33.0	32.1	33.3	32.6	30.5	28.0	25.9	22.3	19.4	19.0	23.4	16.8	14.0	12.6	43.0
				Uncertainty A (dB)	0.9	0.9	0.7	0.5	0.5	0.4	0.3	0.4	0.4	0.5	0.4	0.4	0.3	0.3	0.4	0.5	0.5	0.5	0.5	0.5	0.7	1.5	0.7	0.6	0.6	0.6			
	Background	11.01	36	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.1	1.4	1.7		
				Combined Uncertainty (dB)	2.2	1.9	1.3	1.6	1.2	1.0	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.9	0.8	0.8	0.8	0.9	0.9	0.9	0.9	1.0	1.2	1.3	1.8	1.5	1.8		
11.5	Turbine ON	11.49	30	Average (dBA)	18.8	23.2	25.2	27.5	29.9	34.9	37.5	36.9	39.0	39.2	41.0	42.1	41.0	40.8	42.8	42.4	43.6	43.4	42.5	41.6	40.6	39.8	37.6	34.0	30.8	24.2	18.2	16.0	53.6
				Uncertainty A (dB)	0.6	0.5	0.5	0.3	0.2	0.2	0.3	0.3	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.4	0.6	0.6		
	Background	11.52	26	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.1	1.4	1.7		
				Combined Uncertainty (dB)	2.0	1.7	1.1	1.6	1.1	1.0	0.9	0.9	0.9	0.9	0.7	0.7	0.7	0.8	0.7	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.1	1.4	1.8		
12.0	Turbine ON	11.98	26	Average (dBA)	17.2	22.2	24.2	26.7	29.6	34.4	37.5	37.0	39.1	39.2	40.8	42.0	41.0	41.0	43.0	42.7	43.7	43.6	42.7	41.9	40.9	39.9	37.7	33.8	30.6	23.6	17.2	14.7	53.7
				Uncertainty A (dB)	0.5	0.5	0.4	0.4	0.3	0.2	0.2	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.5	0.5		
	Background	11.99	19	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.1	1.4	1.7		
				Combined Uncertainty (dB)	2.2	1.9	1.3	1.7	1.2	1.0	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	1.0	1.2	1.3	1.3	1.5	1.8			
12.5	Turbine ON	12.48	23	Average (dBA)	17.1	22.2	23.4	26.5	29.1	34.1	37.4	36.4	38.5	38.7	40.0	41.1	40.3	40.4	42.5	42.4	43.7	43.8	43.1	42.2	41.0	39.9	37.4	33.3	29.9	23.0	17.0	14.6	53.5
				Uncertainty A (dB)	0.5	0.4	0.4	0.3	0.3	0.2	0.3	0.3	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.5	0.5		
	Background	12.50	16	Uncertainty B (dB)	2.0	1.6	1.1	1.5	1.1	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	1.1	1.1	1.0	1.1	1.4	1.7		
				Combined Uncertainty (dB)	2.6	2.3	1.8	2.0	1.6	1.4	1.2	1.1	1.0	1.0	0.9	0.9	0.9	1.0	0.9	0.9	0.9	1.0	1.0	1.2	1.4	1.8	2.3	1.7	1.7	2.0			

Appendix D


Tonality Assessment




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 7.5 m/s
Figure D.01		




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 8 m/s
Figure D.02		




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 8.5 m/s
Figure D.03		




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 9 m/s
		Figure D.04




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 9.5 m/s
Figure D.05		




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 10 m/s
		Figure D.06




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 10.5 m/s
Figure D.07		




 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 11 m/s
Figure D.08		



 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 11.5 m/s
Figure D.09		



 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 12 m/s
Figure D.10		



 aercoustics	17095.01.T53.RP1	Project Name Belle River Wind Power Project - IEC 61400-11 Edition 3.0 - Turbine T53
	Scale: NTS Drawn by: AED Reviewed by: MAD Date: Nov 2018 Revision: 1	Figure Title Plot of narrow band spectra - Turbine ON vs. Background at 12.5 m/s
Figure D.11		

Table D.01 Tonality Assessment Table - 7.5 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Page 1 of 1

Report ID: 17095.01.T53.RP2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones							

Table D.02 Tonality Assessment Table - 8 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
 Report ID: 17095.01.T53.RP2

Page 1 of 1

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
145	68	24.7	42.9	35.4	-7.6	-2.0	-5.6
420	69	26.2	44.4	40.3	-4.1	-2.0	-2.1
267	69	24.2	42.5	39.0	-3.4	-2.0	-1.4
386	69	25.4	43.7	37.7	-6.0	-2.0	-4.0
215	69	26.9	45.2	36.7	-8.5	-2.0	-6.5
387	69	24.6	42.9	39.4	-3.4	-2.0	-1.4
305	70	25.1	43.4	39.2	-4.1	-2.0	-2.1
271	71	24.0	42.3	40.5	-1.8	-2.0	0.2
273	71	25.9	44.1	42.2	-1.9	-2.0	0.1
272	71	25.5	43.8	42.3	-1.5	-2.0	0.5
159	71	26.6	44.9	40.8	-4.1	-2.0	-2.1
266	71	26.8	45.0	41.4	-3.6	-2.0	-1.6
160	71	26.1	44.4	40.7	-3.7	-2.0	-1.7
216	71	25.8	44.0	41.4	-2.7	-2.0	-0.6
147	71	26.3	44.6	40.6	-4.0	-2.0	-1.9
214	71	27.7	45.9	42.1	-3.9	-2.0	-1.9
150	71	26.7	44.9	41.6	-3.3	-2.0	-1.3
312	71	26.4	44.6	40.5	-4.1	-2.0	-2.1
383	71	25.4	43.6	41.0	-2.7	-2.0	-0.7
419	71	27.3	45.5	41.6	-4.0	-2.0	-2.0
385	72	25.5	43.8	41.0	-2.7	-2.0	-0.7
217	72	27.2	45.4	39.3	-6.1	-2.0	-4.1
285	73	26.4	44.7	40.9	-3.8	-2.0	-1.8
187	73	27.9	46.2	33.9	-12.2	-2.0	-10.2
178	73	26.4	44.6	35.8	-8.8	-2.0	-6.8
309	73	26.7	45.0	39.9	-5.0	-2.0	-3.0
108	73	27.2	45.5	37.6	-7.9	-2.0	-5.9
143	73	28.4	46.7	36.6	-10.0	-2.0	-8.0
307	73	27.9	46.2	35.7	-10.4	-2.0	-8.4
94	73	27.4	45.6	38.9	-6.7	-2.0	-4.7
155	73	27.9	46.2	41.4	-4.7	-2.0	-2.7
158	73	24.9	43.1	36.2	-7.0	-2.0	-4.9
162	74	28.3	46.5	38.7	-7.8	-2.0	-5.8
161	74	25.3	43.6	37.9	-5.7	-2.0	-3.7
149	74	27.9	46.2	41.7	-4.5	-2.0	-2.5
213	74	27.6	45.9	36.2	-9.6	-2.0	-7.6
142	74	26.1	44.4	37.6	-6.7	-2.0	-4.7
388	74	25.0	43.2	40.6	-2.6	-2.0	-0.6
Average	72				-4.6	-2.0	-2.6

Table D.03 Tonality Assessment Table - 8.5 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
 Report ID: 17095.01.T53.RP2

Page 1 of 2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
375	70	26.0	44.2	38.8	-5.4	-2.0	-3.4
438	70	27.9	46.1	37.5	-8.7	-2.0	-6.7
304	70	26.2	44.5	39.8	-4.6	-2.0	-2.6
382	70	25.6	43.9	39.8	-4.1	-2.0	-2.1
370	71	27.0	45.3	39.8	-5.4	-2.0	-3.4
417	71	26.9	45.1	40.5	-4.6	-2.0	-2.6
299	71	25.1	43.3	38.8	-4.6	-2.0	-2.5
96	71	25.0	43.2	41.2	-2.0	-2.0	0.0
126	71	26.0	44.3	40.7	-3.6	-2.0	-1.6
70	71	26.1	44.3	39.5	-4.8	-2.0	-2.8
376	71	25.4	43.6	40.2	-3.4	-2.0	-1.4
151	71	27.0	45.3	40.6	-4.6	-2.0	-2.6
125	71	27.4	45.7	35.8	-9.9	-2.0	-7.9
41	71	26.1	44.3	40.7	-3.7	-2.0	-1.7
290	71	28.0	46.3	36.7	-9.6	-2.0	-7.6
97	71	27.9	46.2	39.9	-6.2	-2.0	-4.2
454	71	29.1	47.4	40.2	-7.1	-2.0	-5.1
99	71	25.3	43.6	40.2	-3.4	-2.0	-1.4
274	71	26.2	44.5	38.3	-6.2	-2.0	-4.2
308	71	27.4	45.6	40.2	-5.4	-2.0	-3.4
381	71	24.7	43.0	40.7	-2.3	-2.0	-0.3
284	71	25.8	44.1	41.3	-2.8	-2.0	-0.8
418	71	24.5	42.8	41.6	-1.2	-2.0	0.9
289	71	27.5	45.7	33.9	-11.8	-2.0	-9.8
455	71	28.7	46.9	36.4	-10.5	-2.0	-8.5
384	71	25.3	43.6	39.2	-4.4	-2.0	-2.4
283	71	24.9	43.1	40.4	-2.7	-2.0	-0.7
68	71	26.8	45.0	37.0	-8.1	-2.0	-6.1
148	71	26.2	44.5	41.3	-3.2	-2.0	-1.2
95	71	26.1	44.3	41.1	-3.3	-2.0	-1.3
264	71	25.0	43.2	41.5	-1.7	-2.0	0.3
191	71	24.1	42.4	40.2	-2.2	-2.0	-0.2
364	72	27.7	45.9	38.7	-7.2	-2.0	-5.2
416	72	26.7	45.0	40.8	-4.2	-2.0	-2.2
310	72	26.9	45.1	39.5	-5.7	-2.0	-3.7
363	72	27.4	45.6	37.0	-8.6	-2.0	-6.6
265	72	24.5	42.7	40.4	-2.4	-2.0	-0.4
392	73	25.0	43.2	39.5	-3.7	-2.0	-1.7
311	73	28.3	46.6	41.1	-5.5	-2.0	-3.5
40	74	26.5	44.7	39.7	-5.1	-2.0	-3.1
186	74	30.1	48.4	37.8	-10.6	-2.0	-8.6
203	74	26.8	45.0	40.8	-4.2	-2.0	-2.2
282	74	25.1	43.4	39.2	-4.2	-2.0	-2.2
117	74	26.9	45.1	38.1	-7.1	-2.0	-5.1
154	74	26.1	44.4	40.7	-3.7	-2.0	-1.7
69	74	26.0	44.2	39.5	-4.7	-2.0	-2.7
101	74	26.9	45.2	40.7	-4.5	-2.0	-2.5
153	74	25.1	43.4	40.6	-2.8	-2.0	-0.8
50	74	27.0	45.3	39.8	-5.5	-2.0	-3.5
139	74	25.7	43.9	40.3	-3.7	-2.0	-1.7
185	74	25.9	44.1	38.7	-5.5	-2.0	-3.5
107	74	28.1	46.4	36.9	-9.5	-2.0	-7.5
100	74	28.3	46.6	39.2	-7.3	-2.0	-5.3

Table D.03 Tonality Assessment Table - 8.5 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Report ID: 17095.01.T53.RP2

Page 2 of 2

Created on: 2019-05-21

184	75	28.5	46.8	39.5	-7.3	-2.0	-5.3
Average	72				-4.7	-2.0	-2.7

Table D.04 Tonality Assessment Table - 9 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
Report ID: 17095.01.T53.RP2

Page 1 of 2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
281	69	25.1	43.3	36.9	-6.4	-2.0	-4.4
115	70	26.6	44.8	41.8	-3.0	-2.0	-1.0
545	70	26.3	44.6	41.9	-2.7	-2.0	-0.7
12	70	24.9	43.2	39.6	-3.5	-2.0	-1.5
135	70	27.8	46.1	41.9	-4.2	-2.0	-2.1
298	70	24.3	42.5	42.0	-0.5	-2.0	1.5
352	71	25.8	44.0	41.9	-2.1	-2.0	-0.1
103	71	26.0	44.3	41.1	-3.1	-2.0	-1.1
30	71	25.1	43.3	41.7	-1.6	-2.0	0.4
72	71	27.0	45.2	41.8	-3.4	-2.0	-1.4
301	71	24.6	42.8	40.5	-2.3	-2.0	-0.3
201	71	27.7	46.0	42.7	-3.3	-2.0	-1.3
414	71	26.6	44.8	42.0	-2.8	-2.0	-0.8
36	71	27.8	46.0	41.7	-4.3	-2.0	-2.3
205	71	25.5	43.8	41.1	-2.7	-2.0	-0.7
192	71	26.1	44.4	40.7	-3.7	-2.0	-1.7
37	71	23.9	42.1	42.2	0.1	-2.0	2.1
116	71	26.5	44.8	41.5	-3.2	-2.0	-1.2
35	71	30.7	48.9	36.8	-12.1	-2.0	-10.1
14	71	28.0	46.3	40.2	-6.1	-2.0	-4.1
76	71	27.9	46.2	42.1	-4.0	-2.0	-2.0
71	71	25.8	44.1	41.5	-2.5	-2.0	-0.5
65	71	27.5	45.7	42.5	-3.2	-2.0	-1.2
85	71	27.5	45.8	42.0	-3.7	-2.0	-1.7
60	71	29.7	47.9	41.0	-6.9	-2.0	-4.9
47	71	25.1	43.3	41.3	-2.0	-2.0	0.0
39	71	28.6	46.9	43.1	-3.8	-2.0	-1.8
53	71	25.2	43.4	42.2	-1.3	-2.0	0.7
43	71	29.3	47.5	44.1	-3.4	-2.0	-1.4
63	71	27.1	45.4	42.3	-3.1	-2.0	-1.1
64	71	26.9	45.2	42.4	-2.7	-2.0	-0.7
58	71	26.3	44.6	41.8	-2.8	-2.0	-0.8
52	71	24.5	42.7	41.3	-1.4	-2.0	0.6
48	71	26.3	44.6	42.4	-2.2	-2.0	-0.2
13	71	27.9	46.1	42.2	-3.9	-2.0	-1.9
15	71	27.8	46.0	42.5	-3.6	-2.0	-1.6
204	71	25.8	44.0	40.8	-3.3	-2.0	-1.3
45	71	25.8	44.1	41.3	-2.8	-2.0	-0.8
137	71	29.0	47.3	42.5	-4.8	-2.0	-2.8
31	71	26.4	44.6	42.8	-1.8	-2.0	0.2
294	71	27.6	45.8	40.8	-5.0	-2.0	-3.0
46	71	25.6	43.9	40.5	-3.3	-2.0	-1.3
51	71	25.5	43.7	40.9	-2.8	-2.0	-0.8
38	71	27.4	45.6	41.2	-4.4	-2.0	-2.4
73	71	27.0	45.2	41.4	-3.8	-2.0	-1.8
84	71	27.5	45.7	40.7	-5.0	-2.0	-3.0
295	71	26.2	44.4	41.1	-3.4	-2.0	-1.4
102	71	25.8	44.0	39.7	-4.3	-2.0	-2.3
77	71	28.2	46.4	35.2	-11.2	-2.0	-9.2
380	71	25.9	44.2	41.0	-3.2	-2.0	-1.2
300	71	25.1	43.4	39.4	-4.0	-2.0	-2.0
127	71	25.0	43.3	40.2	-3.0	-2.0	-1.0
42	71	26.4	44.7	41.8	-2.8	-2.0	-0.8

Table D.04 Tonality Assessment Table - 9 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
 Report ID: 17095.01.T53.RP2

Page 2 of 2

Created on: 2019-05-21

293	71	27.0	45.3	41.1	-4.2	-2.0	-2.2
439	71	26.9	45.1	39.7	-5.4	-2.0	-3.4
415	71	25.7	44.0	39.4	-4.6	-2.0	-2.6
61	71	26.2	44.5	41.5	-3.0	-2.0	-1.0
362	71	26.9	45.2	40.4	-4.8	-2.0	-2.8
369	71	26.2	44.4	39.9	-4.5	-2.0	-2.5
83	71	28.2	46.5	40.4	-6.1	-2.0	-4.1
62	71	25.9	44.2	42.0	-2.1	-2.0	-0.1
371	71	25.9	44.2	39.9	-4.3	-2.0	-2.3
377	72	25.2	43.5	42.3	-1.2	-2.0	0.8
59	72	28.7	47.0	40.6	-6.4	-2.0	-4.4
313	72	28.0	46.2	38.3	-7.9	-2.0	-5.9
396	72	26.7	45.0	42.0	-3.0	-2.0	-1.0
365	72	26.4	44.7	40.2	-4.5	-2.0	-2.5
303	72	26.1	44.3	41.1	-3.2	-2.0	-1.2
78	72	29.4	47.6	37.8	-9.8	-2.0	-7.8
292	72	25.7	43.9	40.6	-3.3	-2.0	-1.3
26	73	29.1	47.4	42.8	-4.6	-2.0	-2.6
544	73	27.2	45.4	41.4	-4.0	-2.0	-2.0
395	73	25.6	43.9	41.3	-2.6	-2.0	-0.6
114	73	25.7	44.0	41.2	-2.8	-2.0	-0.8
67	74	26.3	44.6	37.8	-6.8	-2.0	-4.8
152	74	26.5	44.7	39.8	-4.9	-2.0	-2.9
136	74	28.8	47.0	39.5	-7.5	-2.0	-5.5
138	74	28.4	46.6	37.6	-9.0	-2.0	-7.0
57	74	25.2	43.5	41.9	-1.5	-2.0	0.5
89	74	27.8	46.1	37.3	-8.8	-2.0	-6.8
49	74	26.5	44.7	40.2	-4.6	-2.0	-2.6
105	74	28.3	46.6	42.7	-3.9	-2.0	-1.9
140	74	28.4	46.6	41.5	-5.1	-2.0	-3.1
141	74	26.4	44.7	40.7	-4.0	-2.0	-2.0
81	74	29.4	47.7	41.6	-6.1	-2.0	-4.1
106	74	26.8	45.0	41.6	-3.4	-2.0	-1.4
456	74	28.0	46.2	39.2	-7.0	-2.0	-5.0
113	75	25.5	43.7	39.8	-3.9	-2.0	-1.9
Average	72				-3.7	-2.0	-1.7

Table D.05 Tonality Assessment Table - 9.5 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Page 1 of 2

Report ID: 17095.01.T53.RP2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
502	68	27.7	45.9	34.1	-11.8	-2.0	-9.8
394	69	25.6	43.8	39.6	-4.3	-2.0	-2.3
579	69	26.3	44.6	37.6	-6.9	-2.0	-4.9
350	70	25.9	44.1	39.8	-4.3	-2.0	-2.3
409	70	26.5	44.7	38.1	-6.6	-2.0	-4.6
339	70	27.6	45.8	36.6	-9.2	-2.0	-7.2
374	70	26.2	44.4	39.3	-5.1	-2.0	-3.1
11	70	26.5	44.7	39.5	-5.2	-2.0	-3.2
19	70	26.8	45.0	41.8	-3.2	-2.0	-1.2
27	71	26.3	44.5	41.8	-2.7	-2.0	-0.7
29	71	27.1	45.4	42.2	-3.2	-2.0	-1.2
337	71	27.1	45.3	42.5	-2.9	-2.0	-0.9
32	71	25.8	44.0	42.3	-1.7	-2.0	0.3
194	71	28.2	46.4	42.8	-3.6	-2.0	-1.6
86	71	27.6	45.9	45.5	-0.4	-2.0	1.6
16	71	24.5	42.8	42.3	-0.5	-2.0	1.5
361	71	26.2	44.4	41.3	-3.1	-2.0	-1.1
367	71	26.9	45.1	42.1	-3.0	-2.0	-1.0
28	71	26.4	44.6	43.3	-1.3	-2.0	0.7
549	71	27.1	45.3	40.9	-4.4	-2.0	-2.4
1	71	25.8	44.0	42.2	-1.8	-2.0	0.2
17	71	25.0	43.2	42.5	-0.7	-2.0	1.3
87	71	26.6	44.8	42.2	-2.6	-2.0	-0.6
220	71	26.0	44.3	41.0	-3.2	-2.0	-1.2
336	71	26.2	44.5	41.5	-3.0	-2.0	-1.0
3	71	28.5	46.8	44.0	-2.7	-2.0	-0.7
21	71	25.9	44.2	41.9	-2.3	-2.0	-0.3
351	71	26.2	44.5	41.9	-2.6	-2.0	-0.6
335	71	26.1	44.3	40.4	-4.0	-2.0	-2.0
297	71	25.1	43.3	42.9	-0.5	-2.0	1.5
275	71	27.1	45.4	40.2	-5.2	-2.0	-3.2
379	71	26.2	44.5	40.9	-3.6	-2.0	-1.6
128	71	25.3	43.6	41.5	-2.1	-2.0	-0.1
368	71	26.5	44.7	42.2	-2.5	-2.0	-0.5
79	71	30.8	49.1	43.9	-5.2	-2.0	-3.2
193	71	25.7	43.9	41.6	-2.4	-2.0	-0.4
302	71	26.1	44.4	40.3	-4.0	-2.0	-2.0
120	71	25.3	43.6	41.2	-2.4	-2.0	-0.4
340	71	27.9	46.1	41.8	-4.3	-2.0	-2.3
20	71	25.8	44.1	41.9	-2.2	-2.0	-0.2
44	71	28.6	46.9	40.2	-6.7	-2.0	-4.7
33	71	28.6	46.8	41.1	-5.7	-2.0	-3.7
296	71	25.9	44.2	41.8	-2.3	-2.0	-0.3
54	72	26.9	45.1	41.9	-3.2	-2.0	-1.2
546	72	28.3	46.6	41.4	-5.1	-2.0	-3.1
372	72	25.4	43.7	41.3	-2.4	-2.0	-0.4
366	72	25.9	44.2	41.4	-2.7	-2.0	-0.7
104	72	26.9	45.2	41.8	-3.4	-2.0	-1.4
393	72	24.9	43.1	40.3	-2.8	-2.0	-0.8
80	73	27.0	45.3	42.2	-3.1	-2.0	-1.1
582	74	27.3	45.5	42.8	-2.7	-2.0	-0.7
397	74	26.8	45.1	40.2	-4.9	-2.0	-2.9
134	74	26.6	44.9	40.4	-4.4	-2.0	-2.4

Table D.05 Tonality Assessment Table - 9.5 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Page 2 of 2

Report ID: 17095.01.T53.RP2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
122	74	28.0	46.2	39.9	-6.3	-2.0	-4.3
410	74	26.5	44.7	41.8	-2.9	-2.0	-0.9
581	74	26.4	44.7	42.7	-2.0	-2.0	0.0
436	74	26.3	44.5	41.5	-3.0	-2.0	-1.0
121	74	27.6	45.8	40.8	-5.0	-2.0	-3.0
88	74	27.1	45.4	42.2	-3.2	-2.0	-1.2
580	74	28.2	46.4	42.7	-3.7	-2.0	-1.7
437	74	27.3	45.6	42.5	-3.1	-2.0	-1.1
Average	71				-3.2	-2.0	-1.2

Table D.06 Tonality Assessment Table - 10 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Page 1 of 1

Report ID: 17095.01.T53.RP2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
559	68	26.4	44.6	35.8	-8.8	-2.0	-6.8
543	69	26.5	44.7	36.6	-8.2	-2.0	-6.2
452	69	29.1	47.4	38.7	-8.7	-2.0	-6.7
447	69	28.2	46.4	39.4	-7.0	-2.0	-5.0
565	69	25.9	44.1	38.0	-6.1	-2.0	-4.1
278	69	26.8	45.0	41.7	-3.3	-2.0	-1.3
567	70	26.6	44.9	36.7	-8.2	-2.0	-6.2
484	70	27.5	45.8	38.6	-7.2	-2.0	-5.2
22	71	26.7	45.0	43.2	-1.8	-2.0	0.2
18	71	28.7	46.9	41.8	-5.2	-2.0	-3.2
195	71	27.6	45.9	41.7	-4.2	-2.0	-2.2
338	71	26.6	44.9	42.8	-2.0	-2.0	0.0
23	71	29.2	47.4	40.5	-7.0	-2.0	-5.0
129	71	24.8	43.0	42.4	-0.7	-2.0	1.3
353	71	24.5	42.7	42.5	-0.3	-2.0	1.7
276	71	26.2	44.5	41.9	-2.5	-2.0	-0.5
550	71	28.0	46.2	42.3	-3.9	-2.0	-1.9
24	71	25.7	44.0	41.8	-2.2	-2.0	-0.2
359	71	26.8	45.1	41.0	-4.1	-2.0	-2.1
133	71	27.4	45.7	42.9	-2.7	-2.0	-0.7
55	71	26.3	44.6	42.4	-2.1	-2.0	-0.1
378	71	25.3	43.6	41.9	-1.7	-2.0	0.3
449	71	28.3	46.6	40.3	-6.2	-2.0	-4.2
360	71	25.8	44.0	40.7	-3.3	-2.0	-1.3
411	71	26.9	45.1	42.8	-2.3	-2.0	-0.3
398	71	27.0	45.3	41.8	-3.5	-2.0	-1.5
412	71	28.1	46.4	42.6	-3.8	-2.0	-1.8
2	71	27.3	45.6	40.6	-4.9	-2.0	-2.9
277	73	27.2	45.4	42.0	-3.4	-2.0	-1.4
199	74	26.5	44.8	40.0	-4.8	-2.0	-2.8
435	74	27.5	45.8	40.0	-5.8	-2.0	-3.8
56	74	26.6	44.8	40.9	-3.9	-2.0	-1.9
556	74	28.4	46.7	40.6	-6.1	-2.0	-4.1
221	74	27.1	45.4	41.9	-3.5	-2.0	-1.5
25	74	31.0	49.3	37.9	-11.4	-2.0	-9.4
440	75	27.6	45.9	41.1	-4.7	-2.0	-2.7
Average	71				-4.0	-2.0	-2.0

Table D.07 Tonality Assessment Table - 10.5 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Page 1 of 1

Report ID: 17095.01.T53.RP2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
510	68	22.6	40.8	34.6	-6.2	-2.0	-4.2
516	69	25.4	43.7	32.2	-11.5	-2.0	-9.5
130	71	26.1	44.3	40.9	-3.4	-2.0	-1.4
432	71	24.8	43.1	40.4	-2.6	-2.0	-0.6
279	71	26.5	44.7	41.1	-3.7	-2.0	-1.7
373	72	25.0	43.3	40.0	-3.2	-2.0	-1.2
399	72	24.7	43.0	37.5	-5.5	-2.0	-3.5
346	72	24.7	42.9	39.1	-3.8	-2.0	-1.8
349	72	25.7	44.0	38.9	-5.0	-2.0	-3.0
355	73	24.7	43.0	38.6	-4.4	-2.0	-2.4
564	73	24.8	43.1	37.4	-5.7	-2.0	-3.7
561	73	24.7	43.0	40.1	-2.9	-2.0	-0.9
560	73	27.9	46.1	41.3	-4.8	-2.0	-2.8
562	73	23.5	41.7	39.1	-2.6	-2.0	-0.6
584	74	27.4	45.7	38.3	-7.4	-2.0	-5.4
Average	72				-4.4	-2.0	-2.4

Table D.10 Tonality Assessment Table - 11 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Page 1 of 1

Report ID: 17095.01.T53.RP2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones							

Table D.09 Tonality Assessment Table - 11.5 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Page 1 of 1

Report ID: 17095.01.T53.RP2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
474	69	26.9	45.1	33.3	-11.8	-2.0	-9.8
599	70	23.8	42.0	35.7	-6.3	-2.0	-4.3
407	70	26.5	44.7	33.9	-10.8	-2.0	-8.8
538	71	25.6	43.9	39.3	-4.6	-2.0	-2.6
443	71	25.3	43.6	37.8	-5.8	-2.0	-3.8
500	71	25.5	43.7	37.3	-6.5	-2.0	-4.5
357	71	26.2	44.4	37.8	-6.6	-2.0	-4.6
356	72	24.0	42.3	39.7	-2.6	-2.0	-0.6
344	72	27.2	45.4	39.0	-6.5	-2.0	-4.5
322	72	24.4	42.6	39.7	-2.9	-2.0	-0.9
490	73	29.3	47.6	36.0	-11.5	-2.0	-9.5
314	73	28.1	46.4	38.2	-8.1	-2.0	-6.1
539	73	24.1	42.3	38.4	-3.9	-2.0	-1.9
431	74	24.8	43.1	39.9	-3.1	-2.0	-1.1
573	74	25.0	43.2	40.5	-2.8	-2.0	-0.7
430	74	24.6	42.8	39.6	-3.2	-2.0	-1.2
442	74	26.7	44.9	39.1	-5.8	-2.0	-3.8
609	74	27.1	45.4	36.7	-8.7	-2.0	-6.7
433	74	27.1	45.3	36.6	-8.7	-2.0	-6.7
572	75	23.5	41.7	39.1	-2.7	-2.0	-0.7
319	86	24.9	43.2	42.7	-0.5	-2.0	1.5
Average	73				-4.9	-2.0	-2.9

Table D.10 Tonality Assessment Table - 12 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Report ID: 17095.01.T53.RP2

Page 1 of 1

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
603	69	24.3	42.6	35.9	-6.7	-2.0	-4.7
558	70	25.7	44.0	35.4	-8.6	-2.0	-6.6
503	72	26.5	44.7	41.8	-2.9	-2.0	-0.9
511	72	25.3	43.5	37.6	-5.9	-2.0	-3.9
534	72	22.8	41.0	39.7	-1.3	-2.0	0.7
498	72	23.9	42.1	37.6	-4.6	-2.0	-2.6
445	72	27.0	45.3	36.8	-8.5	-2.0	-6.5
608	72	25.3	43.6	38.0	-5.6	-2.0	-3.6
571	72	22.2	40.4	39.5	-1.0	-2.0	1.0
587	73	24.3	42.5	40.6	-1.9	-2.0	0.1
506	73	24.7	43.0	41.4	-1.6	-2.0	0.4
497	73	25.7	43.9	39.7	-4.2	-2.0	-2.2
585	73	26.5	44.8	34.2	-10.6	-2.0	-8.6
600	73	24.6	42.8	40.1	-2.7	-2.0	-0.7
586	73	28.3	46.5	38.3	-8.3	-2.0	-6.3
316	73	26.8	45.0	33.2	-11.8	-2.0	-9.8
574	74	24.5	42.7	37.7	-5.0	-2.0	-3.0
406	74	25.4	43.6	39.3	-4.3	-2.0	-2.3
597	75	26.5	44.8	35.0	-9.8	-2.0	-7.8
458	76	27.2	45.5	38.2	-7.2	-2.0	-5.2
496	79	28.8	47.0	35.5	-11.5	-2.0	-9.5
Average	73				-4.8	-2.0	-2.8

Table D.11 Tonality Assessment Table - 12.5 m/s

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement

Page 1 of 1

Report ID: 17095.01.T53.RP2

Created on: 2019-05-21

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones							

Appendix E Measurement Data

Table E.01 Measurement data - Turbine ON

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
Report ID: 17095.01.T53.RP1

Page 1 of 4

Created on: 11/13/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAEq	Turbine Power Output (kW)	Reference Yaw Angle (deg)	Yaw Angle (deg)	Pitch (deg)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (hPa)	Relative Humidity (%)
1	7.7	52.2	1360	217.0	231.7	-1.8	12.5	8.1	7.8	11.2	99778.7	49
2	7.4	51.1	1189	217.0	231.7	-1.8	12.0	7.2	8.6	11.3	99775.7	49
3	7.3	51.3	1157	217.0	231.6	-1.8	11.8	8.7	7.7	11.3	99776.5	49
4	7.0	48.7	957	217.0	231.6	-2.1	10.8	6.3	7.6	11.3	99776.8	49
5	6.5	48.7	819	217.0	231.6	-2.1	10.6	6.3	7.6	11.3	99776.8	49
6	6.5	49.5	786	217.0	231.6	-2.1	10.4	6.8	7.2	11.3	99776.7	49
7	6.4	49.5	760	217.0	231.7	-2.1	10.3	5.8	8.0	11.3	99776.3	49
8	6.4	48.8	758	217.0	231.7	-2.1	10.3	7.0	7.7	11.4	99774.9	48
9	6.7	48.7	676	217.0	231.7	-2.1	10.3	6.7	8.0	11.4	99774.8	48
10	7.0	50.4	1004	217.0	231.7	-2.1	11.3	7.3	8.2	11.4	99774.4	48
11	7.5	52.4	1260	217.0	231.6	-0.9	12.3	6.8	8.2	11.4	99774.8	48
12	8.3	53.4	1650	217.0	231.4	1.2	13.2	8.1	6.9	11.4	99774.1	48
13	8.3	53.1	1757	217.0	231.4	1.2	13.2	8.4	7.5	11.4	99774.4	48
14	8.1	53.6	1548	217.0	229.0	-1.3	13.1	8.9	6.9	11.4	99773.7	49
15	7.8	52.8	1394	217.0	228.2	-1.5	12.7	8.0	6.8	11.4	99774.4	49
16	7.6	51.8	1280	217.0	226.4	-1.5	12.3	7.7	6.0	11.4	99774.8	49
17	7.5	51.4	1250	217.0	226.4	-1.8	12.3	7.4	6.3	11.4	99775.6	49
18	7.7	52.5	1251	217.0	226.4	-1.4	12.3	7.6	11.1	11.4	99775.6	49
19	8.1	53.4	1519	217.0	226.4	-1.6	13.1	7.8	6.6	11.3	99759.9	49
20	8.1	54.0	1530	217.0	224.4	-1.6	13.1	7.0	7.2	11.3	99759.4	49
21	8.1	54.0	1528	217.0	223.5	-1.6	13.1	6.9	7.0	11.3	99759.9	49
22	8.6	53.9	1834	217.0	223.3	-1.3	13.2	9.1	6.5	11.3	99759.9	49
23	9.1	54.4	2143	217.0	223.3	-0.9	13.2	9.1	7.0	11.3	99759.9	49
24	10.1	53.8	2556	217.0	221.2	0.4	13.2	9.8	6.8	11.3	99759.0	49
25	9.9	54.0	2493	217.0	221.2	-0.3	13.1	9.4	7.6	11.3	99759.0	49
26	9.9	54.0	2494	217.0	221.3	-0.7	13.0	9.7	7.8	11.3	99747.4	49
27	10.7	54.1	2495	217.0	221.3	-0.3	13.1	10.9	7.7	11.4	99747.4	49
28			2690	217.0	221.3	-0.7	13.0	10.1	7.3	11.3	99747.0	49
29	9.0	53.7	2052	217.0	221.3	-1.1	12.9	9.8	7.3	11.3	99746.7	49
30	8.6	53.8	1836	217.0	221.3	-1.2	13.0	9.2	9.4	11.3	99746.6	49
31	8.4	53.5	1702	217.0	221.3	-1.3	13.1	8.5	7.8	11.3	99746.6	49
32	8.4	54.0	1713	217.0	221.2	-1.4	13.1	8.9	7.4	11.3	99759.8	49
33	8.0	53.6	1508	217.0	221.2	-1.7	12.9	7.8	9.3	11.2	99759.8	48
34	7.5	52.6	1255	217.0	221.3	-1.8	12.2	6.6	7.8	11.2	99759.4	48
35	7.2	52.3	1092	217.0	221.3	-1.8	11.6	7.0	8.4	11.2	99758.8	48
36	7.4	52.5	1200	217.0	221.3	-1.0	12.0	7.6	8.0	11.2	99758.8	48
37	8.4	53.5	1175	217.0	221.3	-0.4	13.1	8.8	7.7	11.2	99759.6	48
38	8.7	54.0	1868	217.0	221.3	-0.9	13.1	8.0	7.4	11.1	99759.7	49
39	8.1	53.7	1519	217.0	221.3	-1.6	13.0	7.6	7.8	11.1	99759.7	49
40	8.9	53.9	2023	217.0	221.3	-0.9	13.0	8.9	7.4	11.1	99759.9	49
41	8.9	54.2	2024	217.0	221.3	-1.1	13.1	9.5	7.6	11.1	99759.9	49
42	9.0	54.0	2038	217.0	221.2	-1.1	13.1	10.6	7.8	11.1	99762.3	49
43	8.9	54.1	1992	217.0	221.2	-1.1	13.1	9.7	6.3	11.0	99772.8	50
44	9.4	54.1	2255	217.0	221.2	-0.1	13.2	10.1	6.8	11.0	99773.1	50
45	9.4	53.5	2260	217.0	221.3	-0.1	13.1	10.5	6.7	11.0	99773.1	50
46	9.1	53.5	2265	217.0	221.3	-1.0	13.0	9.9	7.2	11.0	99773.1	50
47	8.5	53.4	1762	217.0	221.3	-1.3	13.0	7.1	7.2	11.0	99773.1	50
48	8.8	53.6	1965	217.0	221.3	-0.9	13.2	8.9	6.4	11.0	99772.8	50
49	9.0	53.4	2073	217.0	221.3	-1.1	13.2	8.6	6.2	11.0	99772.3	50
50	9.4	53.9	2177	217.0	221.3	-0.9	13.2	10.1	6.3	11.0	99772.3	50
51	9.0	53.9	2039	217.0	221.3	-1.1	13.1	10.3	7.0	11.0	99772.6	50
52	8.7	53.4	1894	217.0	221.3	-1.2	13.1	10.0	7.3	11.0	99772.7	50
53	8.1	53.4	1517	217.0	224.5	-1.6	12.9	8.8	8.7	11.0	99772.8	50
54	7.8	53.8	1996	217.0	226.8	-1.4	13.0	8.7	9.3	11.0	99773.0	50
55	8.4	53.8	2170	217.0	229.9	-1.4	13.0	9.4	9.7	11.0	99745.9	49
56	8.4	53.6	1734	217.0	229.9	-1.3	13.2	9.9	9.5	11.0	99747.4	49
57	8.0	53.5	1473	217.0	229.9	-1.7	12.9	8.0	10.4	11.0	99747.7	49
58	8.4	53.7	1699	217.0	229.9	-1.2	13.2	9.6	10.2	11.0	99747.6	49
59	8.4	54.0	1705	217.0	229.9	-1.0	13.2	9.1	9.8	11.0	99748.9	49
60	8.1	53.7	1559	217.0	229.9	-1.6	13.1	7.1	9.7	11.1	99763.5	49
61	9.1	54.1	2108	217.0	229.9	0.0	13.4	8.7	10.8	11.1	99774.7	49
62	11.3	54.7	2823	217.0	229.9	1.6	13.4	11.5	10.1	11.1	99774.2	49
63	11.4	54.1	2884	217.0	229.9	3.6	13.5	11.6	9.4	11.1	99774.3	49
64	12.0	54.0	2170	217.0	229.9	5.1	13.4	12.1	9.4	11.1	99774.3	49
65	12.8	54.6	2913	217.0	229.9	7.4	13.7	12.9	10.1	11.1	99774.3	49
66	11.4	55.4	2793	217.0	229.9	6.8	13.1	11.6	9.4	11.0	99774.3	49
67	11.7	53.3	2736	217.0	229.9	5.7	12.9	11.8	8.1	11.0	99775.7	48
68	10.9	52.8	2165	217.0	229.8	4.8	13.0	11.1	9.1	11.0	99775.3	48
69	11.2	53.0	2754	217.0	229.9	4.2	12.9	11.3	8.1	11.0	99775.7	48
70	11.5	53.6	2789	217.0	231.6	4.6	13.2	11.6	9.6	11.0	99775.5	48
71			2841	217.0	232.5	5.8	13.4	11.6	10.9	11.0	99776.0	48
72			2869	217.0	232.5	7.1	13.6	12.5	10.3	11.0	99773.4	48
73			2890	217.0	232.5	5.1	13.4	11.4	10.3	11.0	99773.4	48
74			2720	217.0	232.5	5.3	12.8	11.3	10.2	11.0	99762.3	49
75			2703	217.0	232.5	3.7	12.7	11.3	9.3	11.0	99762.0	49
76			2740	217.0	232.5	2.9	12.9	11.2	9.5	11.0	99761.8	49
77			2765	217.0	232.5	2.6	13.0	12.1	8.9	11.0	99761.8	49
78			2777	217.0	232.6	3.2	13.2	11.4	8.7	11.0	99763.3	49
79			2818	217.0	232.6	3.6	13.3	11.1	8.4	11.0	99775.8	49
80			2894	217.0	232.6	3.9	13.6	11.7	6.5	11.0	99775.9	49
81			2761	217.0	232.4	6.8	13.0	11.9	9.2	11.0	99775.0	49
82			2704	217.0	232.4	5.0	13.1	10.1	9.5	11.0	99775.0	49
83	9.7	53.5	2413	217.0	226.4	0.7	13.0	9.9	5.9	10.8	99774.6	52
84	9.7	53.7	2404	217.0	226.3	0.2	13.0	9.9	5.5	10.8	99774.7	52
85	9.5	54.3	2305	217.0	226.4	-0.6	13.0	9.2	6.4	10.8	99774.9	52
86	10.0	54.2	2525	217.0	226.3	-0.3	13.1	10.6	6.5	10.8	99775.0	52
87	9.6	54.2	2139	217.0	226.4	-0.8	12.9	10.2	6.4	10.8	99775.5	52
88	9.4	54.0	2248	217.0	226.4	-0.4	13.1	9.0	5.5	10.8	99775.4	52

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAEq</

Table E.01 Measurement data - Turbine ON

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
Report ID: 17095.01.T53.RP1

Page 2 of 4

Created on: 11/13/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	L _{Aeq} (dB)	Turbine Power (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
177	7.1	51.4	1043	217.0	215.3	-1.5	11.6	8.7	7.8	11.7	99575.0	45
178	11.5	53.3	2775	217.0	218.8	1.2	13.1	11.7	7.8	11.8	99520.5	44
179	11.6	53.3	2711	217.0	218.8	0.0	13.1	10.8	7.4	11.8	99520.5	44
180	10.7	53.9	210	217.0	218.6	0.0	13.1	10.8	7.4	11.8	99519.8	44
181	11.3	54.2	2777	217.0	218.6	-0.3	13.1	11.4	6.9	11.8	99519.8	44
182	11.2	53.7	2688	217.0	218.8	-0.6	13.0	11.3	6.4	11.8	99519.9	45
183	10.2	53.8	2567	217.0	218.9	-0.8	13.0	11.0	7.9	11.8	99521.2	45
184	9.6	53.7	2360	217.0	218.7	-0.9	13.0	9.5	9.5	11.8	99521.2	45
185	9.5	53.8	2304	217.0	218.8	-0.9	13.0	9.7	9.9	11.8	99519.9	45
186	8.7	53.8	1876	217.0	218.8	-1.2	12.9	9.9	10.1	11.8	99520.8	45
187	8.9	54.1	2016	217.0	218.6	0.0	13.2	8.9	10.2	11.8	99521.0	45
188	9.8	54.0	2429	217.0	218.9	0.9	13.2	10.0	9.9	11.9	99522.4	45
189	11.7	54.3	2671	217.0	218.7	2.0	13.1	11.9	9.5	11.9	99522.4	45
190	11.3	53.8	2864	217.0	219.0	4.3	13.5	11.4	10.2	11.9	99521.0	45
191	11.6	53.6	2777	217.0	221.4	3.6	13.1	11.7	10.3	11.9	99521.7	45
192	11.0	54.2	2822	217.0	221.6	4.7	13.4	11.1	9.8	11.9	99520.5	45
193	12.1	53.8	2822	217.0	221.6	5.4	13.3	12.2	8.8	12.0	99520.5	45
194	9.4	53.0	2474	217.0	219.2	3.9	12.7	12.0	9.0	10.0	99523.7	44
195	9.9	53.6	2487	217.0	221.6	2.2	13.0	11.6	9.7	12.0	99548.7	44
196	10.1	53.7	2561	217.0	221.6	1.4	13.0	11.3	9.2	12.0	99549.1	44
197	9.8	54.4	2440	217.0	221.6	0.8	13.1	9.4	9.4	12.0	99549.2	44
198	11.6	54.6	2838	217.0	221.5	3.0	13.5	11.7	9.9	12.0	99548.6	44
199	12.3	54.5	2777	217.0	221.1	4.9	13.1	12.5	5.1	12.0	99548.6	44
200	9.9	54.1	2463	217.0	218.5	1.9	12.9	11.5	9.8	12.0	99550.0	44
201	8.9	54.6	1985	217.0	218.5	0.0	12.9	9.1	9.6	12.0	99550.4	44
202	8.7	54.9	1874	217.0	218.6	-1.0	13.0	9.8	6.9	12.0	99550.7	44
203	8.4	54.7	210	217.0	218.6	-0.3	13.0	9.2	7.8	12.0	99550.7	44
204	8.9	54.1	1999	217.0	218.5	0.2	13.1	8.8	6.6	12.0	99550.7	44
205	9.6	55.0	2327	217.0	218.6	0.5	13.2	10.6	11.3	12.0	99550.7	44
206	11.8	54.6	2917	217.0	218.6	3.9	13.8	11.9	10.8	12.0	99550.9	44
207	11.3	54.5	2930	217.0	218.6	6.7	13.9	11.4	9.7	12.0	99551.0	44
208	10.9	53.3	2272	217.0	218.5	5.4	13.1	11.0	8.1	12.0	99551.8	44
209	12.4	53.8	2784	217.0	218.6	5.4	13.2	12.6	8.1	12.0	99551.2	44
210	13.5	54.8	2959	217.0	218.5	9.2	14.0	13.7	7.5	12.0	99551.0	44
211	13.9	54.4	2871	217.0	218.5	10.0	13.6	14.0	7.2	12.0	99550.8	44
212	13.9	54.3	2809	217.0	220.0	10.3	13.6	14.0	8.3	12.0	99551.0	45
213	12.9	53.0	2748	217.0	221.3	9.7	13.0	13.1	8.6	12.0	99551.3	45
214	13.4	54.2	2828	217.0	221.2	11.0	13.4	13.5	8.8	12.0	99551.8	45
215	13.0	53.8	2785	217.0	221.3	11.2	13.3	13.2	10.1	12.0	99551.4	45
216	13.9	53.6	2794	217.0	221.3	11.8	13.0	14.0	9.4	12.0	99550.9	45
217	13.0	53.2	2768	217.0	221.3	11.3	13.1	13.1	9.0	12.0	99550.9	45
218	13.9	53.4	2768	217.0	221.3	11.5	13.2	14.0	9.1	12.0	99548.3	45
219	13.7	54.1	2742	217.0	221.3	11.4	13.1	13.8	9.5	12.0	99548.6	45
220	13.2	52.2	2650	217.0	221.3	9.3	12.6	13.3	8.1	12.0	99549.6	45
221	12.8	52.2	2851	217.0	221.2	7.5	12.6	13.0	10.2	12.0	99549.3	45
222	11.7	53.2	2767	217.0	221.2	5.7	12.6	11.9	11.3	12.0	99549.3	45
223	12.2	53.6	2785	217.0	221.2	6.6	13.2	12.3	9.5	12.0	99549.1	44
224	12.7	53.2	2788	217.0	221.2	6.9	13.2	12.9	9.5	12.1	99536.1	44
225	14.7	54.1	2864	217.0	221.2	8.6	13.6	14.9	10.1	12.1	99535.3	44
226	13.4	53.6	2700	217.0	221.2	9.9	13.6	13.6	9.9	12.1	99532.2	44
227	12.9	53.2	2770	217.0	221.3	9.4	13.1	13.0	8.3	12.1	99536.6	44
228	13.5	53.4	2824	217.0	221.2	10.4	13.4	13.6	6.7	12.1	99539.9	44
229	13.9	53.4	2757	217.0	221.3	10.1	13.1	14.0	6.9	12.1	99536.4	45
230	13.4	53.6	2724	217.0	221.2	9.9	13.0	13.5	8.1	12.1	99536.4	45
231	14.2	52.5	2707	217.0	221.3	7.0	13.4	14.4	8.7	12.1	99536.5	45
232	9.9	53.7	2508	217.0	222.8	6.2	12.9	14.3	8.3	12.1	99536.5	45
233	10.1	53.2	2560	217.0	224.0	4.6	12.7	11.4	9.3	12.1	99531.1	45
234	11.2	53.1	2686	217.0	224.0	3.7	12.9	11.3	10.2	12.1	99536.5	45
235	12.3	54.4	2672	217.0	224.0	5.8	12.9	12.4	10.1	12.1	99536.5	45
236	13.7	54.4	2587	217.0	224.0	4.2	12.9	9.7	9.0	12.2	99536.5	45
237	10.8	53.8	2666	217.0	224.0	3.0	12.9	10.9	10.4	12.2	99536.0	44
238	11.7	53.3	2833	217.0	224.0	5.0	13.4	11.8	10.9	12.2	99536.6	44
239	13.0	54.2	2818	217.0	223.7	5.7	13.3	13.1	9.7	12.2	99536.4	44
240	10.9	53.4	2740	217.0	223.7	4.4	13.1	11.0	9.5	12.2	99536.4	44
241	10.8	53.2	2648	217.0	221.6	2.8	12.8	11.0	10.9	12.2	99525.5	44
242	9.9	53.5	2484	217.0	221.5	1.3	12.9	10.9	10.9	12.3	99522.5	44
243	12.2	54.1	2731	217.0	219.9	2.7	13.3	9.9	9.7	12.3	99522.9	44
244	12.0	54.7	2851	217.0	219.1	6.1	13.7	13.2	8.4	12.2	99522.9	44
245	12.0	53.9	2853	217.0	219.2	7.1	13.5	12.2	9.5	12.3	99528.8	44
246	11.9	53.6	2780	217.0	219.2	6.9	13.2	12.0	9.1	12.3	99528.8	44
247	12.8	53.2	2782	217.0	219.2	6.8	13.2	12.9	9.5	12.2	99522.1	44
248	11.4	53.2	2728	217.0	219.1	6.0	12.9	11.6	9.7	12.2	99522.3	44
249	11.3	52.6	2745	217.0	219.1	3.5	12.7	11.5	9.4	12.2	99522.1	44
250	9.4	53.4	2251	217.0	219.1	1.6	12.7	10.5	11.2	12.2	99522.7	44
251	12.2	54.1	2703	217.0	219.1	3.1	13.3	12.4	9.1	12.2	99522.4	44
252	13.0	55.1	2977	217.0	219.2	7.4	14.1	13.1	8.2	12.2	99520.7	44
253	13.1	53.8	2906	217.0	219.2	8.7	13.7	13.2	8.4	12.2	99521.1	44
254	12.1	53.5	2855	217.0	219.2	9.2	13.5	12.2	7.5	12.2	99519.9	44
255	14.2	53.5	2850	217.0	219.1	10.3	13.5	14.4	8.8	12.2	99518.1	44
256	13.7	52.9	2749	217.0	219.2	9.6	13.0	13.9	8.7	12.2	99522.1	44
257	13.1	53.6	2747	217.0	219.2	9.2	13.0	13.3	9.4	12.2	99522.0	44
258	10.9	52.6	2745	217.0	219.1	4.8	12.7	10.7	9.0	12.2	99522.0	44
259	11.8	53.0	2750	217.0	219.1	4.9	13.0	11.9	7.3	12.2	99509.8	44
260	11.1	53.0	2755	217.0	219.1	4.4	13.0	11.2	7.4	12.2	99509.7	44
261	11.2	53.5	2858	217.0	221.8	6.2	13.5	11.4	6.7	12.2	99509.5	44
262	12.5	53.7	2820	217.0	220.3	7.1	13.3	12.7				

Table E.01 Measurement data - Turbine ON

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
Report ID: 17095.01.T53.RP1

Page 3 of 4

Created on: 11/13/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	L _{Aeq} (dB)	Turbine Power Output (kW)	Reference Yaw Angle (deg)	Yaw Angle (deg)	Wind Speed (m/s)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
353	14.4	54.0	2870	217.0	215.5	8.1	13.6	14.6	12.5	99446.3	44	
354	11.9	53.6	2746	217.0	217.0	7.2	13.1	12.1	8.4	99445.0	44	
355	12.8	53.2	2750	217.0	218.2	6.1	13.0	12.0	10.2	99445.2	44	
357	11.9	52.7	2758	217.0	218.2	6.0	13.0	11.4	10.7	99445.5	44	
358	12.6	53.4	2765	217.0	218.2	5.9	13.1	12.7	9.8	99445.0	44	
359			1663	217.0	220.4	15.3	10.5	11.2	11.4	99431.2	44	
360	9.7	54.0	2388	217.0	224.6	1.1	13.1	9.2	9.2	99482.0	57	
361	9.8	54.2	2402	217.0	224.6	-0.7	13.1	9.8	6.8	99482.0	57	
362	9.7	54.7	2407	217.0	224.6	0.1	13.1	9.8	6.6	99487.9	57	
363			2625	217.0	224.6	0.1	13.1	9.4	6.8	99488.1	57	
364			2750	217.0	224.6	-0.1	13.1	10.4	6.5	99489.7	57	
365			2764	217.0	224.6	-0.1	13.1	9.9	7.0	99489.7	57	
366			2764	217.0	224.6	-0.6	13.0	9.5	6.4	99479.7	57	
367			2670	217.0	224.6	-0.3	13.0	9.7	5.9	99477.7	57	
368	10.9	54.5	2707	217.0	224.6	-0.8	13.0	11.0	5.6	99477.7	57	
369	9.6	54.7	2620	217.0	224.3	-0.8	13.0	10.9	6.0	99452.0	57	
370	9.6	54.1	2717	217.0	224.3	-0.7	13.0	11.0	5.6	99452.0	57	
371	8.8	53.9	1965	217.0	224.3	-1.1	13.0	9.6	5.8	99461.8	57	
372	9.1	54.6	2099	217.0	224.3	-1.1	13.1	9.0	6.7	99461.4	57	
373	9.0	54.4	2045	217.0	224.3	-1.1	13.1	8.4	6.8	99461.6	57	
374	9.1	54.5	2098	217.0	224.3	-1.1	13.1	9.6	7.1	99461.6	57	
375	9.3	53.9	2115	217.0	224.3	-1.0	13.0	9.9	7.4	99461.7	57	
376	9.7	54.1	2394	217.0	224.3	-0.3	13.2	9.0	7.7	99461.8	57	
377	9.9	54.7	2484	217.0	224.3	-0.2	13.1	10.3	7.5	99461.5	57	
378	9.6	54.3	2327	217.0	224.3	-0.8	13.0	9.5	7.9	99459.0	57	
379	9.4	54.3	2202	217.0	224.3	-1.0	13.1	9.3	6.4	99459.0	57	
380	9.6	54.4	2335	217.0	224.3	-0.7	13.2	10.3	6.9	99474.7	56	
381	9.9	54.2	2482	217.0	224.3	-0.2	13.1	10.1	6.4	99479.7	56	
382	10.0	55.0	2537	217.0	224.3	-0.6	13.0	9.5	6.5	99479.7	56	
383	10.0	54.0	2193	217.0	224.3	-0.1	13.0	9.5	6.5	99479.7	56	
384	9.8	56.0	2414	217.0	221.0	-0.9	13.0	9.3	6.2	99479.2	56	
385	9.2	55.0	2147	217.0	219.9	-1.0	13.0	9.7	5.9	99478.7	57	
386	9.5	54.3	2294	217.0	219.8	-0.1	13.1	9.3	6.6	99478.7	57	
387	9.6	54.3	2357	217.0	219.9	-0.4	13.1	9.2	7.0	99478.7	57	
388	9.5	54.5	2305	217.0	219.9	-0.3	13.0	10.4	6.4	99497.7	57	
389	9.0	53.9	2076	217.0	219.9	-1.1	13.0	10.0	5.7	99477.7	57	
390	9.1	54.3	2102	217.0	219.9	-1.1	13.1	9.5	6.7	99474.7	57	
391	9.5	54.3	2308	217.0	219.9	-0.7	13.2	8.6	6.0	99472.7	57	
392	9.4	54.6	2253	217.0	219.9	-1.0	13.1	9.3	5.6	99474.7	57	
393	9.5	54.6	2195	217.0	219.9	-1.2	13.0	8.7	5.6	99474.7	57	
394	9.0	55.0	2052	217.0	219.9	-0.8	13.2	8.5	6.3	99478.7	57	
395	9.2	54.6	2149	217.0	219.9	-1.0	13.2	9.7	5.9	99476.7	57	
396	9.2	53.9	2150	217.0	219.9	-1.0	13.1	9.6	7.1	99480.0	57	
397	8.8	54.6	2152	217.0	219.9	-1.1	13.1	8.7	6.5	99487.7	56	
398	9.1	54.9	2156	217.0	219.9	-0.9	13.2	8.6	6.4	99487.7	56	
399	8.7	54.3	1884	217.0	219.9	-1.2	13.0	8.2	7.0	99478.7	56	
400	8.7	54.3	1867	217.0	219.9	-1.2	13.2	8.5	5.8	99475.7	56	
401	8.9	54.4	2008	217.0	219.9	-1.1	13.2	9.2	6.5	99476.7	56	
402	9.1	55.6	2111	217.0	219.9	-1.0	13.2	9.3	6.6	99476.7	56	
403	9.4	55.2	2250	217.0	219.9	-0.9	13.2	9.8	6.7	99470.7	56	
404	9.1	54.1	2090	217.0	219.9	-1.1	13.1	9.1	6.2	99472.7	56	
405	8.8	53.9	1915	217.0	219.9	-1.1	13.1	9.4	4.7	99475.7	56	
406	9.2	54.0	2131	217.0	219.9	-1.1	13.2	9.2	5.6	99475.7	56	
407	9.1	54.1	2070	217.0	219.9	-1.1	13.1	8.7	6.1	99481.5	56	
408	8.8	54.1	1969	217.0	219.9	-1.1	13.1	8.5	6.6	99478.7	56	
409	8.6	54.1	1817	217.0	219.9	-1.2	13.1	9.0	5.6	99478.7	56	
410	8.8	54.3	1957	217.0	219.9	-1.1	13.2	8.5	6.4	99475.7	56	
411	9.1	54.1	2107	217.0	219.9	-0.9	13.2	8.7	6.4	99473.7	56	
412	9.1	53.8	2116	217.0	219.9	-1.0	13.1	8.6	5.8	99472.7	56	
413	9.6	54.2	2322	217.0	219.9	-0.3	13.2	9.7	6.3	99451.5	56	
414	9.9	54.1	2462	217.0	219.9	-0.2	13.1	9.5	5.7	99346.5	56	
415	9.8	53.9	2419	217.0	219.9	-0.8	13.0	9.9	5.7	99345.5	56	
416	9.1	53.8	2191	217.0	219.9	-1.1	13.1	9.4	5.5	99345.5	56	
417	9.1	54.1	2085	217.0	219.9	-1.0	13.1	8.3	7.1	99340.5	56	
418	9.1	54.7	2110	217.0	219.9	-1.0	13.1	9.4	6.7	99344.4	56	
419	9.2	55.8	2145	217.0	219.9	-1.1	13.1	10.0	6.4	99347.5	56	
420	8.9	53.9	2059	217.0	219.9	-1.0	13.2	8.4	5.7	99348.5	56	
421	8.9	54.1	2023	217.0	219.9	-1.1	13.1	8.4	6.5	99342.5	56	
422	9.2	54.6	2144	217.0	219.9	-0.9	13.2	9.7	6.0	99343.5	56	
423	9.1	54.3	2104	217.0	219.9	-1.1	13.1	8.5	6.0	99342.4	56	
424	9.2	54.5	2144	217.0	219.9	-1.1	13.1	9.4	5.5	99342.4	56	
425	9.6	55.6	2109	217.0	219.9	-0.5	13.2	8.4	4.9	99346.5	56	
426	8.8	53.8	1916	217.0	219.9	-1.2	13.0	8.7	4.9	99330.5	57	
427	8.4	53.8	1698	217.0	219.9	-1.4	13.0	7.7	6.2	99335.0	57	
428	8.4	54.0	1693	217.0	219.6	-1.4	13.1	7.8	7.7	99345.5	57	
429	8.6	54.3	1919	217.0	219.7	-1.0	13.2	8.8	8.1	99345.5	57	
430	9.0	54.2	2061	217.0	217.8	-1.0	13.2	8.9	8.0	99345.5	57	
431	9.0	53.9	2075	217.0	217.8	-1.1	13.1	9.2	7.4	99341.5	56	
432	8.9	54.3	1979	217.0	217.8	-0.9	13.1	7.9	6.3	99345.5	55	
433			2092	217.0	217.8	-0.9	13.2	8.2	5.9	99343.5	55	
434			2102	217.0	217.8	-0.9	13.2	8.4	5.5	99343.5	55	
435	9.0	54.0	2044	217.0	217.8	-1.1	13.0	10.0	5.4	99340.5	55	
436	8.8	54.1	1938	217.0	217.8	-1.1	13.1	8.5	6.2	99341.5	55	
437	9.2	54.5	2161	217.0	217.8	-0.7	13.2	10.7	5.6	99345.5	55	
438	9.5	55.5	2278	217.0	217.8	-0.3	13.1	8.5	5.1	99346.5	55	
439	9.4	54.1	2263	217.0	217.8	-0.8	13.1	8.9	5.6	99342.5	55	
440	8.9	54.8	1690	217.0	217.8	-1.1	13.1	8.0	5.5	99345.5	55	

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	L _{Aeq} (dB)	Turbine Power Output (kW)	Reference Yaw Angle
--------------	-------------------------	--------------------------	------------------------------	---------------------

Table E.01 Measurement data - Turbine ON

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
Report ID: 17095.01.T53.RP1

Page 4 of 4

Created on: 11/13/2018

**Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	L _{Aeq}	Turbine Power Output (kW)	Reference Yaw Angle	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)
529	6.5	49.1	798	217.0	212.4	-1.5	10.5	7.6	8.2	9.9	99909.1	55
530	6.2	49.4	704	217.0	212.4	-1.5	10.1	6.0	7.9	9.9	99908.8	55
531	6.1	48.4	668	217.0	212.4	-1.5	10.0	6.5	7.2	9.9	99909.5	54
532	6.3	48.4	703	217.0	212.5	-1.5	10.4	6.4	6.2	9.9	99909.5	54
533	7.2	51.3	1092	217.0	212.5	-1.5	11.8	8.1	5.7	9.9	99909.4	54
534	7.6	52.6	1293	217.0	212.4	-2.1	12.4	7.3	5.4	9.9	99909.4	54
535	7.6	52.8	1293	217.0	212.4	-2.1	12.4	7.5	5.0	9.9	99908.6	54
536	7.7	53.3	1341	217.0	212.4	-2.1	12.6	7.8	4.8	9.9	99909.5	54
537	7.9	53.5	1166	217.0	212.4	-2.1	12.5	8.5	4.7	9.9	99909.5	54
538	7.8	53.3	1404	217.0	212.4	-2.1	12.8	7.9	5.5	10.0	99909.4	55
539	7.8	53.3	1377	217.0	212.4	-2.1	12.7	7.4	5.2	10.0	99909.4	55
540	7.6	53.8	1272	217.0	212.4	-1.6	12.3	6.9	6.7	10.0	99909.0	55
541	7.4	52.3	1671	217.0	212.4	-1.6	12.3	6.5	6.0	10.0	99909.0	55
542	7.5	53.8	1254	217.0	212.4	-1.5	12.3	7.6	4.9	10.0	99909.6	55
543	8.5	54.1	1750	217.0	212.4	0.6	13.2	9.5	4.9	10.0	99909.6	55
544	8.6	53.4	1804	217.0	212.5	0.8	13.1	9.9	6.3	10.0	99908.8	56
545	8.3	54.4	1848	217.0	212.5	-0.7	13.0	8.1	6.7	10.0	99908.6	56
546	7.8	53.4	1456	217.0	212.5	-1.7	12.7	7.6	5.8	10.0	99908.6	56
547	7.4	52.1	1196	217.0	214.4	-1.8	12.1	7.8	5.4	10.0	99908.4	56
548	7.3	52.1	1139	217.0	215.2	-1.8	11.8	7.4	4.8	10.0	99908.3	56
549	7.4	52.3	1201	217.0	215.1	-1.8	12.1	7.6	6.0	10.0	99908.7	55
550	8.3	53.8	1671	217.0	215.1	-0.4	13.2	7.5	5.2	10.1	99908.1	55
551	9.0	54.0	2026	217.0	215.1	-0.9	13.2	9.1	6.4	10.1	99908.5	55
552	9.4	54.1	2235	217.0	215.1	0.0	13.2	10.0	6.6	10.1	99908.2	55
553	9.6	54.4	2327	217.0	215.2	-0.2	13.1	9.9	6.4	10.1	99907.7	55
554	10.0	54.3	2516	217.0	215.2	-0.2	13.1	9.9	5.5	10.1	99907.6	55
555	10.6	55.3	2633	217.0	215.1	-0.1	13.1	10.7	4.7	10.1	99907.6	54
556	9.9	54.0	2612	217.0	215.1	-0.8	13.0	10.5	4.6	10.2	99907.8	54
557	9.9	54.0	2587	217.0	215.2	-0.8	13.0	10.0	4.7	10.2	99907.8	54
558	9.9	54.0	2471	217.0	215.2	-0.9	13.0	10.5	5.6	10.2	99907.9	54
559	9.1	54.5	2108	217.0	215.2	-1.1	13.0	9.4	5.7	10.2	99910.0	54
560	9.2	54.5	2150	217.0	215.2	-0.9	13.2	8.8	4.2	10.2	99910.0	54
561	8.3	54.8	1657	217.0	215.2	-1.4	12.9	8.7	6.4	10.3	99921.7	55
562	8.3	54.2	1633	217.0	215.2	-1.5	13.1	8.7	6.0	10.3	99921.4	55
563	9.1	54.2	2092	217.0	215.2	-0.3	13.3	8.9	6.6	10.3	99921.3	55
564	9.0	53.5	2055	217.0	215.2	-0.3	13.0	9.0	7.0	10.3	99921.6	55
565	8.5	54.7	1768	217.0	215.2	-1.3	13.0	8.2	7.7	10.3	99921.6	55
566	9.7	53.6	1440	217.0	215.1	-1.7	12.9	7.3	7.0	10.3	99921.9	55
567	8.2	53.5	1326	217.0	215.1	-1.8	12.5	7.5	6.3	10.4	99921.6	54
568	7.6	52.5	1263	217.0	215.1	-1.8	12.3	7.5	6.2	10.4	99921.4	54
569	7.8	53.4	1210	217.0	215.1	-1.0	12.3	8.0	5.7	10.4	99917.7	54
570	7.8	53.2	1384	217.0	215.1	-1.8	12.7	8.0	6.0	10.4	99921.9	54
571	7.5	51.9	1225	217.0	215.1	-1.8	12.2	8.4	7.4	10.4	99921.9	54
572	7.8	53.5	1397	217.0	215.1	-1.6	12.8	8.7	7.5	10.4	99922.0	54
573	8.2	54.3	1970	217.0	215.1	-1.5	13.1	8.6	6.4	10.4	99921.4	54
574	7.9	53.8	1441	217.0	215.1	-1.7	12.9	8.9	6.7	10.4	99921.7	54
575	8.1	54.0	1565	217.0	215.0	-1.6	13.1	8.4	6.9	10.4	99921.7	54
576	8.0	54.0	1472	217.0	212.3	-1.7	12.9	6.8	7.4	10.4	99922.0	54
577	7.7	53.2	1345	217.0	211.9	-1.8	12.6	8.7	7.3	10.4	99921.5	54
578	8.4	54.1	1577	217.0	212.0	-1.4	13.1	10.3	7.2	10.4	99921.4	54
579	9.7	53.6	2397	217.0	212.0	1.4	13.2	9.7	7.5	10.4	99921.4	54
580	9.8	54.0	2447	217.0	212.0	1.1	13.1	8.9	6.7	10.4	99920.9	54
581	9.9	54.0	2611	217.0	212.0	0.9	13.1	9.6	6.2	10.4	99921.4	54
582	9.9	54.0	2342	217.0	212.0	-0.1	13.0	11.0	6.2	10.4	99921.4	54
583	9.9	54.0	2133	217.0	212.0	-0.6	13.1	10.8	6.3	10.4	99921.2	54
584	9.9	54.0	2525	217.0	212.0	-0.5	13.1	9.5	6.7	10.4	99921.5	54
585	9.9	54.0	2644	217.0	212.0	-0.6	13.1	9.9	7.1	10.4	99921.6	53
586	9.9	54.0	1943	217.0	212.0	-1.1	12.9	9.3	6.8	10.4	99921.7	53
587	9.9	54.0	2172	217.0	211.9	-1.8	13.0	8.0	6.2	10.4	99921.7	53
588	1.522	217.0	2094	217.0	211.7	-0.9	13.1	8.3	5.9	10.4	99921.7	53
589	1.643	217.0	2092	217.0	212.5	-1.0	13.1	10.4	6.9	10.4	99921.0	53
590	1.610	217.0	2092	217.0	212.0	-1.5	13.1	7.9	7.7	10.4	99919.3	53
591	1.618	217.0	2092	217.0	212.0	-1.5	13.1	7.9	6.6	10.5	99909.7	53
592	1.617	217.0	2092	217.0	212.0	-0.7	13.2	9.7	7.7	10.5	99909.7	53
593	2.301	217.0	210.3	217.0	213.2	0.6	11.9	6.9	10.5	99909.7	53	
594	2.376	217.0	211.7	217.0	211.7	0.2	13.1	11.0	5.3	10.5	99909.8	53
595	2.633	217.0	211.7	217.0	211.7	0.2	13.1	10.6	6.3	10.5	99909.5	53
596	2.065	217.0	211.7	217.0	211.7	-0.1	13.0	10.9	5.5	10.5	99909.5	53
597	2.183	217.0	211.7	217.0	211.7	-0.9	13.1	11.0	6.4	10.5	99921.7	53
598	2.341	217.0	211.7	211.7	211.7	-0.1	13.1	10.7	6.1	10.5	99922.0	53
599	2.094	217.0	212.5	217.0	214.0	0.1	13.2	9.8	6.6	10.5	99922.4	53
600	2.412	217.0	212.5	217.0	214.0	0.1	13.2	9.8	6.6	10.5	99922.4	53
601	2.109	217.0	214.0	217.0	214.0	-0.4	13.1	9.7	5.9	10.5	99909.1	53
602	2.395	217.0	214.0	217.0	214.0	-1.0	13.1	9.6	5.9	10.5	99909.4	53
603	2.193	217.0	214.0	217.0	214.0	-1.0	13.1	9.2	7.3	10.5	99909.4	53
604	1.996	217.0	214.0	214.0	214.0	-1.1	13.0	9.3	6.8	10.5	99909.6	53
605	2.065	217.0	214.0	214.0	214.0	-1.2	13.1	9.7	6.8	10.5	99909.9	53
606	2.111	217.0	214.0	214.0	214.0	-0.3	13.2	10.7	6.8	10.5	99910.2	53
607	2.108	217.0	214.0	214.0	214.0	-0.3	13.1	9.6	6.8	10.5	99909.5	53
608	2.112	217.0	214.0	214.0	214.0	-0.3	13.1	10.4	7.8	10.5	99910.3	53
609	2.226	217.0	214.0	214.0	214.0	-0.5	13.1	9.9	8.1	10.5	99909.3	53
610	2.335	217.0	214.0	214.0	214.0	-0.4	13.1	10.4	8.5	10.5	99909.3	53
611	2.424	217.0	214.0	214.0	214.0	-0.6	13.1	10.3	8.1	10.5	99909.9	53

Table E.02 Measurement data - Background

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
Report ID: 17095.01.T53.RP1

Page 1 of 2

Created on: 11/13/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)	
1	6.3	46.0	0.4	5.1	11	99815.9	52
2	8.2	46.3	0.3	6.5	11	99814.9	52
3	7.0	45.9	0.4	5.6	11	99814.3	52
4	9.2	45.4	0.3	7.4	11	99815.5	52
5	7.6	44.1	0.5	6.1	11	99804.9	51
6	10.1	42.9	0.4	6.0	11	99804.9	51
7	9.7	43.0	0.4	7.7	11	99803.3	51
8	8.7	43.3	0.5	6.9	11	99803.5	51
9	8.9	41.5	0.4	7.1	11	99803.3	51
10	8.6	41.9	0.4	6.9	11	99803.5	51
11	8.2	44.4	0.5	6.6	11	99802.5	51
12	9.4	42.4	0.3	7.5	11	99803.0	51
13	8.0	40.9	0.3	6.4	11	99803.0	51
14	12.8	42.1	0.4	10.2	11	99802.9	51
15	13.2	40.7	0.4	10.5	11	99803.1	51
16	11.8	40.5	0.3	9.4	11	99803.6	51
17	11.7	41.1	0.4	9.4	11	99803.3	50
18	10.2	41.9	0.5	8.2	11	99802.6	49
19	10.4	43.4	0.4	8.3	11	99803.8	49
20	10.6	41.9	0.4	8.4	11	99803.0	49
21	10.2	43.6	0.3	8.2	11	99801.8	49
22	12.3	43.1	0.3	9.8	11	99803.5	49
23	12.0	42.4	0.4	9.5	11	99803.6	49
24	7.9	42.7	0.4	6.3	11	99803.9	50
25	12.1	40.3	0.4	9.7	11	99804.9	50
26	14.1	41.7	0.4	11.3	11	99804.5	50
27	9.29	40.4	0.3	10.3	11	99804.6	50
28	11.4	42.5	0.3	9.1	11	99804.7	50
29	11.1	42.3	0.3	8.5	11	99804.8	50
30	11.6	41.2	0.4	9.3	11	99804.1	50
31	10.7	40.3	0.4	8.5	11	99804.5	50
32	10.8	40.0	0.4	8.6	11	99804.2	50
33	11.0	40.3	0.2	8.8	11	99804.1	50
34	10.9	42.6	0.4	8.7	11	99803.2	50
35	6.5	41.2	0.4	7.5	11	99803.0	50
36	6.9	41.2	0.5	7.9	11	99804.3	50
37	9.2	41.0	0.4	7.4	11	99804.3	50
38	9.6	42.1	0.4	7.7	11	99804.3	50
39	10.9	41.3	0.7	8.7	11	99804.3	50
40	10.7	41.1	0.7	8.5	11	99803.0	50
41	9.2	41.9	0.4	7.5	11	99803.0	50
42	8.7	42.0	0.4	6.9	11	99808.6	50
43	8.1	47.2	0.5	6.5	11	99788.8	50
44	8.3	46.3	0.6	6.6	11	99790.6	50
45	7.6	44.0	0.4	6.1	11	99790.7	50
46	6.8	42.6	0.5	5.4	11	99791.2	50
47	7.3	41.1	0.6	5.5	11	99791.5	51
48	10.1	41.0	0.4	8.0	11	99791.1	51
49	10.1	41.4	0.4	8.1	11	99791.7	51
50	9.9	42.9	0.4	7.9	11	99791.3	51
51	8.0	42.1	0.5	6.4	11	99791.2	51
52	8.2	40.5	0.4	6.5	11	99791.6	51
53	10.4	41.5	0.4	8.3	11	99803.3	51
54	9.5	41.0	0.6	7.6	11	99802.5	51
55	8.0	41.2	0.4	6.3	11	99802.7	51
56	6.6	40.8	0.4	5.3	11	99803.7	51
57	8.6	41.3	0.4	6.8	11	99803.9	51
58	9.8	42.6	0.5	7.5	11	99803.9	51
59	9.7	42.4	0.5	7.7	11	99802.7	51
60	9.0	43.5	0.3	7.2	11	99802.6	51
61	8.5	41.4	0.3	6.8	11	99802.6	51
62	9.3	40.7	0.3	7.4	11	99802.7	51
63	9.0	41.9	0.4	7.2	11	99802.9	51
64	8.6	42.9	0.4	6.9	11	99802.1	51
65	8.5	42.2	0.3	6.7	11	99815.6	51
66	9.7	41.6	0.3	7.8	11	99815.7	51
67	10.3	41.0	0.3	8.2	11	99816.1	51
68	11.5	41.1	0.3	9.2	11	99815.9	51
69	11.5	40.5	0.5	9.2	11	99814.6	51
70	11.7	40.6	0.5	9.5	11	99814.6	51
71	10.6	40.3	0.4	8.4	11	99801.3	51
72	8.1	40.3	0.4	6.5	11	99801.8	51
73	6.2	40.6	0.3	5.0	11	99802.1	51
74	6.9	40.0	0.3	5.5	11	99802.0	51
75	8.2	39.7	0.4	6.5	11	99801.5	51
76	9.5	40.5	0.5	7.6	11	99802.7	51
77	10.7	39.9	0.4	8.5	11	99803.6	51
78	9.5	40.8	0.4	7.6	11	99803.7	51
79	9.9	41.0	0.4	7.9	11	99802.6	51
80	11.5	41.1	0.4	9.2	11	99801.4	51
81	12.7	42.4	0.4	10.2	11	99801.1	51
82	10.6	42.7	0.5	8.4	11	99801.0	51
83	10.4	42.3	0.5	8.3	11	99801.9	50

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (hPa)	Relative Humidity (%)	
84	11.0	42.5	0.5	8.8	11	99801.9	50
85	11.3	40.5	0.4	9.0	11	99801.9	50
86	9.6	42.6	0.5	7.7	11	99802.0	50
87	10.0	41.6	0.6	8.0	11	99802.1	50
88	10.2	41.1	0.4	8.1	11	99795.0	50
89	10.6	42.4	0.4	8.9	11	99795.0	51
90	12.3	39.8	0.3	9.8	11	99788.1	51
91	11.2	40.4	0.4	9.0	11	99788.1	51
92	11.4	40.7	0.3	9.1	11	99787.4	51
93	10.3	40.7	0.2	8.2	11	99787.9	51
94	11.9	40.3	0.3	9.5	11	99789.5	50
95	10.5	40.7	0.2	9.0	11	99789.5	50
96	9.6	41.2	0.2	7.6	11	99789.8	50
97	9.7	42.2	0.2	7.8	11	99789.7	50
98	10.3	40.8	0.2	8.2	11	99789.8	50
99	11.4	39.5	0.2	9.1	11	99789.8	50
100	11.0	40.1	0.3	8.7	11	99789.4	50
101	10.2	40.5	0.2	8.2	11	99778.8	51
102	10.0	41.5	0.2	7.9	11	99776.9	51
103	9.9	39.7	0.3	7.9	11	99776.9	51
104	9.9	40.1	0.3	7.9	11	99777.3	51
105	9.2	42.6	0.3	7.4	11	99746.6	50
106	9.7	43.1	0.5	8.5	11	99746.1	50
107	9.6	42.9	0.4	7.7	11	99746.5	50
108	10.2	42.7	0.5	8.1	11	99746.6	50
109	10.2	41.4	0.3	8.1	11	99747.4	50
110	10.4	42.2	0.3	8.3	11	99747.3	50
111	9.8	41.9	0.4	7.8	11	99746.8	50
112	10.8	42.6	0.4	8.6	11	99746.4	50
113	10.9	41.6	0.4	8.7	11	99746.2	50
114	9.0	42.3	0.5	7.2	11	99747.0	50
115	8.6	42.8	0.3	6.9	11	99747.7	50
116	10.3	43.7	0.3	8.2	11	99743.6	50
117	9.4	43.9	0.4	7.5	11	99734.2	50
118	9.1	43.4	0.3	8.0	11	99734.0	50
119	9.1	43.4	0.3	8.0	11	99734.0	50
120	9.3	45.4	0.2	7.4	11	99734.3	50
121	8.6	41.0	0.4	6.7	11	99734.0	50
122	12.9	42.5	0.5	7.4	11	99733.9	50
123	11.7	41.6	0.3	9.3	11	99733.9	50
124	12.0	41.9	0.4	9.6	11	99733.9	50
125	8.1	41.1	0.4	6.5	11	99734.0	50
126	7.2	40.5	0.5	5.8	11	99733.8	50
127	8.4	41.1	0.4	6.4	11	99734.8	50
128	8.4	41.0	0.4	6.7	11	99734.0	50
129	9.3	42.5	0.5	7.4	11	99733.9	50
130	11.7	41.6	0.3	9.3	11	99733.9	50
131	12.0	41.9	0.4	9.6	11	99733.8	50
132	11.6	41.3	0.4	9.2	11	99733.5	50
133	13.7	42.0	0.5	10.6	11	99706.3	47
134	9.7	45.5	0.4	11.1	11	99707.1	47
135	10.5	40.5	0.3	8.5	12	99706.2	45
136	12.1	40.9	0.4	9.7	11	99706.6	47
137	14.3	44.2	0.2	11.4	11	99719.9	47
138	13.1	43.6	0.2	10.4	11	99720.7	47
139	12.7	42.9	0.4	10.1	11	99720.7	47
140	11.5	43.9	0.5	8.8	11	99715.8	47
141	9.5	42.7	0.4	8.4	11	99706.3	47
142	9.9	42.7	0.4	7.9	11	99706.8	47
143	11.0	42.7	0.5	8.8	11	99706.6	47</td

Table E.02 Measurement data - Background

Project: Belle River Wind Power Project - Turbine T53 - IEC 61400-11 Measurement
Report ID: 17095.01.T53.RP1

Page 2 of 2
Created on: 11/13/2018

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq Rotor RPM	10m Wind Speed (m/s)	Air Temperature	Pressure	Relative Humidity (%)
250	10.9	42.3	0.3	8.7	13	99379.3 44
251	11.0	43.6	0.5	8.8	13	99379.3 44
252	11.1	43.6	0.6	8.9	13	99379.2 44
253	10.8	45.0	0.6	8.6	13	99378.8 44
254			0.4	9.3	13	99378.7 44
255			0.3	10.4	13	99378.5 43
256			0.3	7.8	13	99378.5 43
257			0.4	8.6	13	99378.5 43
258			0.4	10.8	13	99378.4 43
259	13.0	44.7	0.5	10.4	13	99378.9 43
260	11.4	44.8	0.4	9.1	13	99378.7 43
261	11.0	44.0	0.5	8.5	13	99378.7 43
262	9.3	44.8	0.2	7.4	13	99377.7 43
263	7.9	44.1	0.3	6.3	13	99377.6 43
264	8.4	44.0	0.5	6.7	13	99378.0 43
265	8.1	46.2	0.5	6.5	13	99376.6 43
266	7.7	43.1	0.4	6.1	13	99376.3 43
267	6.4	43.4	0.6	5.1	13	99362.3 43
268	7.4	42.8	0.5	5.9	13	99362.3 43
269	5.7	43.7	0.5	4.5	13	99362.2 43
270	7.9	46.4	0.6	6.3	13	99362.4 43
271	10.0	46.0	0.4	8.0	13	99361.7 43
272			0.4	6.2	13	99361.3 43
273	7.5	47.2	0.5	6.0	13	99349.3 43
274	6.8	45.0	0.3	5.5	13	99349.2 43
275	7.1	43.5	0.2	5.6	13	99349.0 43
276	9.3	43.2	0.4	7.4	13	99348.6 43
277	11.6	44.1	0.4	9.3	13	99348.5 43
278	10.5	42.9	0.5	8.3	13	99348.1 43
279	8.9	44.9	0.5	7.1	13	99348.1 43
280	7.8	46.8	0.5	6.2	13	99348.5 43
281			0.6	5.9	13	99348.5 43
282			0.5	5.9	13	99347.4 43
283	7.7	47.1	0.6	6.2	13	99348.0 43
284	7.5	45.9	0.4	6.0	13	99348.1 43
285	7.3	44.2	0.5	5.9	13	99348.1 43
286	6.8	42.7	0.4	5.4	13	99348.2 43
287	7.0	43.2	0.4	5.5	13	99348.4 43
288	6.4	42.7	0.4	5.1	13	99347.9 43
289			0.4	5.9	13	99347.9 43
290	7.7	43.6	0.5	6.1	13	99347.9 44
291	10.2	42.8	0.5	8.1	13	99347.4 44
292	10.1	43.1	0.6	8.0	13	99347.0 44
293	8.9	41.3	0.5	7.1	13	99346.8 44
294	7.8	41.4	0.4	6.2	13	99347.2 44
295	9.1	41.7	0.5	7.2	13	99347.0 44
296	11.1	42.8	0.4	8.9	13	99348.5 43
297	9.6	42.0	0.4	7.7	13	99348.1 43
298	10.0	41.8	0.3	8.0	13	99348.3 43
299	8.7	41.9	0.3	6.9	13	99348.2 43
300	7.0	44.4	0.2	5.6	13	99348.5 43
301	8.2	46.5	0.3	6.5	13	99348.3 43
302			0.4	7.3	13	99360.3 44
303	8.3	46.3	0.5	6.6	13	99350.4 44
304	7.8	46.0	0.5	6.3	13	99349.9 44
305	9.2	43.9	0.5	7.4	13	99349.3 44
306	13.5	42.7	0.5	10.7	13	99347.9 44
307	13.0	42.0	0.4	10.3	13	99347.9 44
308	11.9	41.6	0.4	9.5	13	99348.2 43
309	12.3	41.9	0.5	9.8	13	99348.8 43
310	13.6	43.8	0.6	10.8	13	99348.8 43
311	12.3	44.0	0.8	9.8	13	99348.9 43
312	10.5	43.9	0.6	8.4	13	99362.2 43
313	10.4	45.5	0.5	5.3	13	99360.4 43
314			0.4	10.3	13	99362.8 43
315	11.1	45.8	0.6	8.8	13	99363.8 43
316	11.8	43.7	0.5	9.4	13	99364.4 43
317	13.3	42.8	0.5	10.6	13	99365.0 43
318	13.1	43.1	0.4	10.5	13	99365.1 43
319	13.5	42.9	0.4	10.7	13	99365.1 43
320	11.6	42.5	0.4	9.2	13	99365.0 42
321	10.1	45.4	0.5	8.1	13	99365.3 42
322	9.2	44.3	0.6	7.4	13	99365.5 42
323	12.0	43.3	0.5	9.6	13	99365.4 42
324	12.6	43.8	0.6	10.0	13	99364.9 42
325	10.9	43.0	0.5	8.7	13	99364.9 42
326	9.6	44.1	0.5	7.6	13	99365.7 42
327			0.5	8.0	13	99366.1 42
328			0.4	7.6	13	99366.0 42
329			0.5	8.9	13	99366.1 42
330			0.7	8.0	13	99364.9 42
331	10.6	45.7	0.7	8.4	13	99364.9 42
332	10.6	46.0	0.6	8.5	13	99365.4 43

***Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq Rotor RPM	10m Wind Speed (m/s)	Air Temperature	Pressure	Relative Humidity (%)
333	11.9	46.7	0.6	9.5	13	99365.9 43
334	14.5	46.7	0.5	11.5	13	99365.5 43
335	12.2	46.7	0.5	9.7	13	99365.5 43
336	11.8	46.5	0.5	9.4	13	99364.5 43
337	11.1	45.0	0.5	8.9	13	99365.3 43
338	12.3	45.3	0.4	9.8	13	99365.3 43
339	9.6	45.8	0.6	7.6	13	99365.0 43
340	13.4	42.8	0.6	10.7	13	99365.1 43
341	14.5	44.9	0.5	11.5	13	99365.7 43
342	11.7	43.8	0.5	9.3	13	99365.7 43
343	9.3	45.8	0.6	7.4	13	99366.0 43
344	10.7	45.3	0.5	9.5	13	99366.7 43
345	10.6	43.4	0.5	8.4	13	99365.4 43
346	10.9	42.3	0.5	8.7	13	99365.4 43
347	11.0	44.2	0.5	8.8	13	99365.2 43
348	10.7	43.6	0.6	8.5	13	99365.5 43
349	12.5	43.7	0.6	10.0	13	99365.0 43
350	8.9	45.6	0.5	7.1	13	99362.5 42
351	9.1	44.4	0.7	7.2	13	99352.7 42
352	11.0	44.4	0.5	8.8	13	99352.6 42
353			0.4	8.1	13	99352.6 42
354			0.5	8.8	13	99352.9 42
355			0.5	10.6	13	99346.7 42
356			0.4	9.3	13	99339.2 43
357	11.3	45.5	0.5	9.0	13	99338.6 43
358	12.1	44.9	0.5	9.7	13	99339.1 43
359	11.0	44.1	0.4	8.8	13	99339.6 43
360	11.1	43.8	0.5	8.8	13	99340.2 43
361	10.1	45.7	0.4	8.0	13	99353.5 43
362	9.5	42.4	0.5	7.6	13	99353.0 43
363	8.7	43.1	0.7	6.9	13	99352.7 43

Appendix F

Supplementary Information for the Regulator

Appendix F.01 Calibration Certificates



ISO 17025

As Left RECALIBRATION CERTIFICATE

Sales Region:	NA
Account:	Aercoustics Engineering Limited
Instrument:	LMS SCADAS
Manufacturer:	Siemens Industry Software B.V.
Type:	SCR202
Serial number(s):	22163146
Calibration method:	Two calibrated external standards (DC voltage and frequency) are used to calibrate the internal LMS SCADAS references: time/frequency accuracy of the internal system clock and amplitude accuracy of the internal signal sources. All input channels are calibrated against the internal references.
Ambient conditions:	The calibrations have been carried out in a controlled environment, at an ambient temperature of $23.3^{\circ}\text{C} \pm 0.3^{\circ}\text{C}$ and a relative humidity of $21\% \pm 5\%$.
Calibration date:	February 27, 2018
Results:	The calibration results, together with their associated uncertainties, are included in this calibration certificate. <i>Calibration results within specification.</i>
Uncertainty:	The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty of measurement has been determined in accordance with publication EA-4/02.
Traceability:	The measurements have been executed using methods for which the traceability to international standards has been demonstrated towards the Raad voor Accreditatie.

Breda, February 27, 2018

Calibration performed by:

Hans Dam, Customer Service Engineer

Certificate approved by:

F. Lemmens, Production Manager

The Raad voor Accreditatie is one of the signatories of the Multilateral Agreement of the European Cooperation for Accreditation (EA) for the mutual recognition of calibration certificates.

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.

This certificate is issued provided that neither Siemens Industry Software B.V. nor the Raad voor Accreditatie assumes any liability.

Certificate number: 22163146-20180227-1

Page: 1 of 16

West Caldwell Calibration Laboratories Inc.

Certificate of Calibration

for

MICROPHONE UNIT

Manufactured by: BRUEL & KJAER
Model No: 4189-A-021
Serial No: 2622169
Calibration Recall No: 28016

Submitted By:

Customer:

Company: Aercoustics Engineering LTD.
Address:

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. 4189-A-021 BRUE

Upon receipt for Calibration, the instrument was found to be:

Within (X)

tolerance of the indicated specification. See attached Report of Calibration.

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by: *FC*

Calibration Date: 05-Sep-17

Felix Christopher (QA Mgr.)

Certificate No: 28016 - 1

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

ISO/IEC 17025:2005

uncompromised calibration
West Caldwell
Calibration
Laboratories, Inc.
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01

**West Caldwell
Calibration
Laboratories, Inc.**
uncompromised calibration
1575 State Route 96, Victor NY 14564



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

for

Model No.: 4189-A-021

Mic. Model No.: 4189

Preamp. Model No.: 2671

Company: Aercoustics Engineering LTD.

Serial No.: 2622169
Serial No.: 2625417
Serial No.: 2614900
I. D. No.: XXXX

Calibration results:

Before & after data same: ...X...
 Combined Sensitivity @ 250 Hz and pressure of 98.432 kPa Ambient Temperature: 21.8 °C
 (Sens. with mic. and preamp.) 0 Volts Polarization voltage (External): Ambient Humidity: 56.4 % RH
 -26.54 dB re.1V/Pascal Ambient Pressure: 98.432 kPa
 47.10 mV/Pascal Calibration Date: 5-Sep-2017
 0.54 Ko (- dB re 50 mV/Pascal) Calibration Due: 5-Sep-2018
 Sensitivity: Pass Report Number: 28016 -1
 Freq. Response: Pass Control Number: 28016
 All tests: Pass

The above listed instrument meets or exceeds the tested manufacturer's specifications.


The IEC 651:1979 & 1993 Type 1 specification passed.

This Calibration is traceable through NIST test numbers: 683/284413-14

The expanded uncertainty of calibration: 0.079dB at 95% confidence level with a coverage factor of k=2.

The pressure response recorded with electroacoustic method.

Frequency Response



The above listed instrument was checked using calibration procedure documented in West Caldwell Calibration Laboratories Inc. procedure : Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189A021B&K
 Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures
 intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Measurements performed by:

James Zhu

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189A021B&K

West Caldwell Calibration Laboratories Inc.

1575 State Route 96, Victor NY 14564

Tel. (585) 586-3900 FAX (585) 586-4327

Calibration Data Record

for

Model No.: 4189-A-021

Brüel & Kjær Microphone Unit

Company: Aercoustics Engineering LTD.

Serial No.: 2622169

I. D. No.: XXXX

Frequency Response (Reference = 0 dB @ 250Hz)

Frequency [Hz]	Pressure [dB]	Free Field (dB)	Random (dB)
19.95	-0.85	-0.85	-0.85
25.12	-0.51	-0.51	-0.51
31.62	-0.28	-0.28	-0.28
39.81	-0.14	-0.14	-0.14
50.12	-0.06	-0.06	-0.06
63.10	-0.02	-0.02	-0.02
79.43	-0.01	-0.01	-0.01
100.00	0.00	0.00	0.00
125.89	0.00	0.00	0.00
158.49	0.00	0.00	0.00
199.53	0.01	0.01	0.01
251.19	0.00	0.00	0.00
316.23	0.00	0.00	0.00
398.11	-0.01	0.00	-0.01
501.19	-0.01	0.01	-0.01
630.96	-0.02	0.01	-0.02
794.33	-0.05	0.02	-0.05
1000.00	-0.09	0.01	-0.11
1258.93	-0.14	0.01	-0.17
1584.89	-0.23	-0.01	-0.29
1995.26	-0.39	-0.06	-0.39
2511.89	-0.59	-0.11	-0.55
3162.28	-0.94	-0.23	-0.91
3981.07	-1.51	-0.45	-1.42
5011.87	-2.11	-0.53	-1.97
6309.57	-3.15	-0.87	-2.83
7943.28	-4.38	-1.00	-3.63
10000.00	-5.92	-0.80	-4.39
12589.25	-7.13	0.07	-4.62
15848.93	-9.80	-1.21	-7.22
19952.62	-12.02	-1.97	-9.54

Freq. response: Expanded Uncertainty (dB) with coverage factor K = 2

20 to 63Hz 0.1dB, 63 to 12.5kHz 0.094dB, 12.5k to 16kHz 0.10dB, 16k to 20kHz 0.5dB.

Instruments used for calibration:		Date of Cal.	Traceability No.	Re-cal. Due Date
Brüel & Kjær	4226	S/N 1445428	3-Nov-2016	683/284413-14
Brüel & Kjær	3560	S/N 2202374	3-Nov-2016	683/284413-14
HP	33120A	S/N 36043716	1-Oct-2016	,287708
HP	34401A	S/N 36064102	1-Oct-2016	,287708

Cal. Date: 5-Sep-2017

Tested by: James Zhu

Calibrated on WCCL system type 9700

This document shall not be reproduced except in full without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189A021B&K

West Caldwell Calibration Laboratories Inc.

Certificate of Calibration

for

ACOUSTICAL CALIBRATOR

Manufactured by: BRUEL & KJAER
Model No: 4231
Serial No: 2513182
Calibration Recall No: 29034

Submitted By:

Customer:

Company: Aercoustics Engineering Ltd.
Address:

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. 4231 BRUE

Upon receipt for Calibration, the instrument was found to be:

Within (X)

tolerance of the indicated specification. See attached Report of Calibration.

The information supplied relates to the calibrated item listed above.

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by: FC

Calibration Date: 25-Jul-18

Felix Christopher (QA Mgr.)

Certificate No: 29034 - 1

ISO/IEC 17025:2005

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

West Caldwell
Calibration
Laboratories, Inc.
uncompromised calibration
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

for

Brüel & Kjær Sound Calibrator

Model No.: 4231

Serial No.: 2513182

Company: Aeroustics Engineering LTD.

ID No.: XXXX

Calibration results:

Before data: After data:

Before & after data same: ...X.....

Sound Pressure Level at 1000.0 Hz and pressure of 1013 hPa (mbar)
was 113.99 dB re 20 μ Pa

(Calibrator tested with 1/4" adaptor UC 0210)

IEC 1094-4 Type WS 2 P Microphone was used for measurement.

Sound Pressure Level: 114dB 94dB

Frequency: Pass Pass

Distortion: Pass Pass

Stability: Pass Pass

All tested parameters: Pass

Laboratory Environment:

Ambient Temperature: 23.0 °C

Ambient Humidity: 47.0 % RH

Ambient Pressure: 98.901 kPa

Calibration Date: 25-Jul-2018

Calibration Due: 25-Jul-2019

Report Number: 29034 -1

Control Number: 29034

The above listed instrument meets or exceeds the tested manufacturer's specifications

The IEC 60942:2003 Class 1 specifications, passed.


The ANSI S1.4-1984 specifications, passed.

This Calibration is traceable through NIST test numbers: 683/284413-14


The expanded uncertainty of calibration: 0.11 dB at 95% confidence level with a coverage factor of k=2.

Graph represents six samples of Sound Pressure Level measured at 5sec. interval.

Stability @ 114dB SPL



Stability @ 94dB SPL



The above listed instrument was checked using calibration procedure documented in West Caldwell

Calibration Laboratories Inc. procedure : Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&K

Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures

intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Cal. Date: 25-Jul-2018

Measurements performed by: *MS*

Calibrated on WCCL system type 9700

Matthew Smith

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&K

West Caldwell Calibration Laboratories Inc.

1575 State Route 96, Victor NY 14564

Tel. (585) 586-3900 FAX (585) 586-4327

Calibration Data Record

for

Model No.: 4231

Serial No.: 2513182

Brüel & Kjær Sound Calibrator

Company: Aercoustics Engineering LTD.

All tested parameters: Pass

Measured Sound Pressure Level (Six samples measured at 5 sec. interval)

Sample	1	113.99 dB re 20µPa	93.98 dB re 20µPa
	2	113.99	93.97
	3	113.99	93.98
	4	113.99	93.97
	5	113.99	93.98
	6	113.99	93.98
Average		113.99 Spec. 114dB ± 0.2dB	93.98 Spec. 94dB ± 0.2dB

Frequency measured (Three samples at 30 sec. Interval)

Sample	1	999.98 Hz	999.97 Hz
	2	999.98	1000.00
	3	999.98	999.98
Average		999.98	999.98 Spec. 1000Hz ±0.1%

The Frequency expanded uncertainty of calibration:45µHz/Hz at 95% confidence level with a coverage factor of k=2.

Distortion measured	-50.8 dB	-46.5 dB	Spec. ≤-40dB
---------------------	----------	----------	--------------

Instruments used for calibration:			Date of Cal.	Traceability No.	Re-cal. Due Date
Brüel & Kjær	4231	S/N 2205493	25-Aug-2017	683/284413-14	25-Aug-2018
Brüel & Kjær	4134	S/N 1942286	25-Aug-2017	683/284413-14	25-Aug-2018
Brüel & Kjær	2669	S/N 1835082	25-Aug-2017	683/284413-14	25-Aug-2018
HP	34401A	S/N US360641	25-Aug-2017	,287708	25-Aug-2018
Brüel & Kjær	2636	S/N 1324082	25-Aug-2017	683/284413-14	25-Aug-2018
HP	33120A	S/N US360437	25-Aug-2017	,287708	25-Aug-2018

Cal. Date: 25-Jul-2018

Tested by: Matthew Smith

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&K



CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

Certificate number: 18.USI.05011

Date of issue: September 28, 2018

Type: Vaisala Weather Transmitter, WXT520

Serial number: k4250007

Manufacturer: Vaisala Oyj, Pl 26, FIN-00421 Helsinki, Finland

Client: Aeroustics Engineering Ltd., 1004 Middlegate RD, Suite 1100, S Tower, Mississauga, ON L4Y 1M4, Canada

Anemometer received: September 28, 2018

Anemometer calibrated: September 28, 2018

Calibrated by: MEL

Procedure: MEASNET IEC 61499-12-1:2017 Annex F

Certificate prepared by: EIF

Approved by Calibration engineer EIE

Calibration equation obtained: v [m/s] = 1.01370 · C [m/s] + 0.06230

Standard uncertainty, slope: 0.00263

Standard uncertainty: effect 0.14506



Covariance: 0.0000683 (m/s) 2 /m

Standard uncertainty, offset: 0.44596

Absolute maximum deviation = 0.005 / μ + 15.814 / μ^2

m/s

Barometric pressure: 1004.0 mbar		Relative humidity: 41.7%					
Succession	Velocity	Temperature in		Wind	Anemometer	Deviation,	Uncertainty
	pressure, q.	wind tunnel	d.p. box	velocity, v.	Output, f.	d.	u_c ($k=2$)
	[Pa]	[°C]	[°C]	[m/s]	[m/s]	[m/s]	[m/s]
2	9.14	26.3	26.6	3.966	3.8633	-0.012	0.020
4	14.39	26.4	26.7	4.976	4.8828	-0.036	0.023
6	20.73	26.4	26.7	5.973	5.8533	-0.023	0.026
8	28.21	26.4	26.7	6.967	6.8000	0.012	0.029
10	36.96	26.4	26.7	7.974	7.7828	0.023	0.033
12	46.92	26.3	26.7	8.985	8.8033	-0.002	0.037
13-last	57.63	26.3	26.7	9.957	9.7310	0.030	0.041
11	69.92	26.3	26.7	10.968	10.7300	0.029	0.045
9	83.41	26.3	26.7	11.980	11.7500	0.007	0.049
7	97.59	26.3	26.7	12.959	12.7000	0.023	0.053
5	113.15	26.3	26.7	13.955	13.6667	0.039	0.057
3	129.18	26.3	26.6	14.911	14.6500	-0.002	0.061
1-first	147.16	26.3	26.6	15.914	15.7214	-0.085	0.065



EQUIPMENT USED

Serial Number	Description
Njord1	Wind tunnel, blockage factor = 1.0035
2254	Control cup anemometer
-	Mounting tube, D = 19 mm
TT002	Summit Electronics, 1XPT100, 0-10V Output, wind tunnel temp.
TP001	PR Electronics 5102, 0-10V Output, differential pressure box temp.
DP005	Setra Model 239, 0-1inWC, differential pressure transducer
HY003	Dwyer RHP-2D20, 0-10V Output, humidity transmitter
BP003	Setra M278, 0-5VDC Output, barometer
PL8	Pitot tube
XB002	Computer Board. 16 bit A/D data acquisition board
9PRZRW1	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Atlantic Scale, Esco Calibration Labs & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.




Photo of the wind tunnel setup. The cross-sectional area is 2.5m x 2.5m.

UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ($k=2$) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.12.01.004 for further details.

COMMENTS

This sensor was calibrated at 90°.

Certificate number: 18.US1.05011

All calibrations are done in the "As Left" condition unless otherwise noted.

This certificate must not be reproduced, except in full, without the approval of SOH Wind Engineering LLC



SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.316.4368 • Fax 802.735.9106 • www.sohwind.com

CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

Certificate number: 18.US1.05010

Date of issue: September 28, 2018

Type: Vaisala Weather Transmitter, WXT520

Serial number: k4250007

Manufacturer: Vaisala, Oyj, Pl 26, FIN-00421 Helsinki, Finland

Client: Aercoustics Engineering Ltd., 1004 Middlegate RD, Suite 1100, S.Tower, Mississauga, ON L4Y 1M4, Canada

Anemometer received: September 28, 2018

Anemometer calibrated: September 28, 2018

Calibrated by: MEJ

Procedure: MEASNET, IEC 61400-12-1:2017 Annex F

Certificate prepared by: EJF

Approved by: Calibration engineer, EJF

Calibration equation obtained: $v [m/s] = 0.99242 \cdot f [m/s] + 0.03258$

Standard uncertainty, slope: 0.00169

Standard uncertainty, offset: 0.54886

Covariance: -0.0000280 (m/s)²/m/s




Coefficient of correlation: $\rho = 0.999984$

Absolute maximum deviation: -0.043 m/s at 12.957 m/s

Barometric pressure: 1004.7 hPa

Relative humidity: 42.1%

Succession	Velocity pressure, q. [Pa]	Temperature in wind tunnel [°C]	Temperature in d.p. box [°C]	Wind velocity, v. [m/s]	Anemometer Output, f. [m/s]	Deviation, d. [m/s]	Uncertainty u_c (k=2) [m/s]
2	9.17	26.0	26.6	3.970	4.0000	-0.032	0.020
4	14.42	26.1	26.7	4.978	4.9655	0.017	0.023
6	20.76	26.1	26.7	5.973	5.9667	0.019	0.026
8	28.34	26.1	26.7	6.979	6.9833	0.016	0.029
10	37.04	26.1	26.7	7.979	8.0167	-0.010	0.033
12	46.92	26.1	26.7	8.981	9.0133	0.003	0.037
13-last	57.79	26.1	26.7	9.967	10.0103	0.000	0.041
11	70.03	26.1	26.7	10.972	11.0167	0.006	0.045
9	83.27	26.1	26.7	11.965	12.0167	0.007	0.049
7	97.66	26.1	26.7	12.957	13.0667	-0.043	0.053
5	113.17	26.1	26.7	13.949	14.0467	-0.024	0.057
3	129.15	26.0	26.7	14.901	14.9500	0.031	0.061
1-first	147.15	26.0	26.6	15.904	15.9833	0.009	0.065



AC-1746



Page 1 of 2

EQUIPMENT USED

Serial Number	Description
Njord 1	Wind tunnel, blockage factor = 1.0035
2254	Control cup anemometer
-	Mounting tube, D = 19 mm
TT002	Summit Electronics. IXPT100, 0-10V Output, wind tunnel temp.
TP001	PR Electronics 5102, 0-10V Output, differential pressure box temp.
DP005	Setra Model 239, 0-1 inWC, differential pressure transducer
HY003	Dwyer RHP-2D20, 0-10V Output, humidity transmitter
BP003	Setra M278, 0-5VDC Output, barometer
PL8	Pitot tube
XB002	Computer Board. 16 bit A/D data acquisition board
9PRZRW1	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Atlantic Scale, Essco Calibration Labs & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.



Photo of the wind tunnel setup. The cross-sectional area is 2.5m x 2.5m.

UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ($k=2$) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.12.01.004 for further details.

COMMENTS

This sensor was calibrated at 0°.

Certificate number: 18.US1.05010

All calibrations are done in the "As Left" condition unless otherwise noted.

This certificate must not be reproduced, except in full, without the approval of SOH Wind Engineering LLC



Trust in every measure

Customer: AEROCOUSTICS ENGINEERING LTD

1004 MIDDLEGATE ROAD

SUITE 1100

MISSISSAUGA, ON L4Y 1M4

PO Number: 2017.01.12C



Certificate/SO Number: 33-Q0M0D-20-1 Revision 0

Manufacturer: Nokoval

Model Number: 7470

Description: Serial to Analog Converter

Serial Number: A165164

ID: NONE

As-Found: In Tolerance

As-Left: In Tolerance

Calibration Date: Feb 02, 2017

Due Date: Feb 02, 2019

Calibrated To: Manufacturer Specification
Calibration Procedure: 1-AC58014-0

Transcat Calibration Laboratories have been audited and found in compliance with ISO/IEC 17025:2005. Accredited calibrations performed within the Lab's Scope of Accreditation are indicated by the presence of the Accrediting Body's Logo and Certificate Number on this Certificate of Calibration. Any measurements on an accredited calibration not covered by that Lab's Scope of Accreditation are listed in the notes section of the certificate. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, SCC, NRC, CLAS, ANAB or any agency of the Federal Government. NVLAP, NIST, SCC, NRC, CLAS or ANAB do not guarantee the accuracy of an individual calibration by accredited laboratories.

Transcat calibrations, as applicable, are performed in compliance with the requirements of the Transcat Quality Manual Revision 1, ISO 9001:2008, ANSI/NCSL Z540.1-1994 (R2002), and ISO 10012:2003. When specified contractually, the requirements of ISO TS 16949:2009, 10CFR21, 10CFR50 App. B and ASME NQA-1:2012 are also covered. Complete records of work performed are maintained by Transcat and are available for inspection. Laboratory standards used in the performance of this calibration are shown on the Supplemental Report.

Transcat documents the traceability of measurements to the SI units through the National Institute of Standards and Technology (NIST), or the National Research Council of Canada (NRC), or other recognized national measurement institutes (NMI) that are signatories to the CIPM Mutual Recognition Arrangement, or accepted fundamental and/or natural physical constants, or by the use of specified methods, consensus standards or ratio type measurements. Documentation supporting traceability information is available for review at a Transcat facility. The measured quantity and the measurement uncertainty are required for further dissemination of traceability.

Uncertainties are reported with a coverage factor k=2, providing a level of confidence of approximately 95%. All calibrations have been performed using processes having a TUR of 4:1 or better (3:1 for mass calibrations), unless otherwise noted on the Supplemental Report. The Test Uncertainty Ratio (TUR) is calculated in accordance with NCSL International RP-18. For mass calibrations: Conventional mass referenced to 8.0 g/cm³.

The results in this report relate only to the item calibrated or tested, and the determination of in or out of tolerance is specific to the model/serial no. referenced above based on the tolerances shown on the supplemental report; these tolerances are either the original equipment manufacturer's (OEM's) warranted specifications or the client's requested specifications. Any number of factors can cause a unit to drift out of tolerance at any time following its calibration. Limitations on the uses of this instrument are detailed in the OEM's operating instructions. This certificate may not be reproduced except in full, without the written approval of Transcat. Additional information, if applicable may be included on separate report(s).



CERTIFICATE OF CALIBRATION

Trust in every measure

Customer: AEROCOUSTICS ENGINEERING LTD
 1004 MIDDLEGATE ROAD
 SUITE 1100
 MISSISSAUGA, ON L4Y 1M4
 PO Number: 2017.01.12C

Certificate/SO Number: 33-Q0M0D-20-1 Revision 0



SCC Lab No 827

As Found/As Left Data

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O Cal Process Uncertainty (k=2; ±)	T O Measurement Uncertainty (k=2; ±)	Units	TUR
DC Current % Source - 4-20mA Ch #1									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	4.002 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	8.003 mA	2.7e-004	1.9e-003	mA	59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	12.000 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.001 mA	1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.001 mA	1.4e-003	2.3e-003	mA	11.4 : 1
DC Current % Source - 4-20mA Ch #2									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	4.004 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	7.998 mA	2.7e-004	1.9e-003	mA	59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	12.000 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.001 mA	1.3e-004	1.9e-003	mA	100.0 : 1
	100%	±(0.1% Span)	19.984	20.016	20.001 mA	1.4e-003	2.3e-003	mA	11.4 : 1
DC Current % Source - 4-20mA Ch #3									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	3.999 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	8.000 mA	2.7e-004	1.9e-003	mA	59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	12.003 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.004 mA	1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	19.999 mA	1.1e-003	2.2e-003	mA	14.5 : 1
DC Current % Source - 4-20mA Ch #4									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	4.003 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	8.006 mA	2.7e-004	1.9e-003	mA	59.3 : 1
	50%	±(0.1% Span)	11.984	12.016	12.010 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.007 mA	1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.008 mA	1.4e-003	2.3e-003	mA	11.4 : 1



Trust in every measure

Customer: AEROCOUSTICS ENGINEERING LTD

1004 MIDDLEGATE ROAD

SUITE 1100

MISSISSAUGA, ON L4Y 1M4

PO Number: 2017.01.12C

CERTIFICATE OF CALIBRATION



SCC Lab No 827

Date Received: January 17, 2017

Service Level: R9

Certificate/SO Number: 33-Q0M0D-20-1 Revision 0

As Found/As Left Data

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O Cal Process Uncertainty (k=2; ±)	O Measurement Uncertainty (k=2; ±)	Units	TUR
DC Current % Source - 0-20mA Ch #1									
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.000 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	5.003 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	10.002 mA	3.2e-004	2.3e-003	mA	62.5 : 1
	75%	±(0.1% Span)	14.980	15.020	14.999 mA	1.2e-003	2.6e-003	mA	16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	20.000 mA	1.4e-003	2.7e-003	mA	14.3 : 1
DC Current % Source - 0-20mA Ch #2									
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.000 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	4.999 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	10.002 mA	3.2e-004	2.3e-003	mA	62.5 : 1
	75%	±(0.1% Span)	14.980	15.020	14.999 mA	1.3e-003	2.7e-003	mA	15.4 : 1
	100%	±(0.1% Span)	19.980	20.020	20.000 mA	1.4e-003	2.7e-003	mA	14.3 : 1
DC Current % Source - 0-20mA Ch #3									
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.001 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	5.001 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	10.000 mA	3.2e-004	2.3e-003	mA	62.5 : 1
	75%	±(0.1% Span)	14.980	15.020	15.002 mA	1.2e-003	2.6e-003	mA	16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	19.998 mA	1.4e-003	2.7e-003	mA	14.3 : 1
DC Current % Source - 0-20mA Ch #4									
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.002 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	5.004 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	10.006 mA	3.2e-004	2.3e-003	mA	62.5 : 1
	75%	±(0.1% Span)	14.980	15.020	15.011 mA	1.3e-003	2.7e-003	mA	15.4 : 1
	100%	±(0.1% Span)	19.980	20.020	20.008 mA	1.4e-003	2.7e-003	mA	14.3 : 1

TRANSCAT
CANADA

Trust in every measure

Customer: AEROCOUSTICS ENGINEERING LTD

1004 MIDDLEGATE ROAD

SUITE 1100

MISSISSAUGA, ON L4Y 1M4

PO Number: 2017.01.12C

CERTIFICATE OF CALIBRATION



Certificate/SO Number: 33-Q0M0D-20-1 Revision 0

As Found/As Left Data						
Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O T (k=2; ±)
DC Voltage % Source - 0-5V Ch#1						Cal Process Measurement Uncertainty (k=2; ±)
0-5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0006 V	5.0e-07
	20%	±(0.1% Span)	0.9950	1.0050	0.9987 V	5.5e-06
	40%	±(0.1% Span)	1.9950	2.0050	2.0004 V	1.1e-05
	60%	±(0.1% Span)	2.9950	3.0050	2.9994 V	1.6e-05
	80%	±(0.1% Span)	3.9950	4.0050	4.0011 V	2.1e-05
	100%	±(0.1% Span)	4.9950	5.0050	5.0001 V	2.6e-05
DC Voltage % Source - 0-5V Ch#2						Cal Process Measurement Uncertainty (k=2; ±)
0-5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0000 V	5.8e-07
	20%	±(0.1% Span)	0.9950	1.0050	1.0010 V	5.5e-06
	40%	±(0.1% Span)	1.9950	2.0050	2.0000 V	2.2e-05
	60%	±(0.1% Span)	2.9950	3.0050	3.0000 V	1.6e-05
	80%	±(0.1% Span)	3.9950	4.0050	4.0020 V	2.1e-05
	100%	±(0.1% Span)	4.9950	5.0050	5.0000 V	2.6e-05
DC Voltage % Source - 0-5V Ch#3						Cal Process Measurement Uncertainty (k=2; ±)
0-5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0001 V	5.0e-07
	20%	±(0.1% Span)	0.9950	1.0050	1.0000 V	5.5e-06
	40%	±(0.1% Span)	1.9950	2.0050	2.0005 V	1.1e-05
	60%	±(0.1% Span)	2.9950	3.0050	2.9993 V	1.6e-05
	80%	±(0.1% Span)	3.9950	4.0050	4.0000 V	2.1e-05
	100%	±(0.1% Span)	4.9950	5.0050	5.0013 V	2.6e-05

TRANSCAT
MANUFACTURING

Trust in every measure

Customer: AEROCOUSTICS ENGINEERING LTD

1004 MIDDLEGATE ROAD

SUITE 1100

MISSISSAUGA, ON L4Y 1M4

PO Number: 2017.01.12C

Certificate/SO Number: 33-Q0M0D-20-1 Revision 0



As Found/As Left Data						
Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O 0 T
					Cal Process Uncertainty (k=2; ±)	Measurement Uncertainty (k=2; ±)
DC Voltage % Source - 0-5V Ch#4						
0 - 5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0004 V	5.0e-007
	20%	±(0.1% Span)	0.9950	1.0050	1.0010 V	5.5e-006
	40%	±(0.1% Span)	1.9950	2.0050	2.0000 V	1.1e-005
	60%	±(0.1% Span)	2.9950	3.0050	3.0020 V	1.6e-005
	80%	±(0.1% Span)	3.9950	4.0050	4.0020 V	2.1e-005
	100%	±(0.1% Span)	4.9950	5.0050	5.0036 V	2.6e-005
DC Voltage % Source - 0-10V Ch#1						
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.001 V	5.0e-007
	20%	±(0.1% Span)	1.990	2.010	2.000 V	1.1e-005
	40%	±(0.1% Span)	3.990	4.010	4.001 V	2.1e-005
	60%	±(0.1% Span)	5.990	6.010	6.002 V	3.1e-005
	80%	±(0.1% Span)	7.990	8.010	7.999 V	4.1e-005
	100%	±(0.1% Span)	9.990	10.010	9.999 V	5.2e-005
DC Voltage % Source - 0-10V Ch#2						
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.001 V	5.0e-007
	20%	±(0.1% Span)	1.990	2.010	2.000 V	1.1e-005
	40%	±(0.1% Span)	3.990	4.010	4.002 V	2.1e-005
	60%	±(0.1% Span)	5.990	6.010	6.002 V	3.1e-005
	80%	±(0.1% Span)	7.990	8.010	8.006 V	4.1e-005
	100%	±(0.1% Span)	9.990	10.010	9.999 V	5.2e-005



CERTIFICATE OF CALIBRATION

Customer: AEROCOUSTICS ENGINEERING LTD

1004 MIDDLEGATE ROAD
SUITE 1100

MISSISSAUGA, ON L4Y 1M4

PO Number: 2017.01.12C

Certificate/SO Number: 33-Q0M0D-20-1 Revision 0



As Found/As Left Data

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O 0 T	Cal Process Uncertainty (k=2; t)	Measurement Uncertainty (k=2; t)	Units	TUR
DC Voltage % Source - 0-10V Ch#3	0%	±(0.1% Span)	-0.010	0.010	0.001 V	5.0e-007	1.2e-003	✓	100.0 : 1	
	20%	±(0.1% Span)	1.990	2.010	2.001 V	1.1e-005	1.2e-003	✓	100.0 : 1	
	40%	±(0.1% Span)	3.990	4.010	4.000 V	2.1e-005	1.2e-003	✓	100.0 : 1	
	60%	±(0.1% Span)	5.990	6.010	6.000 V	3.1e-005	1.2e-003	✓	100.0 : 1	
	80%	±(0.1% Span)	7.990	8.010	8.001 V	4.1e-005	1.2e-003	✓	100.0 : 1	
	100%	±(0.1% Span)	9.990	10.010	10.000 V	5.2e-005	1.2e-003	✓	100.0 : 1	
DC Voltage % Source - 0-10V Ch#4	0%	±(0.1% Span)	-0.010	0.010	0.000 V	5.0e-007	1.2e-003	✓	100.0 : 1	
	20%	±(0.1% Span)	1.990	2.010	2.000 V	1.1e-005	1.2e-003	✓	100.0 : 1	
	40%	±(0.1% Span)	3.990	4.010	4.002 V	2.1e-005	1.2e-003	✓	100.0 : 1	
	60%	±(0.1% Span)	5.990	6.010	6.003 V	3.1e-005	1.2e-003	✓	100.0 : 1	
	80%	±(0.1% Span)	7.990	8.010	8.004 V	4.1e-005	1.2e-003	✓	100.0 : 1	
	100%	±(0.1% Span)	9.990	10.010	10.003 V	5.2e-005	1.2e-003	✓	100.0 : 1	

Customer: AEROCOUSTICS ENGINEERING LTD
 1004 MIDDLEGATE ROAD
 SUITE 1100
 MISSISSAUGA, ON L4Y 1M4
 PO Number: 2017.01.12C



Certificate/SO Number: 33-Q0MOD-20-1 Revision 0

Traceable Standards

Asset	Manufacturer	Model Number	Description	Cal Date	Due Date	Traceability Number
N0118	Agilent/HP	3458A Opt 002	Multimeter, 8.5 Digit	22-Nov-16	30-Nov-17	5-8N0118-727-1

Environmental Data

Temperature	Relative Humidity	Temp / RH Asset
69.30°F / 20.72°C	35.30%	N0438A

Calibrated At:
 4043 Carling Avenue
 Ottawa, ON K2K 2A4

Facility Responsible:
 4043 Carling Avenue
 Ottawa, ON K2K 2A4
 800-828-1470

Calibrated By:
 Digitally Signed On February 02, 2017
 By Mark King

Reviewed By:
 Digitally Signed On February 02, 2017
 By Francis Kanafor

Mark King
 Calibration Technician

Robert Whitaker
 Lab Manager

Unit Barcode:

Customer Number: 9-322110-000

Date Received: January 17, 2017

Service Level: R9

Certificate - Page 7 of 7

OPS-F20-014R0 11/10/2016 FP001R0 10/14/2016

Appendix F.02

Summary of Measurement Results

Summary of Measurement Results

1.1 Sound Power Levels

From Table 12 of IEC test report 17095.01.T53.RP1:

Wind Speed (m/s)	Apparent L _{WA} , (dBA)	Maximum Sound Power Level (dBA)* REA # 2765-A4ER2P
7.5	102.3	104.5
8	103.7	104.5
8.5	104.3	104.5
9	104.4	104.5
9.5	104.3	104.5
10	104.2	104.5
10.5	103.9	104.5
11	103.8	104.5
11.5	104.0	104.5
12	103.6	104.5
12.5	103.8	104.5

*Includes +0.5 dB, per Section E3.1 of the MOECC Compliance Protocol for Wind Turbine Noise

1.2 Tonal Audibility Values

From Table 14 of IEC test report 17095.01.T53.RP1:

Wind Speed (m/s)	Frequency (Hz)	Tonal audibility, ΔL _a (dB)	Tonal Audibility from AAR* (dB)
8	72	-2.6	3
8.5	72	-2.7	3
9	72	-1.7	3
9.5	71	-1.2	3
10	71	-2.0	3
10.5	72	-2.4	3
11.5	73	-2.9	3
12	73	-2.8	3

*Belle River Wind Project Noise Impact Assessment Report (November 27, 2015)

1.3 Statement of Compliance

Based on the results in Table 12 of the IEC 61400-11 test report to which this statement is attached, the maximum apparent sound power level of the test turbine complies with the sound level in REA # 2765-A4ER2P and Section E3.1 of the MOECC Compliance Protocol for Wind Turbine Noise.

Based on the results in Table 14 of the IEC 61400-11 to which this statement is attached, the tonal audibility of the test turbine complies with the maximum tonal audibility of 3 dB as indicated in the statement from the manufacturer dated July 15, 2015, found in Appendix E of the Noise Impact Assessment Report dated November 27, 2015.

Appendix F.03

E-Audit Checklist

Appendix F.03 - (2017 Compliance Protocol Appendix F6): E-Audit checklist for IEC 61400-11:2013

Wind Energy Project – Screening Document – Acoustic Audit Report – Emission IEC61400-11:2013 Standard

Information Required in the Acoustic Audit Report – Emission

Item #	Description	Complete?	Comment
1	Characterization of the wind turbine Items 1 to 26; IEC61400-11:2013, Section 10.2	✓	Report Section 2.1
2	Physical environment Items 27 to 33; IEC61400-11:2013, Section 10.3, Physical Environment	✓	Report Section 2.2, 3.2, 4.2, Appendix A
3	Measurement instrumentation Items 34 to 39; IEC61400-11:2013, Section 10.4, Instrumentation	✓	Report Section 3, Appendix F.01
4	Acoustic data Items 40 to 52; IEC61400-11:2013, Section 10.5, Acoustic Data	✓	Report Section 4, 3.3, Appendix C, Appendix D,
5	Non-acoustic data Items 50 to 53, and 56; IEC61400-11:2003 Section 10.6, Non-Acoustic Data Items 59 and 60; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 8, All necessary and supporting calculations	✓	Report Section 3, Appendix E
6	Uncertainty the apparent sound power level at integer wind speeds one-third octave band spectrum of the noise at the reference position at each integer wind speed the Tonality of the sound emissions of the wind turbine measured at the reference position	✓	Report Section 4, Appendix C
7	Additional information Item 60; NPC-233, Section 10, Report Format, bullet point number 4, Conclusions and Recommendations Item 61; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 8, All necessary and supporting calculations Item 62; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 3, Details of measurement procedure	✓	Report Section 3, Appendix F, data in Excel provided separately
8	Items 68 to 72; IEC61400-11:2013, Section 10.5, Acoustic Data	∅	Optional information, not provided in this report
9	Non-acoustic data Items 73 to 74 are from IEC61400-11:2013, Section 10.6, Non-Acoustic Data	∅	Optional information, not provided in this report

End of Report
