

BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

**IN THE MATTER OF THE CORONA WIND)
COMPANIES' JOINT APPLICATION FOR THE)
LOCATION OF THE CORONA WIND PROJECTS)
AND THE CORONA GEN-TIE SYSTEM IN)
LINCOLN, TORRANCE AND GUADALUPE)
COUNTIES PURSUANT TO THE PUBLIC UTILITY)
ACT, NMSA 1978, §62-9-3)**

Case No. 18-_____

**ANCHO WIND LLC, COWBOY MESA LLC, DURAN)
MESA LLC, RED CLOUD WIND LLC, TECOLOTE)
WIND LLC, VIENTO LOCO LLC,)
)
)
)**

JOINT APPLICANTS.)

DIRECT TESTIMONY OF

DEREK PRICE

BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

IN THE MATTER OF THE CORONA WIND)
COMPANIES' JOINT APPLICATION FOR THE)
LOCATION OF THE CORONA WIND PROJECTS)
AND THE CORONA GEN-TIE SYSTEM IN)
LINCOLN, TORRANCE AND GUADALUPE)
COUNTIES PURSUANT TO THE PUBLIC UTILITY)
ACT, NMSA 1978, §62-9-3)
)
ANCHO WIND LLC, COWBOY MESA LLC, DURAN)
MESA LLC, RED CLOUD WIND LLC, TECOLOTE)
WIND LLC, VIENTO LOCO LLC,)
)
)
JOINT APPLICANTS.)

Case No. 18- 00065-UT

DIRECT TESTIMONY OF

DEREK PRICE

ON BEHALF OF THE CORONA WIND COMPANIES

Case No. 18 - _____ - UT
Before the New Mexico Public Regulation Commission
Direct Testimony of Derek Price
on Behalf of the Corona Wind Companies

WITNESS INTRODUCTION AND QUALIFICATIONS

Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

A. My name is Derek Price. My business address is 4225 Executive Sq., Ste. 260; La Jolla, CA 92037.

Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?

A. I am employed by Pattern Energy Group, LP (together with Pattern Energy Group 2 LP, "Pattern Development"). I hold the position of Senior Pre-Construction Manager. I serve as the Engineering Manager for Transmission and provide technical support for routing and permitting the 345-kilovolt ("kV") transmission system and associated transmission facilities, including the 180-foot right of way ("ROW") located within a 1-mile-wide corridor ("Corona Gen-Tie System" or the "Gen-Tie System"). The Gen-Tie System is being built in association with proposed 2200 megawatt ("MW") of wind generation under development by Pattern Development in Guadalupe, Lincoln, and Torrance Counties ("Corona Wind Projects"). This work was performed in support of the application for location control approval before the New Mexico Public Regulation Commission ("Commission") pursuant to NMSA 1978, §§62-9-3, 62-9-3.2 and Commission Rule 17.9.592 NMAC.

Q. PLEASE DESCRIBE YOUR EDUCATIONAL AND WORK BACKGROUND.

A. I have a Bachelor of Science in Construction Management from Minnesota State University. I have worked in the renewable energy industry since 2008 leading engineering, procurement, and construction of wind and transmission projects. In those

Case No. 18 - _____ - UT
Before the New Mexico Public Regulation Commission
Direct Testimony of Derek Price
on Behalf of the Corona Wind Companies

1 years, I worked as a field engineer, project engineer, construction manager, and project
2 manager.

3 **Q. DO YOU HOLD ANY PROFESSIONAL LICENSES?**

4 A. No.

5 **Q. ON WHOSE BEHALF ARE YOU APPEARING IN THIS PROCEEDING?**

6 A. I am testifying on behalf of the joint applicants, Ancho Wind LLC, Cowboy Mesa LLC,
7 Duran Mesa LLC, Red Cloud Wind LLC, Tecolote Wind LLC, and Viento Loco LLC,
8 (collectively the “Corona Wind Companies” or the “Joint Applicants”).

9 **Q. HAVE YOU PREVIOUSLY TESTIFIED IN ANY ADMINISTRATIVE OR JUDICIAL PROCEEDING?**

10 A. No.

11 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY.**

12 A. My testimony provides an overview of the technical aspects of the Gen-Tie System and the
13 need for a ROW width of 180 feet.

14 **Q. PLEASE PROVIDE A SUMMARY OF YOUR TESTIMONY.**

15 A. I will describe the technical aspects of the Corona Gen-Tie System, including substations,
16 the proposed structure configurations, typical structure heights, typical span lengths and
17 required equipment as well as the anticipated level of ground disturbance. I will also
18 address the need for a 180-foot ROW width which ensures the Gen-Tie System meets all
19 National Electrical Safety Codes (“NESC”), minimizes landowner impact, ensures
20 adequate space for construction workers and equipment, and allows for flexibility during
21 the detailed design phase.

Case No. 18 - _____ - UT
Before the New Mexico Public Regulation Commission
Direct Testimony of Derek Price
on Behalf of the Corona Wind Companies

1 **II. TECHNICAL ASPECTS OF THE CORONA GEN-TIE SYSTEM**

2 **Q. PLEASE DESCRIBE THE CORONA GEN-TIE SYSTEM IN GENERAL TERMS.**

3 A. The Gen-Tie System will include above-ground single-circuit and double-circuit 345-kV
4 high-voltage transmission lines, substations and switchyards. The substations and
5 switchyards are located and optimized in such a manner to accommodate a large subset
6 group of wind turbines to maximize design efficiency and minimize unnecessary
7 underground and above ground electrical infrastructure. The Corona Gen-Tie System will
8 consist of approximately 80 miles of high-voltage transmission lines that act as a collector
9 system in between each of the proposed seven 345-kV substations of the Corona Wind
10 Projects. This collector system will transmit the electricity generated by the wind turbines
11 to the 345-kV substations. Then, the electricity located in the 345-kV substations will be
12 transmitted via the high-voltage transmission lines to the Eastern terminus of one of SunZia
13 Transmission LLC's 500-kV step-up substations ("SunZia Project"). The Eastern terminus
14 of the SunZia Project ("SunZia East") represents the point of interconnection for the
15 Corona Gen-Tie System and the Corona Wind Projects. Steel monopoles or wooden h-
16 frames are expected to be the primary transmission line structures utilized to support the
17 transmission line conductors and overhead optical ground wire ("OPGW"). Typical
18 structure configurations are provided in Exhibit DP-1.

19 **Q. DOES THE CORONA GEN-TIE SYSTEM INCLUDE AN ELECTRIC GENERATING PLANT?**

20 A. No. The Corona Wind Projects are separate from the Gen-Tie System.

Case No. 18 - _____ - UT
Before the New Mexico Public Regulation Commission
Direct Testimony of Derek Price
on Behalf of the Corona Wind Companies

1 **Q. PLEASE DESCRIBE THE TRANSMISSION LINES THAT WILL COMPRISE THE CORONA GEN-**
2 **TIE SYSTEM.**

3 A. As previously mentioned, the Corona Gen-Tie System will transfer the energy generated
4 by the Corona Wind Projects (up to 2200 MW) to the SunZia Project, a 515-mile-long
5 transmission corridor with possible configurations of two 500-kV alternative current
6 transmission (“AC”) lines, or one AC and one direct current 500-kV line in New Mexico
7 and Arizona. There will be approximately 80 miles (427,680 feet) of high-voltage
8 transmission lines that will transfer the electricity generated by the Corona Wind Projects
9 to the 345-kV substations and then, to the 500- kV step-up substation adjacent to SunZia
10 East. See Exhibit DP-2 for substation general arrangements and Exhibit DP-3 for
11 substation one-line diagrams.

12 **Q. PLEASE DESCRIBE THE TRANSMISSION LINE STRUCTURES THAT WILL BE USED.**

13 A. It is anticipated that the primary structure will be steel monopole used to support the
14 transmission line conductor and the OPGW. It is also expected that the conductor will be
15 Aluminum Conductor Steel-Reinforced. However, given the uncertain availability of
16 resources during the time of the Gen-Tie System, the Gen-Tie System keeps flexibility in
17 case one of the primary materials for construction is not economically viable or readily
18 available.

19 **Q. WHY WERE THE STEEL MONOPOLES OR WOODEN H-FRAMES CHOSEN FOR THE CORONA**
20 **GEN-TIE SYSTEM?**

21 A. Steel monopoles and wooden h-frames are the industry standard for 345-kV transmission
22 lines in this region for wind projects. They allow for the greatest flexibility in design for the

Case No. 18 - _____ - UT
Before the New Mexico Public Regulation Commission
Direct Testimony of Derek Price
on Behalf of the Corona Wind Companies

1 Corona Gen-Tie System. They also have a shorter procurement timeframe and have a
2 proven history of being reliable and safe to build and operate.

3 **Q. PLEASE DESCRIBE THE DISTANCE BETWEEN STRUCTURES THAT WILL BE USED IN THE**
4 **CORONA GEN-TIE SYSTEM.**

5 A. The anticipated distance between each structure will vary depending on structure type,
6 conductor, configuration, terrain, avoidance of sensitive areas, existing infrastructure, and
7 landowner preferences, just to name a few. It is anticipated that the average ruling span
8 between each structure will be between 500 and 1,000 feet. For example, flat ground with
9 no extreme turns will result in span lengths generally around 800 to 1,000 feet.

10 **Q. PLEASE DESCRIBE THE INTERCONNECTION FACILITIES.**

11 A. The interconnection facilities proposed for the Corona Gen-Tie System will consist of
12 approximately seven 34.5/345-kV step-up substations, approximately 80 miles of single-
13 circuit and double-circuit 345-kV and 500-kV transmission lines, and one 345/500-kV
14 step-up substation. The substations will also include main-power transformers, breakers,
15 control buildings, and other miscellaneous voltage support equipment necessary for the
16 operation and maintenance of the facilities. See Exhibit DP-2.

17 **Q. HOW WILL THE GEN-TIE SYSTEM INTERCONNECT WITH THE CORONA WIND PROJECTS?**

18 A. Exhibit DP-4 shows a schematic diagram showing how the Corona Gen-Tie System will
19 interconnect with the Corona Wind Projects.

20 **Q. WHERE WILL THE TRANSMISSION LINES BE LOCATED?**

21 A. The transmission lines will be located in Lincoln, Torrance, and Guadalupe Counties in
22 New Mexico. See the Direct Testimony of Adam Cernea Clark and the corresponding

Case No. 18 - _____ - UT
Before the New Mexico Public Regulation Commission
Direct Testimony of Derek Price
on Behalf of the Corona Wind Companies

exhibit for a map showing approximately where the transmission lines will be located.

III. ROW WIDTH EVALUATION

Q. PLEASE EXPLAIN THE PURPOSE OF YOUR ROW WIDTH EVALUATION?

A. The purpose of the ROW width evaluation was to determine the range of ROW widths that would ensure safety, minimize landowner impact, provide adequate space in which to work, and allow flexibility during detailed design of the 345-kV transmission lines proposed by the Gen-Tie System. The NESC and standard industry practice were also used as the basis for determining the necessary ROW width.

Q. HOW IS THE ROW WIDTH DETERMINED?

A. The ROW for an electric transmission line is the corridor under and to either side of the transmission line needed to build, maintain, and operate the line. In general, the width required for an electric high voltage transmission line is access for construction, operations, and maintenance and NESC compliance.

Q. HAVE THE JOINT APPLICANTS DETERMINED THE ROW WIDTH REQUIRED FOR THE PROPOSED GEN-TIE SYSTEM?

A. Yes. The Corona Gen-Tie System will require a 180-foot ROW width.

Q. ARE YOU AWARE OF THE NEW MEXICO STATUTORY REQUIREMENTS REGARDING ROW WIDTH IN RELATION THE A 345-kV TRANSMISSION LINE?

A. My understanding is that under NMSA 1987, §62-9-3.2 no person or entity can begin construction of a transmission line that requires a ROW width greater than 100 feet without first obtaining approval by the Commission, unless the parties agree otherwise.

Case No. 18 - _____ - UT
Before the New Mexico Public Regulation Commission
Direct Testimony of Derek Price
on Behalf of the Corona Wind Companies

1 **Q. WHY DOES THE GEN-TIE SYSTEM REQUIRE A 180-FOOT ROW WIDTH?**

2 A. As mentioned above, a nominal 180-foot ROW width, 90 feet on either side of construction
3 is necessary to ensure compliance with NESC, provide adequate space for construction,
4 and for the operations and maintenance of the transmission line. A 180-foot ROW width
5 also allows for project flexibility in span lengths to reduce impacts to private landowners
6 and sensitive resources. As the span length increases, the ROW width also needs to
7 increase to compensate for increased conductor blowout. There are areas where a 180-foot
8 ROW width may not be necessary depending on structure type and site terrain.

9 **Q. PLEASE EXPLAIN THE BASIC DESIGN CONDITIONS YOU EVALUATED.**

10 A. Preliminary design considerations include geotechnical soils studies, topographical
11 surveys, and annual wind and weather conditions to determine a range of preliminary
12 specifications for equipment and infrastructure for the proposed location of the
13 transmission and interconnection facilities. The primary conditions studied for conductor
14 loading was in compliance with local utilities, NESC and the Associated Criteria for
15 Buildings and other Structures ("ASCE"). Under conditions in NESC ASCE 7, we analyze
16 a maximum wind gust of 100mph (160km/hr) at 60 degrees Fahrenheit (15 degrees Celsius)
17 at a horizontal wind pressure (lb/ft²) of 4 lb/ft². We also evaluate the loading criterial for
18 a ½ inch of radial ice around the conductor since we are located in NESC Zone 1. Under
19 these conditions, and the aforementioned considerations, we evaluate the clearances,
20 conductor movement, and structure deflection to calculate span lengths and structure types
21 and configurations.

Case No. 18 - _____ - UT
Before the New Mexico Public Regulation Commission
Direct Testimony of Derek Price
on Behalf of the Corona Wind Companies

1 **Q. HOW DO SPAN LENGTH AND STRUCTURE CONFIGURATION AFFECT ROW WIDTH?**

2 A. Structure height, configuration, and spacing determine transmission line ROW width.

3 Longer span lengths and higher structures result in an increase of conductor movement
4 which requires additional ROW width.

5 **Q. HOW WILL A 180-FOOT ROW WIDTH MINIMIZE LANDOWNER IMPACT?**

6 A. A 180-foot ROW width allows for greater flexibility in transmission line design, such as
7 longer span lengths, to reduce the number of structures required per mile of line. Narrower
8 ROW width reduces design efficiency and would require structures that are closer together
9 to keep the conductor movement within the designated ROW. Longer spans reduce
10 structure inference with farming, grazing, or any other future use of the landowners'
11 property. Longer spans also reduce visual impact due to less structures and thus
12 minimizing the appearance of a 'picket fence'.

13 **Q. DID YOU TAKE OTHER CONSIDERATIONS INTO ACCOUNT?**

14 A. Yes, other considerations were taken into account such as constructability, operations and
15 maintenance of the line. Visual and noise impacts also affect ROW width. These
16 considerations also consider NESC, prudent industry standards and best practices.

17 **Q. HOW DO CONSTRUCTION, OPERATIONS AND MAINTENANCE AFFECT THE NECESSARY**
18 **ROW WIDTH?**

19 A. The ROW width must be large enough to move equipment along the transmission corridor.
20 Large cranes used to erect the transmission structures are typically the controlling factor.
21 In this case we determined 90 feet from the centerline of the structure (total of 180 feet) is
22 the minimum for access and operations purposes. Considering the level terrain of the

Case No. 18 - _____ - UT
Before the New Mexico Public Regulation Commission
Direct Testimony of Derek Price
on Behalf of the Corona Wind Companies

transmission corridor, we did not identify any extraordinary issues for construction, maintenance, or operations. However, the Joint Applicants request the Commission 90 feet on either side of the structure—a total of 180 feet—to further ensure safety, have minimize landowner impact, allow for enough flexibility to design the transmission lines and provide adequate space to work.

Q. WERE THERE ANY OTHER IMPORTANT CONSIDERATIONS?

A. Yes. We analyzed setback distances from public roads, proposed wind turbine locations, and worked with landowners to ensure proper alignment and setback distances from any existing infrastructure.

IV. CONCLUSION

Q. PLEASE SUMMARIZE YOUR CONCLUSION.

A. The Corona Gen-Tie System will transmit the electricity generated by the Corona Wind Projects to the generation substations and ultimately to the SunZia Project. The high-voltage transmission lines and substations will be built to maximize design efficiency and minimize unnecessary underground and above ground electrical infrastructure. A 180-foot ROW width is necessary for the Corona Gen-Tie System since this range will provide sufficient ROW width for variations in design while addressing electrical safety code requirements, construction and operational considerations according to industry standard practice.

Q. DOES THIS INCLUDE YOUR TESTIMONY?

A. Yes, it does.

BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

**IN THE MATTER OF THE CORONA WIND)
COMPANIES' JOINT APPLICATION FOR THE)
LOCATION OF THE CORONA WIND PROJECTS)
AND THE CORONA GEN-TIE SYSTEM IN)
LINCOLN, TORRANCE AND GUADALUPE)
COUNTIES PURSUANT TO THE PUBLIC UTILITY)
ACT, NMSA 1978, §62-9-3)**

Case No. 18-_____

**ANCHO WIND LLC, COWBOY MESA LLC, DURAN)
MESA LLC, RED CLOUD WIND LLC, TECOLOTE)
WIND LLC, VIENTO LOCO LLC,)
)
)
)**

JOINT APPLICANTS.)

EXHIBIT DP-1

Corona Wind Projects
LINCOLN AND TORRANCE
COUNTIES, NEW MEXICO

Rev	Date	Description	By
A	12/14/17	1111.02.0001	ULI

PATTERN ENERGY GROUP
4225 EXECUTIVE SQUARE
LA JOLLA, CA 92037



PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
TO BE USED FOR
CONSTRUCTION.
FOR REVIEW PURPOSES
ONLY.

3350 38th Avenue South
P.O. Box 1000
Flagstaff, AZ 86001
Phone: 928.779.1100
Fax: 928.779.1101
www.ultele.com




Ultel
Design By: Q. HART
Checked By: D. HART
Approved By: D. HART
Project Number: 17-0501

STRUCTURE FRAMING
DRAWING - SINGLE
CIRCUIT TANGENT
STRUCTURE

REVISION
A
DWG #
SNZ-TLO-C-ST1-001

Exhibit DP-1
Page 1 of 4


ITEM #	QTY	DESCRIPTION	MFG	MFG ITEM#
OPGW ASSEMBLY				
18142	AS REQ'D	FIBER OPGW		
CONDUCTOR ASSEMBLY				
10176	3	BRACED POST INSULATOR ASSEMBLY, VERTICAL BUNDLE, MAXIMUM WORKING VERTICAL LOAD 6,620 LBS	MACLEAN	B311F149B14140VB



Corona Wind Projects
LINCOLN AND TORRANCE
COUNTIES, NEW MEXICO

Rev.	Date	Description	By
1	10/15/17	15% DESIGN	UET

PATTERN ENERGY GROUP
4225 EXECUTIVE SQUARE
LA JOLLA, CA 92037



PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
TO BE USED FOR
CONSTRUCTION.
FOR REVIEW PURPOSES
ONLY.

3350 34th Avenue South
P.O. Box 10000
Flagstaff, AZ 86001
Phone: 928.779.1100
Fax: 928.779.1101
Website: www.ulteg.com




Ultieg
Barbara - Owner - Detail Label - 7/20/17
Design By: G. PARENT
Checked By: J. MARRAS
Approved By: J. MARRAS
Project Number: 17-0551

STRUCTURE FRAMING
DRAWING - DOUBLE
CIRCUIT TANGENT
STRUCTURE

REVISION:
A
DWG #
SNZ-TLO-C-ST2-001

Exhibit DP-1
Page 2 of 4

ITEM #	QTY	DESCRIPTION	MFG	MFG ITEM#
18142	AS REQ'D	FIBER OPGW		
CONDUCTOR ASSEMBLY				
10176	3	BRACED POST INSULATOR ASSEMBLY, VERTICAL BUNDLE, MAXIMUM WORKING VERTICAL LOAD 8,620 LBS	MACLEAN	B311F149B14140VB



Corona Wind Projects
LINCOLN AND TORRANCE
COUNTIES, NEW MEXICO

Rev.	Date	Drawn by	By
A	10/15/17	1702.02/00H	U.S.

PATTERN ENERGY GROUP
4225 EXECUTIVE SQUARE
LA JOLLA, CA 92037



PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND NOT
TO BE USED FOR
CONSTRUCTION.
FOR REVIEW PURPOSES
ONLY.

3250 38th Avenue South
Flagle North Canada 28104
Flagle North Canada 28104
Flagle North Canada 28104
www.flagle.com


Design By: C. HARTNEY
Reviewed By: M. HARTNEY
Approved By: M. HARTNEY
Project Number: 1710501

STRUCTURE FRAMING
DRAWING - SINGLE
CIRCUIT GUYED HEAVY
ANGLE STRUCTURE


REVISION:
A
SNZ-TLO-C-ST3-001

Exhibit DP-1
Page 3 of 4


ITEM #	QTY.	DESCRIPTION	INFO	ITEM#
OPGW ASSEMBLY				
18149	AS REQ'D	FIBER OPGW		
11222	2	FIBER/IGN DEAD END FOR OPGW		
CONDUCTOR ASSEMBLY				
10175	3	HORIZONTAL JUMPER POST INSULATOR		




DETAIL A: OPGW DETAIL & 38\"/>



DETAIL B: CONDUCTOR DETAIL
SCALE: N.T.S.




SECTION B-B: CONDUCTOR PLAN VIEW
SCALE: N.T.S.



SECTION A-A: OPGW PLAN VIEW
SCALE: N.T.S.



SECTION C-C: JUMPER POST MOUNTING
SCALE: N.T.S.



ELEVATION
SCALE: N.T.S.

Corona Wind Projects
LINCOLN AND TORRANCE
COUNTIES, NEW MEXICO

[illegible]

PATTERN ENERGY GROUP
4225 EXECUTIVE SQUARE
LA JOLLA, CA 92037



PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
TO BE USED FOR
CONSTRUCTION.
FOR REVIEW PURPOSES
ONLY

3150 14th Avenue South
Fargo, North Dakota 58104
Phone: 701.263.6500
Fax: 701.267.9181
www.ultaleg.com


Standard - Denver - Green Lakes - Fargo - Scottsdale - St. Paul

TRANSMISSION LINE
345KV TANGENT H-FRAME

REVISIONS

A

XXXX-XXXX-XXXX-XXXX-XXXX
© DMG

Exhibit DP-1
Page 4 of 4

BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

IN THE MATTER OF THE CORONA WIND)
COMPANIES' JOINT APPLICATION FOR THE)
LOCATION OF THE CORONA WIND PROJECTS)
AND THE CORONA GEN-TIE SYSTEM IN)
LINCOLN, TORRANCE AND GUADALUPE)
COUNTIES PURSUANT TO THE PUBLIC UTILITY)
ACT, NMSA 1978, §62-9-3)

Case No. 18-_____

ANCHO WIND LLC, COWBOY MESA LLC, DURAN)
MESA LLC, RED CLOUD WIND LLC, TECOLOTE)
WIND LLC, VIENTO LOCO LLC,)
)
)
)

JOINT APPLICANTS.)

EXHIBIT DP-2

LEGEND:
OPERATOR PLATFORM
RETRACTED SECTION VIEW
DRAWING ON WHICH SECTION
APPEARS
CABLE TRENCH
AREA LIGHT
BASE LINE INTERSECTION
FENCE TO GATE

PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
TO BE USED FOR
CONSTRUCTION
FOR REVIEW PURPOSES
ONLY.


3300 38th Avenue South
Fargo, North Dakota 58104
Tel: 701.785.1000
Fax: 701.785.1001
www.ultelec.com
Ultelec
Design By: T. REVERANCE
Approved By: J. WILCOX (PE)
Project Number: 17-001

SUBSTATION
GENERAL ARRANGEMENT
(SUB A, E, F & G)

REVISION
A

SNZ-SS0-E-EL0-P01-01

Exhibit DP-2
Page 1 of 5



File	Date	Description	By
A RETROCE 304 GELMAN PACKAGE			

PATTERN ENERGY GROUP
4225 EXECUTIVE SQUARE
LA JOLLA, CA 92037



- LEGEND:**
- | | |
|---|---------------------------------------|
|  | OPERATION PLATFORM |
|  | INDICATES SECTION VIEW |
|  | ORIGINATING OR VISION SECTION APPAREL |
|  | CABLE TRENCH |
|  | AIRWAY LIGHT |
|  | BASE LINE INTERSECTION |
|  | FENCE or BARRIER |

PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
TO BE USED FOR
CONSTRUCTION.
FOR REVIEW PURPOSES
ONLY.


3350 20th Avenue South
 Fargo, North Dakota 58104
 Phone: 701.250.8500
 Fax: 701.207.3197
www.ultele.com

Richard W. Roberts
 Executive Director
 Forward • Connect • Develop Lives • Forge • Social Fabric of Our
 Design By
 T. BEVERANCE
 Cream By
 P. TWUCHURU
 Approved By
 Project Number: 17 00501

**SUBSTATION
GENERAL ARRANGEMENT
(SUB B)**

REVISION:

NEW YORK, NY
A DWG #
SNZ-SS0-E-EL0-P02-01

Exhibit DP-2
Page 2 of 5



- LEGEND:
- OPERATOR PLATFORM
 - INDICATES SECTION VIEW
 - DRAWING ON WHICH LOCATION APPEARS
 - CABLE TRENCH
 - AREA LIGHT
 - BASE LINE INTERSECTION
 - FENCE OR BARRIER

PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
FOR CONSTRUCTION
FOR REVIEW PURPOSES
ONLY.

3500 34th Avenue South
Palo Alto, CA 94304
Tel: 650.321.1000
Fax: 650.321.2101
www.ullrich.com

Ullrich


Design By: T. J. JENNIFER
Drawn By: P. W. JENNIFER
Project Number: 1706691

SUBSTATION
GENERAL ARRANGEMENT
(SUB D)

REVISION:
A

SNZ-SS0-E-EL0-P04-01

Exhibit DP -2
Page 4 of 5



Rev.	Date	Description	By
A	03/04/10	30% DESIGN PACKAGE	LAT

PATTERN ENERGY GROUP
4225 EXECUTIVE SQUARE
LA JOLLA, CA 92037



LEGEND:
SWITCHGEAR PLATFORM
INDICATED SECTION VIEW
DRAWING ON WHICH SECTION APPLIES
CABLE TRENCH
AREA LIGHT
BASE LINE INTERSECTION
FENCE at MARGIN

PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
TO BE USED FOR
CONSTRUCTION.
FOR REVIEW PURPOSES
ONLY.

3500 34th Avenue South
Phoenix, AZ 85040
Phone: 710.350.6500
Fax: 710.327.3191
www.ultegra.com


Ultegra
Design By: T. REVENANCE
Approved By: T. REVENANCE
Project Number: 172091

SUBSTATION
GENERAL ARRANGEMENT
345/500KV SWITCHYARD

REVISION
A

SNZ-SS0-E-EL1-P01-01

Exhibit DP-2
Page 5 of 5



BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION


**IN THE MATTER OF THE CORONA WIND)
COMPANIES' JOINT APPLICATION FOR THE)
LOCATION OF THE CORONA WIND PROJECTS)
AND THE CORONA GEN-TIE SYSTEM IN)
LINCOLN, TORRANCE AND GUADALUPE)
COUNTIES PURSUANT TO THE PUBLIC UTILITY)
ACT, NMSA 1978, §62-9-3)**

Case No. 18-_____

**ANCHO WIND LLC, COWBOY MESA LLC, DURAN)
MESA LLC, RED CLOUD WIND LLC, TECOLOTE)
WIND LLC, VIENTO LOCO LLC,)**

JOINT APPLICANTS.)

EXHIBIT DP-3



Corona Wind Projects
LINCOLN AND TORRANCE
COUNTIES, NEW MEXICO

Rev. 10/10/10
A. 10/10/10 10/10/10 (PAGE 1)

PATTERN ENERGY GROUP
4225 EXECUTIVE SQUARE
LA JOLLA, CA 92037



PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
TO BE USED FOR
FOR REVIEW PURPOSES
ONLY.


3500 34th Avenue South
Fargo, ND 58104
Phone: 701.233.0000
Fax: 701.233.0001
www.unilog.com

Unilog
3500 34th Avenue South
Fargo, ND 58104
Phone: 701.233.0000
Fax: 701.233.0001
www.unilog.com

DESIGNED BY
T. SEVERANCE
CHECKED BY
T. ADAMS
PROJECT NUMBER: 17-0287

REVISION
A
DWG. 4
SNZ-SSO-R-QLD-803-01

Exhibit DP-3
Page 2 of 5




Ultraig
3350 34th Avenue South
Fort Myers, North Carolina 28104
Phone: 701.280.6500
Fax: 701.237.3181
www.ultraig.com

Board: Davis • Carol Lewis • Faye • Sou Felt • S. Fall
 Design By: T. BEVERIDGE
 Drawn By: T. ADAMS
 Approved By: _____
 Project Number: 17.00161

REVISION
A

SNZ-SS0-R-OL0-B04-01



Corona Wind Projects
LINCOLN AND TORRANCE
COUNTIES, NEW MEXICO

Rev	Desc	Drawn	By
1	02/13/17	W. J. (JASON) HOGAN	WJH

PATTERN ENERGY GROUP
4025 EXECUTIVE SQUARE
LA JOLLA, CA 92037



PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
TO BE USED FOR
CONSTRUCTION
FOR REVIEW PURPOSES
ONLY


3360 Jule Avenue South
Fargo, North Dakota 58104
Phone: 701.281.8500
Fax: 701.281.8501
www.dyneg.com

Design By: T. ADAMS
Checked By: T. ADAMS
Project Number: 17-0001

**SUBSTATION
SWITCHING DIAGRAM
(SUB D)**

REV: 02/13/17
A
DWG #
SNZ-SSO-R-OL-005-01

Exhibit DP-3
Page 4 of 5



Rev	Date	Description	By
1	03/11/17	10% DESIGN PROPOSAL	LSB

PATTERN ENERGY GROUP
4125 EXECUTIVE SQUARE
LA JOLLA, CA 92037



PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
FOR CONSTRUCTION
FOR REVIEW PURPOSES
ONLY.


3250 34th Avenue South
Flagstaff, North Dakota 58104
Phone: (701) 782-2222
Fax: (701) 782-2319
www.ultipac.com

Ultipac
Branch Office - Dallas, Texas - 17000
Design By: T. ACHILLE
Checked By: T. ACHILLE
Approved By: T. ACHILLE
Project Number: 1700001

**SUBSTATION
SWITCHING DIAGRAM**
345/500KV SWITCHYARD

REVISION:
A
SNZ-SS0-R-OL0-B06-01

Exhibit DP-3
Page 5 of 5



BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

**IN THE MATTER OF THE CORONA WIND)
COMPANIES' JOINT APPLICATION FOR THE)
LOCATION OF THE CORONA WIND PROJECTS)
AND THE CORONA GEN-TIE SYSTEM IN)
LINCOLN, TORRANCE AND GUADALUPE)
COUNTIES PURSUANT TO THE PUBLIC UTILITY)
ACT, NMSA 1978, §62-9-3)**

Case No. 18-_____

**ANCHO WIND LLC, COWBOY MESA LLC, DURAN)
MESA LLC, RED CLOUD WIND LLC, TECOLOTE)
WIND LLC, VIENTO LOCO LLC,)
)
)
)**

JOINT APPLICANTS.)

EXHIBIT DP-4



Rev.	Date	Description	By	Check
A	5/15/14	PRELIMINARY	TJC	

PRELIMINARY
NOT FOR CONSTRUCTION

THIS DRAWING IS
PRELIMINARY AND IS NOT
TO BE USED FOR
CONSTRUCTION
FOR REVIEW PURPOSES
ONLY.


3250 38th Avenue South
Flagstaff, North Dakota 58104
Phone: 701.782.2000
Fax: 701.782.2181
www.ulteg.com

Ultig
Design By: T. BEVERANCE
Drawn By: P. BECKHARDT
Checked By: J. BECKHARDT
Project Number: 170001

**OVERALL SWITCHING
DIAGRAM**

REVISION:
A
DWG. #
SNZ-SSO-R-OL-0-B01-01

Exhibit DP-4
Page 1 of 1



BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

IN THE MATTER OF THE CORONA WIND)
COMPANIES' JOINT APPLICATION FOR THE)
LOCATION OF THE CORONA WIND PROJECTS)
AND THE CORONA GEN-TIE SYSTEM IN)
LINCOLN, TORRANCE AND GUADALUPE)
COUNTIES PURSUANT TO THE PUBLIC UTILITY)
ACT, NMSA 1978, §62-9-3)

Case No. 18-_____

ANCHO WIND LLC, COWBOY MESA LLC, DURAN)
MESA LLC, RED CLOUD WIND LLC, TECOLOTE)
WIND LLC, VIENTO LOCO LLC,)
)
)
)

JOINT APPLICANTS.)

AFFIDAVIT OF DEREK PRICE

BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

IN THE MATTER OF CORONA WIND)
COMPANIES' JOINT APPLICATION FOR)
THE LOCATION OF THE CORONA WIND)
PROJECTS AND CORONA GEN-TIE)
SYSTEM PURSUANT TO THE PUBLIC)
UTILITY ACT, NMSA 1978, § 62-9-3)

Case No. 18-____-UT

ANCHO WIND LLC, COWBOY MESA LLC,)
DURAN MESA LLC, RED CLOUD WIND)
LLC, TECOLOTE WIND LLC, VIENTO)
LOCO LLC,)

JOINT APPLICANTS)
_____)

AFFIDAVIT OF DEREK PRICE

STATE OF CALIFORNIA)
COUNTY OF San Diego) ss.

I have read the foregoing Direct Testimony, and it is true and accurate based on my own knowledge and belief.

D. P. R.

SUBSCRIBED and sworn to before me this 12 day of March 2018.

Pamela Kiefer Metz
NOTARY PUBLIC

May 19, 2019
My Commission Expires

