



GRAND RENEWABLE ENERGY PARK
WIND TURBINE SPECIFICATIONS REPORT

DRAFT

File No. 160960577
July 2011

Prepared for:

Samsung Renewable Energy Inc.
55 Standish Court
Mississauga, ON L5R 4B2

Prepared by:

Stantec Consulting Ltd.
Suite 1 - 70 Southgate Drive
Guelph ON N1G 4P5

EXECUTIVE SUMMARY

Samsung C&T (Samsung), Korea Power Electric Corporation (KEPCO) and Pattern Energy (Pattern) are proposing to develop, construct, and operate the Grand Renewable Energy Park (the “Project”) in response to the Government of Ontario’s initiative to promote the development of renewable electricity in the Province. Together, these companies (referred to herein as “SPK”) will be involved in the development of the first phase of the energy cluster development.

The Project is proposed within the County of Haldimand and is generally bounded by Townline Road to the north, Haldimand Road 20 to the west, the Grand River to the east and Lake Erie to the south. It consists of a 151.1 MW (nameplate capacity) wind project, a 100 MW (nameplate capacity) solar project located on privately owned and Ontario Realty Corporation (ORC) managed lands and a transmission line to convey electricity to the existing power grid.

The basic components of the Project include 67 wind turbines, approximately 425,000 photovoltaic (PV) solar panels installed on fixed ground-mounted racking structures organized into 100-1 MW solar modules, a collector sub-station, interconnect station and Operations and Maintenance building, temporary storage and staging areas, approximately 20 km of 230 kV transmission lines along Haldimand Road 20, approximately 82 km of new overhead and/or underground 34.5 kV collector lines along public roads, approximately 48 km of new underground collector lines along turbine access roads, approximately 45 km of turbine access roads and 40 km of solar panel maintenance roads.

SPK has retained Stantec Consulting Ltd. (Stantec) to prepare a Renewable Energy Approval (REA) application, as required under Ontario Regulation 359/09 - Renewable Energy Approvals under Part V.0.1 of the Act of the *Environmental Protection Act* (O. Reg. 359/09). According to subsection 6(3) of O. Reg. 359/09, the wind component of the Project is classified as a Class 4 Wind Facility and the solar component of the Project is classified as a Class 3 Solar Facility. This Draft Wind Turbines Specification Report is one component of the REA application for the Project, and has been prepared in accordance with O. Reg. 359/09, and the Ontario Ministry of Natural Resources’ (MNR’s) *Approval and Permitting Requirements Document for Renewable Energy Projects* (September 2009).

The following table summarizes the documentation requirements as specified under O. Reg. 359/09.

**GRAND RENEWABLE ENERGY PARK
WIND TURBINES SPECIFICATION REPORT****Table E.1: Wind Turbine Specifications Report Requirements (as per O. Reg. 359/09 – Table 1)**

Requirements	Completed	Section Reference
Provide specifications of each wind turbine, including make, model, name plate capacity, hub height above grade, rotational speeds and acoustic emissions data, including the sound power level and frequency spectrum, in terms of octave-band power levels.	✓	2.0

The purpose of the Wind Turbine Specifications Report is to provide the public, aboriginal communities, municipalities, and regulatory agencies with an understanding of the technical specifications of the wind turbine generators to be utilized for the Project.

Table of Contents

EXECUTIVE SUMMARY	E.1
1.0 OVERVIEW.....	1.1
2.0 TECHNICAL SPECIFICATIONS	2.1
2.1 SWT-2.3-101 WIND TURBINE	2.1
2.2 WIND TURBINE LOCATIONS.....	2.1
3.0 CLOSURE	3.1

List of Tables

Table 2.1: Turbine Description – Siemens SWT-2.3	2.1
--	-----

List of Attachments

Attachment A Turbine Specifications
Attachment B Turbine Locations

1.0 Overview

Samsung C&T (Samsung), Korea Power Electric Corporation (KEPCO) and Pattern Energy (Pattern) are proposing to develop, construct, and operate the Grand Renewable Energy Park (the “Project”) in response to the Government of Ontario’s initiative to promote the development of renewable electricity in the Province. Together, these companies (referred to herein as “SPK”) will be involved in the development of the first phase of the energy cluster development.

The Project is proposed within the County of Haldimand and is generally bounded by Townline Road to the north, Haldimand Road 20 to the west, the Grand River to the east and Lake Erie to the south. It consists of a 151.1 MW (nameplate capacity) wind project, a 100 MW (nameplate capacity) solar project located on privately owned and Ontario Realty Corporation (ORC) managed lands and a transmission line to convey electricity to the existing power grid.

The basic components of the Project include 67 wind turbines, approximately 425,000 photovoltaic (PV) solar panels installed on fixed ground-mounted racking structures organized into 100-1 MW solar modules, a collector sub-station, interconnect station and Operations and Maintenance building, temporary storage and staging areas, approximately 20 km of 230 kV transmission lines along Haldimand Road 20, approximately 82 km of new overhead and/or underground 34.5 kV collector lines along public roads, approximately 48 km of new underground collector lines along turbine access roads, approximately 45 km of turbine access roads and 40 km of solar panel maintenance roads.

SPK has retained Stantec Consulting Ltd. (Stantec) to prepare a Renewable Energy Approval (REA) application, as required under O. Reg. 359/09. According to subsection 6.(3) of O. Reg. 359/09, the wind component of the Project is classified as a Class 4 Wind Facility and the solar component of the Project is classified as a Class 3 Solar Facility. This Draft Wind Turbines Specification Report is one component of the REA application for the Project, and has been prepared in accordance with O. Reg. 359/09, and the Ontario Ministry of Natural Resources’ (MNR’s) *Approval and Permitting Requirements Document for Renewable Energy Projects* (September 2009) (APRD).

2.0 Technical Specifications

2.1 SWT-2.3-101 WIND TURBINE

The Project includes 67 Siemens SWT-2.3-101 wind turbines (65 turbines with a nameplate capacity of 2.221 MW and 2 turbines with a nameplate capacity of 2.126 MW). All physical attributes of the turbine remain the same however the reduction of name plate capacity impacts the maximum power output of the turbine as well as each turbines noise characteristics.

A summary of the basic specifications of the turbine model is provided in Table 2.1 below. A complete description of the general specifications for this turbine model is found in the manufacturer's information provided as **Attachment A**.

Table 2.1: Turbine Description – Siemens SWT-2.3	
Operating Data	Specification
General	
Rated capacity (kW)	2221 and 2126
Cut-in wind speed (m/s)	3-5
Cut-out wind speed (m/s)	25
Rotor	
Number of rotor blades	3 (49 m long each)
Rotor diameter (m)	101
Swept area (m ²)	8000
Rotor speed (rpm)	6-16
Tower	
Hub height (m)	100
Tip height (m)	149

Acoustic emissions data supplied by Siemens is provided in **Attachment A**. Additional acoustic data is also provided in the Environmental Noise Impact Assessment contained within the Design and Operations Report.

2.2 WIND TURBINE LOCATIONS

The wind turbines will be located at the locations and coordinates provided in **Attachment B**. The map also identifies the 2 turbines that have a nameplate capacity of 2.126 MW.

3.0 Closure

This report has been prepared by Stantec for the sole benefit of SPK, and may not be used by any third party without the express written consent of SPK. The data presented in this report are in accordance with Stantec's understanding of the Project as it was presented at the time of reporting.

This Turbine Specifications Report has been prepared in accordance with O. Reg. 359/09. The data presented in this report are in accordance with Stantec's understanding of the Project as it was presented at the time of the Report.

STANTEC CONSULTING LTD.

DRAFT

Mark Kozak
Project Manager

DRAFT

Rob Nadolny
Senior Project Manager

Attachment A

Turbine Specifications

WINDTEST

Kaiser-Wilhelm-Koog GmbH

**Report of acoustical emissions of a Siemens
wind turbine generator system of the type
2.3 MW Mk II
near Høvsøre in Denmark**

Date(s) of measurements: 2005-08-11 to 13

September 2005

Report WT 4498/05



Laboratory accredited by DAP Deutsches Akkreditierungssystem
Prüfwesen according to DIN EN ISO/IEC 17025. This
accreditation is valid for the test and measurement procedures
given in the certificate.





**Report of acoustical emissions of a Siemens
wind turbine generator system of the type
2.3 MW Mk II
near Høvsøre in Denmark**

Report WT 4498/05

Site or measuring place:	Høvsøre, Denmark in the region of Ringkøbing
--------------------------	--

Customer:	Siemens Wind Power A/S Borupvej 16 7330 Brande, Denmark
-----------	---

Contractor:	WINDTEST Kaiser-Wilhelm-Koog GmbH Sommerdeich 14 b 25709 Kaiser-Wilhelm-Koog, Germany
-------------	---

Date of order:	2005-08-23	Order No.:	4025 05 03069 64
----------------	------------	------------	------------------

Engineer:

Checked:


Dipl.-Ing. A. Jensen


Dipl.-Ing. J. Neubert
Acoustics Group Leader

Kaiser-Wilhelm-Koog, 2005-09-08



Table of contents

1	Scope	4
2	Method	4
2.1	Measurement procedures.....	4
2.2	Measurement object.....	4
2.3	Course of the measurements	4
2.4	Measuring equipment.....	5
2.5	Position of microphone	5
3	Measurement results.....	5
3.1	Determination of directivity	5
3.2	Sound pressure level.....	6
3.3	Sound power level of the turbine	7
3.4	Tonal and frequency analyses.....	7
3.5	3rd octave analysis.....	8
3.6	Uncertainties	9
3.6.1	Sound power level.....	9
3.6.2	One-third octave band spectra	10
3.6.3	Tonality	10
4	Summary	10
5	List of employed symbols and abbreviations	12
6	References.....	13
7	Annex	13
	Annex 1: Measuring equipment used	14
	Annex 2.1a: 2 nd order regression of L_{Aeq} and L_n against standardised wind speed.....	15
	Annex 2.1b: Higher order regression of L_{Aeq} and L_n against standardised wind speed.....	16
	Annex 2.2: Summary of analysis input parameters and results.....	17
	Annex 2.3: Plot of L_{WA} against standardised wind speed	18
	Annex 2.4: Plot of L_{Aeq} and L_n against measured wind speed	19
	Annex 2.5: Plot of L_{Aeq} against power	20
	Annex 2.6: Plot of rotor speed against power	21
	Annex 2.7: Time plot of measurement.....	22
	Annex 3.1a: Overview spectra 1-6 of turbine noise at a wind speed of 6 m/s	23
	Annex 3.1b: Overview spectra 7-12 of turbine noise at a wind speed of 6 m/s	24
	Annex 3.1c: Analysis of tonality of turbine noise at a wind speed of 6 m/s.....	25
	Annex 3.2a: Overview spectra 1-6 of turbine noise at a wind speed of 7 m/s	26



Annex 3.2b: Overview spectra 7-12 of turbine noise at a wind speed of 7 m/s	27
Annex 3.2c: Analysis of tonality of turbine noise at a wind speed of 7 m/s.....	28
Annex 3.3a: Overview spectra 1-6 of turbine noise at a wind speed of 8 m/s	29
Annex 3.3b: Overview spectra 7-12 of turbine noise at a wind speed of 8 m/s	30
Annex 3.3c: Analysis of tonality of turbine noise at a wind speed of 8 m/s.....	31
Annex 3.4a: Overview spectra 1-6 of turbine noise at a wind speed of 9 m/s	32
Annex 3.4b: Overview spectra 7-12 of turbine noise at a wind speed of 9 m/s	33
Annex 3.4c: Analysis of tonality of turbine noise at a wind speed of 9 m/s.....	34
Annex 3.5a: Overview spectra 1-6 of turbine noise at a wind speed of 10 m/s	35
Annex 3.5b: Overview spectra 7-12 of turbine noise at a wind speed of 10 m/s.....	36
Annex 3.5c: Analysis of tonality of turbine noise at a wind speed of 10 m/s.....	37
Annex 4.1: A-weighted sound pressure 1/3-octave spectrum at 6 m/s.....	38
Annex 4.2: A-weighted sound pressure 1/3-octave spectrum at 7 m/s.....	39
Annex 4.3: A-weighted sound pressure 1/3-octave spectrum at 8 m/s.....	40
Annex 4.4: A-weighted sound pressure 1/3-octave spectrum at 9 m/s.....	41
Annex 4.5: A-weighted sound pressure 1/3-octave spectrum at 10 m/s.....	42
Annex 5: Photos	43
Annex 6: Power curve used in the analysis	45
Annex 7a: Manufacturer's certificate, page 1/2.....	46
Annex 7b: Manufacturer's certificate, page 2.....	47



1 Scope

The order from Siemens Wind Power A/S dated 2005-08-23 required WINDTEST Kaiser-Wilhelm-Koog GmbH (WINDTEST) to carry out acoustic noise measurements on the Siemens wind turbine generator system (WTGS or 'turbine') 2.3 MW Mk II of hub height 80 m near Høvsøre, in the region of Ringkøbing in Denmark. From this, the sound power level, relevant for noise propagation calculations, of the noise emitted from the turbine at different wind speeds, and frequency spectra of the same, was also to be determined.

The results given in this report relate only to this WTGS.

2 Method

2.1 Measurement procedures

All measurements and analysis described in this report were done in accordance with the IEC 61400-11: Wind turbine generator systems – Part 11: Acoustic noise measurement techniques, Ed. 2 [IEC 61400-11] using Method 1 as outlined in 7.3.1.1 "Method 1: determination of the wind speed from the electric output and the power curve". In this report the sound power level and the tonality are given in the range of wind speeds from 6 to 10 m/s at a height of 10 m.

Note: A calculated power curve for the turbine was provided by the customer for purposes of converting the measured turbine power output into the standardised wind speed. This power curve is given in the Annex.

2.2 Measurement object

Table 1 shows the characteristics of the measured WTGS. The remaining characteristics can be found in the manufacturer's certificate included in the Annex.

Table 1: Characteristics of the measured WTGS

parameter	Value
manufacturer	Siemens Wind Power A/S
type	2.3 MW Mk II
WTGS No.	2300439
site	Høvsøre, Denmark
hub-height above ground	80 m
rotor diameter	92,4 m
distance middle of tower to middle of blade flange	3,5 m
power control (pitch/stall)	pitch

2.3 Course of the measurements

The total measurement period lasted from 2005-08-12 15:00 h until 2005-08-13 20:00 h. During this time the measured wind speed ranged from 5,5 to 12 m/s at a height of 10 m. The real



electrical power output of the turbine ranged between 300 and 2300 kW. The turbine was running continuously during the operating noise measurements.

The sound pressure level was recorded with a microphone on an acoustically hard board. The real electrical power output and the wind speed at a height of 10 m, taken upwind of the turbine in clear air, were also recorded. Time periods, where there were intermittent background noise of a significant nature, e.g. passing cars, planes flying over, rain etc., were marked accordingly during the measurements, and were omitted in the later evaluation. If there were random and reoccurring disturbances, which could not be marked during the measurement, a later state correction by means of a comparison with the DAT-recording was done.

The wind turbine generator system is sited in farmland. The surface roughness length for this measurement is assumed to be 0.05 m. The microphone position was chosen to minimise the effect of buildings, trees or bushes in the surrounding area of the wind turbine generator system, which might have had an influence on the measurement results. The conditions comply with free field behaviour over a reflecting plane.

During the noise measurements the meteorological conditions given in Table 2 were prevailing.

Table 2: Prevailing meteorological conditions during the measurements

<i>barometric pressure at 2 m height above ground [hPa]</i>	1001 - 1006
<i>air temperature at 2 m height above ground [°C]</i>	14 - 18
<i>prevailing wind direction</i>	WNW
<i>range of wind direction</i>	280 - 330
<i>weather conditions</i>	cloudy and dry
<i>Turbulence intensity at 10 m height above ground [%]</i>	14,0

2.4 Measuring equipment

The measuring equipment used is listed in the Annex. This equipment is tested regularly according to [IEC 61400-11] to ensure a high degree of measurement accuracy as well as security of data. The complete acoustic measurement system was checked before and after the measurements using an acoustic calibrator (B&K 4231).

2.5 Position of microphone

The microphone was placed according to [IEC 61400-11]. The distance from the turbine to the reference measuring point, $R_0 = 112$ m, was chosen taking local circumstances into account. The height of the microphone with respect to the bottom of the turbine foundation was 0 m.

3 Measurement results

3.1 Determination of directivity

As no significant directivity was ascertained the reference measurement position was chosen to be directly downwind of the turbine. This ensured worst case sound propagation conditions were taken into account.



3.2 Sound pressure level

The microphone converts the sound pressure into a continuous analogue signal which is then fed to a sound level meter. The resulting dB value, L_{Aeq} , together with the status, the wind speed at a height of 10 m, WS , and the real power output of the turbine, P_w , all recorded by the measurement system, is plotted against time in a graph given in the Annex. Here it can be seen at which points in time the turbine is switched on and off and provides an overview of the background noise in relation to the operating noise recorded by the measurement system over the whole period of the measurement. As can be seen, data was captured continuously throughout the whole measurement period. Non-normal background noises occurring in the measurement period, e.g. from aircraft or traffic, were marked during data acquisition to enable their easy omission in the evaluation to follow. The state signal is used to differentiate between periods when the turbine is running and when it is stopped. $State = 3$ depicts a running turbine, $state = 0.5$ depicts a stopped turbine, and $state = 0$ marks the data to be omitted in the evaluation.

The noise produced by the turbine alone $L_{Aeq,c}$ at wind speeds of 6, 7, 8, 9 and 10 m/s is then determined by converting the dB levels of background and in-service noise to intensities, performing a subtraction and converting back again to dB. In order to determine this, regression curves of the measured sound pressure level with the turbine both running and stopped, plotted with respect to the standardised wind speed at a height of 10 m are required. The wind speed measured during the background noise measurement is multiplied by the factor κ , which is defined as the following:

$$\kappa = \frac{V_s}{V_z}$$

where,

V_s is the standardised wind speed

V_z is the measured wind speed.

For this measurement, $\kappa = 0,93$.

The results of this regression analysis are given in the Annex. All relevant sound pressure level values are given in the annex.

Remark: The data have been analysed using a fourth order regression because this is the best fitting approximation through all the relevant data points. In accordance with [IEC 61400-11] the data have also been analysed using a second order regression which is given in the annex only for information purposes. The sound levels resulting from the higher order regression have been applied in the third octave analysis.



3.3 Sound power level of the turbine

In accordance with [IEC 61400-11] the sound power level $L_{WA,k}$ of the turbine in dB is derived from the corrected sound pressure level $L_{Aeq,c,k}$, at wind speeds between 6 and 10 m/s at a height of 10 m, using the following formula:

$$L_{WA,k} = L_{Aeq,c,k} - 6 + 10 \cdot \lg\left(\frac{4 \cdot \pi \cdot R_1^2}{S_0}\right)$$

where, 6 dB is the correction due to the doubled sound pressure sensed by the microphone caused by coherent interference at the acoustically hard board.

$10 \cdot \lg\left(\frac{4 \cdot \pi \cdot R_1^2}{S_0}\right)$ = the ratio in dB of the surface area of a sphere having the radius R_1 to the reference surface area of S_0

where,

$$S_0 = 1 \text{ m}^2$$

$$R_1 = \sqrt{(R_0 + d)^2 + (H - h_A)^2}$$

R_0 = distance between tower centre and microphone position

d = distance between tower centre and rotor flange middle point

H = hub-height above ground level

h_A = height of microphone

The following results are given in the Annex:

- A graph showing regressions through all the measured wind turbine sound data L_{Aeq} and background noise data L_n .
- A plot of the background corrected normalised values of L_{WA} against the standardised wind speed.
- A plot of L_{Aeq} and L_n against measured wind speed.
- A plot of L_{Aeq} against power.
- A plot of rotor speed against power.
- A time plot of the measurement.

For the Siemens 2.3 MW Mk II in the present configuration the real power output and the apparent sound power levels are given in table 4.

3.4 Tonal and frequency analyses

In accordance with the technical guideline [IEC 61400-11] a tonal analysis has to be carried out. The frequency spectrum of the noise, which is measured on the acoustically hard board, is determined on the basis of a narrow band analysis by means of the FFT-analyser B&K 2144. This analysis was performed after the measurements using the audio signal recorded on a DAT-recorder.



The results of the tonal analysis of the Siemens 2.3 MW Mk II according to [IEC 61400-11] are given in table 4.

3.5 3rd octave analysis

The A-weighted sound spectra at all the integer wind speeds are given in the Annex.



3.6 Uncertainties

3.6.1 Sound power level

The result of the sound power level measurement is subject to uncertainties which are due to the environment, meteorological conditions and the measurement system. For these measurements all the type B measurement uncertainty components as specified in the technical guideline [IEC 61400-11] are given in Table 3. For all of the type B uncertainties mentioned here, a rectangular distribution of possible values is assumed for simplicity with a range described as “ $\pm a$ ”. The standard deviation for such a distribution is:

$$U = \frac{a}{\sqrt{3}}$$

Table 3: Type B measurement uncertainty components

Component	Range [dB]	Uncertainty [dB]
Calibration, U_{B1}	$\pm 0,2$	0,12
Chain of acoustic measurement instruments, U_{B2}	$\pm 0,4$	0,23
Acoustically hard board, U_{B3}	$\pm 0,5$	0,29
Distance measurement, U_{B4}	$\pm 0,1$	0,06
Acoustic impedance of air, U_{B5}	$\pm 0,2$	0,12
Meteorological variation (including turbulence), U_{B6}	$\pm 0,7$	0,40
Wind speed derived from the power curve, U_{B7}	$\pm 0,3$	0,17
Wind direction, U_{B8}	$\pm 0,5$	0,29
$\sum_{i=1}^8 U_{Bi}^2$		0,44

The error in the background correction U_{B9} in dB has been calculated for each integer wind speed as follows:

$$U_{B9} = L_{Aeq,c,k} - \left[10 \cdot \log \left(10^{0,1 \cdot L_{Aeq,k}} - 10^{0,1 \cdot (L_n + U_{HG})} \right) \right]$$

where U_{HG} is the error in the background noise in dB defined as follows:



$$U_{HG} = \sqrt{\frac{(y_n - y_{n,est})^2}{N_n - 2}}$$

where:

- y_n = measured sound pressure level of background noise in dB
- $y_{n,est}$ = estimated sound pressure level of background noise from the regression analysis in dB
- N_n = number of background noise measurement values in the wind speed bin corresponding to the integer wind speed.

The combined measurement uncertainty U_C relating to the sound power level $L_{WA,k}$ is calculated as follows:

$$U_C = \sqrt{U_A^2 + U_{B9}^2 + \sum_{i=1}^8 U_{Bi}^2}$$

where:

$$U_A = \sqrt{\frac{\sum (y - y_{est})^2}{N - 2}}$$

where:

- y = measured sound pressure level of total noise (operating plus background) in dB
- y_{est} = estimated sound pressure level of total noise from the regression analysis in dB
- N = number of total noise measurement values in the wind speed bin corresponding to the integer wind speed.

All values for U_A , U_{B9} and U_C are given in the annex.

3.6.2 One-third octave band spectra

The uncertainty in the one-third octave band spectra is given in the Annex for all the third octave bands.

3.6.3 Tonality

The uncertainty in the tonality is given in the Annex for all the given tones.

4 Summary

As ordered by Siemens Wind Power A/S, 7330 Brande, Denmark, WINDTEST Kaiser-Wilhelm-Koog GmbH took measurements of the acoustic noise emissions on the Siemens WTGS 2.3 MW Mk II with a hub height of 80 m.



All measurements and analyses of the sound power level and tonality described in this report were made on the basis of the technical guideline [IEC 61400-11]. The analysis of the sound power level was carried out using the standardised wind speed which was calculated from the power curve provided by the customer (see Annex).

The data on the Siemens WTGS 2.3 MW Mk II have been evaluated by using a fourth order regression because this is the best fitting approximation over all relevant points.

The results of this measurement are given in table 4.

Table 4: Summary of results

wind speed in 10 m height [m/s]	6	7	8	9	10
electrical power output calculated from the power curve [kW]	1049	1651	2106	2260	2295
measured pitch angle [degrees]	-0,8	-0,8	-0,8	0	>1
measured rotor speed [min⁻¹]	15,1	15,3	15,4	15,8	16,0
sound power level [dB]	103,4	104,9	105,1	105,0	105,0
combined uncertainty in the sound power level, U_c [dB]	1,2	1,1	1,2	1,3	1,3
tonality, ΔL_k [dB]	-5,58	-4,68	-6,36	-5,43	-5,91
tonal audibility, $\Delta L_{a,k}$ [dB]	-2,58	-1,69	-3,36	-2,43	-3,58
frequency of the most prevalent tone [Hz]	1200	1200	1200	1200	530

It is assured that this report has been drawn up impartially in accordance with state-of-the-art science and technology and with best knowledge and conscience.



5 List of employed symbols and abbreviations

d	- distance from rotor centre to tower axis	m
D	- rotor diameter	m
$\Delta L_{tn,j,k}$	- tonality of the 'j th' spectrum at 'k th' wind speed, where $j = 1$ to 12 and $k = 6, 7, 8, 9, 10$	dB
ΔL_k	- energetic average of the 12 $\Delta L_{tn,j,k}$	dB
$\Delta L_{a,k}$	- tonal audibility	dB
f	- frequency of the tone	Hz
f_c	- centre frequency of critical band	Hz
H	- height of rotor centre (horizontal axis turbine) or height of rotor equatorial plane (vertical axis turbine) above local ground near the wind turbine	m
h_A	- location point height (in measurement equal to microphone height)	m
κ	- the ratio between standardised wind speed and measured wind speed	-
L_A or L_C	- A or C-weighted sound pressure level	dB
$L_{Aeq,k}$	- equivalent continuous A-weighted sound pressure level, where $k = 6, 7, 8, 9, 10$	dB
$L_{Aeq,c,k}$	- equivalent continuous A-weighted sound pressure level corrected for background noise at each integer wind speed and corrected to reference conditions, where $k = 6, 7, 8, 9, 10$	dB
L_n	- equivalent continuous sound pressure level level of the background noise	dB
L_p	- sound pressure level	dB
$L_{pn,j,k}$	- sound pressure level of masking noise within a critical band in the 'j th' spectrum at the 'k th' wind speed, where $j = 1$ to 12 and $k = 6, 7, 8, 9, 10$	dB
$L_{pn,avg,j,k}$	- average of analysis bandwidth sound pressure levels of masking noise in the 'j th' spectrum at the 'k th' wind speed, where $j = 1$ to 12 and $k = 6, 7, 8, 9, 10$	dB
$L_{pt,j,k}$	- sound pressure level of the tone or tones in the 'j th' spectrum at the 'k th' wind speed, where $j = 1$ to 12 and $k = 6, 7, 8, 9, 10$	dB
L_s	- equivalent continuous sound pressure level of only wind turbine noise	dB
L_{s+n}	- equivalent continuous sound pressure level of combined wind turbine and background noise	dB
$L_{WA,k}$	- apparent sound power level, where $k = 6, 7, 8, 9, 10$	dB
N	- Number of measured values	-
P_W	- effective electrical power	kW
R_0	- reference distance	m
R_i	- slant distance from rotor centre to actual measurement position	m
S_0	- reference area, $S_0 = 1 \text{ m}^2$	m
U_A, U_B	- Uncertainty components	dB
U_C	- Total uncertainty	dB
U_{HG}	- Error in the background noise	dB
V_m	- derived wind speed from power curve	m/s
V_S	- standardised wind speed	m/s
WTGS	- wind turbine generator system	-
y	- measured sound pressure level of operating plus background noise	dB
y_{est}	- estimated sound pressure level of operating plus background noise from the regression analysis	dB



6 References


[IEC 61400-11] IEC 61400-11, Wind turbine generator systems - Part 11: Acoustic noise measurement techniques, Ed. 2.


7 Annex



Annex 1: Measuring equipment used

Beschreibung description	Fabrikat supplier	Typ/type	WT Nr./Ser.Nr. WT stock number/serial number	Kal. am cal. on	Eichung am standardisation	Einsatz used
Akustischer Kalibrator acoustic calibrator	Brüel & Kjær	4231	WT 300083004 (2438819)	-	31.12.2006	x
Mikrofon microphone	Brüel & Kjær	4188	zu WT 30002904 (2427565)	-	31.12.2006	x
Vorverstärker preamplifier	Brüel & Kjær	ZC 0030	zu WT 30002904	-	31.12.2006	x
Mikrofonkabel microphone cable	Brüel & Kjær	AO 0560	zu WT 30002904	-	31.12.2006	x
Handschallpegelmessgerät decibel meter	Brüel & Kjær	2238	WT 30002904 (2437622)	-	31.12.2006	x
Primärwindschirm primary wind shield	Brüel & Kjær	UA 0237	-	-	-	x
Sekundärwindschirm secondary wind shield	Delta Acoustics	SIM	-	-	-	
DAT-Rekorder DAT-recorder	Sony	TCD-D100	WT 300083304 (541959)	-	-	x
Anemometer anemometer	Thies Clima	4.3519.00.000	WT 010041504 (PN 457 0604)	Jun. 04	-	x
Windrichtungsgeber wind direction sensor	Thies Clima	4.3129.00.012	WT 020013504 (0504426)	-	-	x
Temperaturgeber temperature sensors	Heraeus (Logger)	PT100	WT 300084704	Jul. 05	-	x
Temperaturgeber temperature sensors	Heraeus (W+W)	PT100	WT 300084604	Jul. 05	-	x
Luftdruckgeber pressure sensors	Wilms Messtechnik (Logger)	0619	WT 090021803	Jul. 05	-	x
Luftdruckgeber pressure sensors	Wilms Messtechnik (W+W)	0619	WT 090022804	Jul. 05	-	x
Leistungsumformer power transducer	Metrawatt (DME 1)	SINEAX DME 442	WT 300070903	Jun. 04	-	
Leistungsumformer power transducer	Metrawatt (DME 2)	SINEAX DME 442	WT 300055202	Aug. 03	-	
Leistungsumformer power transducer	Metrawatt (DME 3)	SINEAX DME 442	WT 300018898	Feb. 05	-	
Leistungsumformer power transducer	Metrawatt (DME 4)	SINEAX DME 442	WT 300079804	Feb. 05	-	
Zangenstromwandler current clamps	Chauvin Arnoux (DME 1)	D32N	WT 300071603 bis 300071803	Jul. 05	-	
Zangenstromwandler current clamps	Chauvin Arnoux (DME 2)	D32N	WT 300053501 bis 300053701	Jul. 05	-	
Zangenstromwandler current clamps	Chauvin Arnoux (DME 3)	AmpFLEX A100	WT 300091804 bis 300092004	Jul. 05	-	
Zangenstromwandler current clamps	Chauvin Arnoux (DME 4)	AmpFLEX A100	WT 300085804 bis 300086004	Jul. 05	-	
Datenlogger datalog	Th. Friedrichs	1020	WT 030013504 (091630)	Jul. 04	-	x
Zweikanal-Echtzeit- Frequenzanalysator 2-channel real time frequency analyser	Brüel & Kjær	2144	WT 9904897 (1732981)	Sep. 03	-	x
Erfassungs- und Auswertesoftware data acquisition and analytical software	GFS Aachen Microsoft DATALOG GmbH	DIAdem 8.1 Excel 2000 Dasy-Lab 7.0	-	-	-	x
Erfassungsrechner data acquisition Computer	HP	Compaq nx 9005	WT 400023903 (CNF 3371X4F)	-	-	
Erfassungsrechner data acquisition Computer	HP	OmniBook XE3	WT 400021502 (TW 21806701)	-	-	
Erfassungsrechner data acquisition Computer	HP	OmniBook XE3	WT 400020802 (TW 21121810)	-	-	
Erfassungsrechner data acquisition Computer	HP	Compaq nx 5000	WT 400026604 (CNU43700RT)	-	-	
Erfassungsrechner data acquisition Computer	HP	Compaq nx 9005	WT 400024003 (CNF 3371X70)	-	-	
Erfassungsrechner data acquisition Computer	HP	Compaq nx 9005	WT 400024103 (CNF 3371X4X)	-	-	x
10 m – Teleskopmast 10 m – telescopic mast	Clark (SMS 3)	QT 12M/HP	WT 050019003	-	-	x
Spannungsversorgung uninterruptable power supply	APS	Smart UPS 1000	WT 30009002104	-	-	x

Annex 2.1a: 2nd order regression of L_{Aeq} and L_n against standardised wind speed

Annex 2.1b: Higher order regression of L_{Aeq} and L_n against standardised wind speed



Annex 2.2: Summary of analysis input parameters and results

Parameters of evaluation / Auswerteparameter:

H = 80.0 m d = 3.50 m
D = 93.0 m z₀ = 0.050 m

h_A = 0.0 m P_{rated} / P_{Nenn} = 2.30 MW
R₀ = 112.0 m WS_{95%} / WG_{95%} = 11.67 m/s

Results / Ergebnisse:

WS_{95%(10m)} / WG_{95%(10m)} = 8.38 m/s
Power_{95%} / Leistung_{95%} = 2.185 MW
Range of the wind direction / Windrichtungsbereich = 284.40° - 325.68°
κ = 0.93
average turbulence intensity / mittlere Turbulenzintensität = 14.0 %

WS _{10m} WG _{10m}	U _A [dB]	U _{B1} [dB]	U _C [dB]
6	0.44	0.04	1.2
7	0.31	0.05	1.1
8	0.41	0.08	1.2
9	0.64	0.14	1.3
10	0.68	0.25	1.3

table 1: uncertainty / Tabelle 1: Messunsicherheiten

WS _{10m} WG _{10m}	L _{Aeq,k} [dB]	L _{backgr} [dB]	L _{Aeq,c,k} [dB]	L _{WAK} [dB]
6	55.5	37.9	55.4	103.4
7	57.1	40.2	57.0	104.9
8	57.3	42.6	57.2	105.1
9	57.3	44.9	57.0	105.0
10	57.5	47.3	57.1	105.0

table 2: results L = f(WS) / Tabelle 2: Ergebnisse L = f(WG)

WS _{95%} WG _{95%}	L _{Aeq,k} [dB]	L _{backgr} [dB]	L _{Aeq,c,k} [dB]	L _{WAK} [dB]
8.38	57.3	43.5	57.1	105.1

table 3: results L = f(WS_{95%}) / Tabelle 3: Ergebnisse L = f(WG_{95%})


WINDTEST
Kaiser-Wilhelm-Koog GmbH


Siemens 2.3 MW Mk II


Results / Ergebnisse

Site / Standort:
WTGS-SNr./WEA-SNr.:
Mode / Modus:
Date of meas. / Messdatum:
Standard / Messung:
Data base / Datenbasis:
In charge / Bearbeiter:

Havssø, Denmark
2300439
Standard Mode 2300
2005-08-12/13
IEC 61400-11 Ed. 2
1 Hz sampling
Dipl.-Ing. Joerg Neubert


Annex 2.3: Plot of L_{WA} against standardised wind speed

Annex 2.4: Plot of L_{Aeq} and L_n against measured wind speed

Annex 2.5: Plot of L_{Aeq} against power




Annex 2.6: Plot of rotor speed against power






Annex 2.7: Time plot of measurement






Annex 3.1a: Overview spectra 1-6 of turbine noise at a wind speed of 6 m/s





Annex 3.1b: Overview spectra 7-12 of turbine noise at a wind speed of 6 m/s





Annex 3.1c: Analysis of tonality of turbine noise at a wind speed of 6 m/s

Source file: Ton_Sm_1EC_8											
Graphic file: e1_delta_Leq.WG											
07.08.2005											
m No.	tone f [Hz]	delta f [Hz]	L _{pn,avg} ,k [dB]	L _{pt} ,k [dB]	L _{pn} ,k [dB]	delta L _{tn} ,k [dB]	L _a [dB]	delta L _a ,k [dB]			
1	1204	2.00	19.36	33.06	37.29	-4.23	-3.00	-1.24			
2	1204	2.00	20.40	33.91	38.33	-4.42	-3.00	-1.43			
3	1204	2.00	20.14	31.73	38.07	-6.34	-3.00	-3.35			
4	1204	2.00	20.19	30.86	38.12	-7.26	-3.00	-4.26			
5	1204	2.00	19.57	29.77	37.49	-7.73	-3.00	-4.73			
6	1204	2.00	20.97	30.07	38.90	-8.83	-3.00	-5.83			
7	1204	2.00	19.65	32.98	37.57	-4.59	-3.00	-1.60			
8	1202	2.00	20.35	32.08	38.27	-6.19	-2.99	-3.20			
9	1202	2.00	19.20	31.01	37.12	-6.11	-2.99	-3.12			
10	1204	2.00	18.92	31.62	36.85	-5.22	-3.00	-2.23			
11	1202	2.00	19.38	30.27	37.31	-7.04	-2.99	-4.04			
12	1202	2.00	18.82	34.02	36.74	-2.73	-2.99	0.27			

Energetic average of delta L_t (delta L_k) = -6.58 [dB]

Frequency dependant audibility criterion (L_a) [dB] = -3.00 [dB]

Audibility, delta L_k - L_a (delta L_{a,k}) = -2.58 [dB]

Uncertainty of delta L_{a,k} (U_a) = 2.41 [dB]

Audibility greater than or equal to -3.0 dB ? : Yes



WINDTEST
Kaiser-Wilhelm-Koog GmbH


Siemens 2.3 MW Mk II

Analysis of tonality of turbine noise
Tonhaltigkeitsbewertung des Betriebsgeräusches

Site / Standort: Høvsøre
Measurerm. / Messdatum: 2005-08-12/13
Standard / Messung: IEC 61400-11/Ed 2
Wind speed / Windge: 6 m/s
In charge / Bearbeiter: Dipl.-Ing. Ulf Kock




Annex 3.2a: Overview spectra 1-6 of turbine noise at a wind speed of 7 m/s





Annex 3.2b: Overview spectra 7-12 of turbine noise at a wind speed of 7 m/s





Annex 3.2c: Analysis of tonality of turbine noise at a wind speed of 7 m/s

Source file: Ton_5M_IEC_7											
Graphic file: e_Lt_delta_Leq_MG											
07.08.2005											
m No.	tone f [Hz]	delta f [Hz]	L _{pn,avg} ,k [dB]	L _{pt} ,k [dB]	L _{pn} ,k [dB]	delta L _{tn} ,k [dB]	L _a [dB]	delta L _a ,k [dB]			
1	1204	2.00	20.72	34.72	38.65	-3.93	-3.00	-0.94			
2	1204	2.00	21.03	33.39	38.95	-5.57	-3.00	-2.57			
3	1202	2.00	21.44	35.77	39.36	-3.59	-2.99	-0.60			
4	1204	2.00	21.13	35.80	39.06	-3.26	-3.00	-0.26			
5	1202	2.00	21.86	36.97	39.78	-2.82	-2.99	0.18			
6	1202	2.00	21.88	34.03	39.80	-5.78	-2.99	-2.78			
7	1204	2.00	21.62	30.69	39.55	-8.87	-3.00	-5.87			
8	1204	2.00	22.07	31.40	40.00	-8.60	-3.00	-5.60			
9	1204	2.00	22.34	31.52	40.27	-8.75	-3.00	-5.75			
10	1204	2.00	22.48	35.58	40.41	-4.83	-3.00	-1.83			
11	1202	2.00	22.37	36.62	40.29	-3.68	-2.99	-0.68			
12	1202	2.00	20.90	36.18	38.82	-2.64	-2.99	0.36			

Energetic average of delta L_t (delta L_k) = -4.68 [dB]

Frequency dependant audibility criterion (L_a) [dB] = -3.00 [dB]

Audibility, delta L_k - L_a (delta L_{a,k}) = -1.69 [dB]

Uncertainty of delta L_{a,k} (U_a) = 2.43 [dB]

Audibility greater than or equal to -3.0 dB ? : Yes



WINDTEST
Kaiser-Wilhelm-Koog GmbH

Siemens 2.3 MW Mk II


Analysis of tonality of turbine noise

Tonhaltigkeitsbewertung des Betriebsgeräusches

Site / Standort: Høvsøre
Measurment / Messdatum: 2005-08-12/13
Standard / Messung: IEC 61400-11/Ed 2
Wind speed / Windge: 7 m/s
In charge / Bearbeiter: Dipl.-Ing. Ulf Kock



Annex 3.3a: Overview spectra 1-6 of turbine noise at a wind speed of 8 m/s




Site / Standort: Høvsøre
 Messung / Measurement: 2005-08-12/13
 Standard / Messung: IEC 61400-11/Ed.2
 Wind speed / Windge: 8 m/s
 In charge / Bearbeiter: Dipl.-Ing. Ulf Kock

Siemens 2.3 MW Mk II
 Spectra 1 - 6 of turbine noise
 Übersichtsspektren 1 – 6 des Betriebsgeräusches





Annex 3.3b: Overview spectra 7-12 of turbine noise at a wind speed of 8 m/s





Annex 3.3c: Analysis of tonality of turbine noise at a wind speed of 8 m/s

m No.	tone f [Hz]	delta f [Hz]	L _{pn,avg} ,k [dB]	L _{pt} ,k [dB]	L _{pn} ,k [dB]	delta L _{tn} ,k [dB]	L _a [dB]	delta L _a ,k [dB]
1	1202	2.00	24.17	38.84	42.09	-3.24	-2.99	-0.25
2	1202	2.00	21.96	36.91	39.88	-2.97	-2.99	0.03
3	1202	2.00	23.10	36.78	41.02	-4.24	-2.99	-1.25
4	1202	2.00	25.03	36.71	42.95	-6.25	-2.99	-3.25
5	1202	2.00	25.78	34.91	43.70	-8.78	-2.99	-5.79
6	1202	2.00	25.29	35.47	43.21	-7.74	-2.99	-4.75
7	1202	2.00	22.13	28.51	40.05	-11.54	-2.99	-8.55
8	1202	2.00	20.56	32.53	38.48	-5.95	-2.99	-2.96
9	1204	2.00	21.44	30.29	39.37	-9.08	-3.00	-6.08
10	1202	2.00	21.77	31.03	39.70	-8.67	-2.99	-5.67
11	1202	2.00	22.44	31.96	40.36	-8.41	-2.99	-5.41
12	1204	2.00	21.66	31.46	39.59	-8.13	-3.00	-5.13

Source file: Ton_SM_IEC_9
07.08.2005

Graphic file: e_L_delta_Leq.WG

Energetic average of delta L_t (delta L_k) = -6.36 [dB]

Frequency dependant audibility criterion (L_a) [dB] = -2.99 [dB]

Audibility, delta L_k - L_a (delta L_{a,k}) = -3.36 [dB]

Uncertainty of delta L_{a,k} (U_a) = 2.56 [dB]

Audibility greater than or equal to -3.0 dB ? : No



WINDTEST
Kaiser-Wilhelm-Koog GmbH


Siemens 2.3 MW Mk II

Analysis of tonality of turbine noise
Tonhaltigkeitsbewertung des Betriebsgeräusches

Site / Standort: Høvsøre
Measur. / Messdatum: 2005-08-12/13
Standard / Messung: IEC 61400-11/Ed 2
Wind speed / Windge: 8 m/s
In charge / Bearbeiter: Dipl.-Ing. Ulf Kock




Annex 3.4a: Overview spectra 1-6 of turbine noise at a wind speed of 9 m/s





Annex 3.4b: Overview spectra 7-12 of turbine noise at a wind speed of 9 m/s





Annex 3.4c: Analysis of tonality of turbine noise at a wind speed of 9 m/s

m No.	tone fT [Hz]	delta f [Hz]	Lpn,avg,k [dB]	LpT,k [dB]	Lpn,k [dB]	delta Ltn,k [dB]	La [dB]	delta La,k [dB]
1	1202	2.00	21.21	34.04	39.13	-5.09	-2.99	-2.09
2	1202	2.00	22.59	36.23	40.51	-4.28	-2.99	-1.29
3	1202	2.00	21.36	34.35	39.28	-4.93	-2.99	-1.94
4	1204	2.00	21.53	33.98	39.46	-5.48	-3.00	-2.48
5	1202	2.00	21.56	34.35	39.48	-5.13	-2.99	-2.14
6	1202	2.00	21.44	35.08	39.36	-4.28	-2.99	-1.28
7	1202	2.00	22.59	34.75	40.52	-5.76	-2.99	-2.77
8	1202	2.00	21.53	32.08	39.45	-7.37	-2.99	-4.37
9	1202	2.00	22.20	31.49	40.12	-8.63	-2.99	-5.64
10	1202	2.00	24.50	36.83	42.42	-5.59	-2.99	-2.60
11	1202	2.00	25.28	38.67	43.20	-4.54	-2.99	-1.54
12	1202	2.00	26.09	38.16	44.01	-5.85	-2.99	-2.86

Energetic average of delta Lt (delta Lk) = -6.43 [dB]
Frequency dependant audibility criterion (La) [dB] = -2.99 [dB]
Audibility, delta Lk - La (delta La,k) = -2.43 [dB]
Uncertainty of delta La,k (Ua) = 2.32 [dB]
Audibility greater than or equal to -3.0 dB ? : Yes


WINDTEST
Kaiser-Wilhelm-Koog GmbH

Siemens 2.3 MW Mk II
Analysis of tonality of turbine noise
Tonhaltigkeitsbewertung des Betriebsgeräusches

Site / Standort: Høvsøre
 Measur. / Messdatum: 2005-08-12/13
 Standard / Messung: IEC 61400-11/Ed.2
 Wind speed / Windge: 9 m/s
 In charge / Bearbeiter: Dipl.-Ing. Ulf Kock




Annex 3.5a: Overview spectra 1-6 of turbine noise at a wind speed of 10 m/s





Annex 3.5b: Overview spectra 7-12 of turbine noise at a wind speed of 10 m/s





Annex 3.5c: Analysis of tonality of turbine noise at a wind speed of 10 m/s

m No.	tone fT [Hz]	delta f [Hz]	L _{pn,avg} ,k [dB]	L _{pt} ,k [dB]	L _{pn} ,k [dB]	delta L _{tn} ,k [dB]	L _a [dB]	delta L _a ,k [dB]
1	536	2.00	31.80		47.81	-16.01	-2.34	-13.67
2	520	2.00	31.72		47.69	-15.97	-2.32	-13.65
3	540	2.00	31.75		47.77	-16.02	-2.34	-13.68
4	526	2.00	30.81	41.35	46.79	-5.44	-2.33	-3.12
5	534	2.00	31.98		47.99	-16.00	-2.34	-13.67
6	524	2.00	31.25		47.23	-15.98	-2.32	-13.65
7	534	2.00	31.08	43.89	47.08	-3.19	-2.34	-0.85
8	530	2.00	31.00	39.38	47.00	-7.62	-2.33	-5.29
9	528	2.00	31.53	40.32	47.52	-7.20	-2.33	-4.87
10	530	2.00	31.04	42.17	47.03	-4.87	-2.33	-2.53
11	526	2.00	31.04	44.67	47.03	-2.36	-2.33	-0.03
12	534	2.00	30.39	45.01	46.39	-0.39	-2.34	1.95

Source file Ton_3M_IEC_52Hz_10
Graphic file t_5M_IEC_52Hz_10

07 08 2005

Energetic average of delta L_t (delta L_k) = -6.91 [dB]

Frequency dependant audibility criterion (L_a) [dB] = -2.33 [dB]

Audibility, delta L_k - L_a (delta L_{a,k}) = -3.58 [dB]

Uncertainty of delta L_{a,k} (U_a) = 3.13 [dB]

Audibility greater than or equal to -3.0 dB ? : No



WINDTEST
Kaiser-Wilhelm-Koog GmbH

Siemens 2.3 MW Mk II


Analysis of tonality of turbine noise

Tonhaltigkeitsbewertung des Betriebsgeräusches

Site / Standort: Havsøre
Measurim. / Messdatum: 2005-08-12/13
Standard / Messung: IEC 61400-11/Ed.2
Wind speed / Windge: 10 m/s
In charge / Bearbeiter: Dipl.-Ing. Ulf Kock




Annex 4.1: A-weighted sound pressure 1/3-octave spectrum at 6 m/s






Annex 4.2: A-weighted sound pressure 1/3-octave spectrum at 7 m/s






Annex 4.3: A-weighted sound pressure 1/3-octave spectrum at 8 m/s






Annex 4.4: A-weighted sound pressure 1/3-octave spectrum at 9 m/s






Annex 4.5: A-weighted sound pressure 1/3-octave spectrum at 10 m/s





Annex 5: Photos



Picture from the board in direction of the WTGS



Annex 5: Photos



Picture of microphone and board




Annex 6: Power curve used in the analysis

PP 2.3 MW Mk II, 1.225 kg/m³ / 30-06-2004

Bonus 2.3 MW Mk II, 1.225 kg/m³ Sales Power Curve, Preliminary


The calculated power curve data are valid for the above air density conditions, clean rotor blades, and horizontal, undisturbed air flow with 10% turbulence intensity.

Wind [m/s]	Power [kW]
0	0
1	0
2	0
3	0
4	65
5	180
6	352
7	590
8	906
9	1308
10	1767
11	2085
12	2234
13	2283
14	2296
15	2299
16	2300
17	2300
18	2300
19	2300
20	2300
21	2300
22	2300
23	2300
24	2300
25	2300



The annual energy production data for different annual mean wind speeds in hub height are calculated from the above power curve assuming a Rayleigh wind speed distribution, 100 percent availability, and no reductions due to array losses, grid losses, or other external factors affecting the production.

Wind [m/s]	Energy [MWh]
5.0	3238
5.5	4179
6.0	5134
6.5	6089
7.0	7037
7.5	7926
8.0	8792
8.5	9580
9.0	10324
9.5	11002
10.0	11616





Annex 7a: Manufacturer's certificate, page 1/2

Herstellerbescheinigung zu spezifischen Daten der Anlage vom Typ Manufacturer's certificate on specific data of the type of installation

Datum / date: 22/08/2005

1. Allgemeines		General
Hersteller	Siemens Wind Power A/S	manufacturer
Anlagenbezeichnung	2.3 MW mkII	type name
Art (horizontale/vertikale Achse)	Horizontal	type (horizontal / vertical axis)
Nennleistung	2300 kW	rated power
Nabenhöhe über Grund	80 m	hub height above ground
Nabenhöhe über Fundamentflansch	80 m	hub height above top of foundation flange
Nennwindgeschwindigkeit	12 m/s	rated wind speed
Ein- und Ausschaltwindgeschwindigkeit	3/25 m/s	cut-in and cut-out wind speed
Beitrag zum Kurzschlussstrom	appr. 2.5 kA	contribution to short circuit current
2. Rotor		Rotor
Durchmesser	92.4 m	diameter
Bestrichene Fläche	6706 m²	swept area
Anzahl der Blätter	3	number of blades
Nabenart (pendelnd/starr)	Rigid	kind of hub (teetered/rigid)
Anordnung zum Turm (luv/lee)	Luv	relative position to tower (luv/lee)
Nennndrehzahl / -bereich	6,1-18,4 U/min / rpm	rated speed / speed range
Auslegungsschnellaufzahl	—	design tip speed ratio
Rotorblatteinstellwinkel	-2 to 82° Pitch controlled	rotor blade pitch setting
Konuswinkel	2°	cone angle
Achsneigung	6°	tilt angle
Abstand Rotorflanschmittelpunkt - Turmmittellinie	3.5 m	distance between rotor flange centre and tower centre line
3. Blatt		Blade
Hersteller	Siemens Wind Power A/S	manufacturer
Typenbezeichnung	B45	type
Profile innen/außen	FFAW3/ NACA63-6xx	blade section inner/outer
Material	GRE	material
Länge	45 m	length
Profiltiefe max./min.	3.35 m/ 0.7 m	chord length (max./min.)
Zusatzkomponenten (z.B. stall strips, Vortex-Generatoren, Turbulatoren)	Vortex generator	additional components (e.g. stall strips, vortex generators, trip strips)
Extenderlänge	N/A	extender length
4. Getriebe		Gear
Hersteller	Flender	manufacturer
Typenbezeichnung	PEAB 4456	type
Ausführung	Planetary/helical	design
Übersetzungsverhältnis	1 : 90.84	speed ratio
5. Generator		Generator
Hersteller	ABB	manufacturer
Typenbezeichnung	AMA500L4A	type
Anzahl	1	numbers
Art	Asynchronous	design
Nennleistung(en)	2400 kW	rated power (s)
Nennscheinleistung	2690 kVA	rated apparent power
Nennndrehzahlen oder Drehzahlbereich	600-1800 1/min rpm	rated speed (s)/ speed range
Spannung	750 V @1550rpm	voltage
Frequenz	20-60 Hz	frequency
Nennschlupf	%	rated slip
6. Turm		Tower
Hersteller		manufacturer
Typenbezeichnung	DSSM04	type
Ausführung (Gitter/Rohr, zyl./kon.)	Tapered tubular	design (lattice/tubular, cylindrical/ conical)
Material	S355	material
Länge	78 m	length



Annex 7b: Manufacturer's certificate, page 2

7. Windrichtungsnachführung		Yaw control
Ausführung (aktiv/Passiv)	Active	design (active/passive)
Antriebsart (el./mech./hydr.)	Electrical	drive (electr./mech./hydr.)
Dämpfungssystem während des Betriebes	Friction	damping system during operation
8. Betriebsführung/ Regelung		Other electric installations
Art der Leistungsregelung	Pitch control	kind of power control
Antrieb der Leistungsregelung	Blade pitch	actuation of power control
Hersteller der Betriebsführung/ Regelung	KK-electronic	manufacturer of control system
- Typenbezeichnung	WTC 3	- type
- Verwendete Steuerungskurve		- applied used control characteristics
9. Sonstige elektrische Komponenten		Other electric installations
Anzahl der Kompensationsstufen	Controlled by use of 4 quadrant frequency converter	number of compensation stages
Blindleistung Stufe 1	___ kvar	reactive power stage 1
Art der Netzkopplung	Connected by use of frequency conv.	kind of interconnection
- Hersteller	Alstom	- manufacturer
- Typenbezeichnung	4 quadrant frequency conv.	- type
-		-
Netzschutzhersteller	KK	mains protective manufacturer
- Typenbezeichnung	_____	- type
- Einstellbereiche:		- adjustment ranges:
Spannungssteigerungsschutz	759 V line-line	overvoltage protection
Spannungsrückgangsschutz	621 V line-line for more than 3 sec.	undervoltage protection
Frequenzsteigerungsschutz	51,5 Hz	overfrequency protection
Frequenzrückgangsschutz	47,5 Hz	underfrequency protection
Typenbezeichnung der Abschalteneinheit	Short circuit breaker	type of contact break device
Oberschwingungsfilter (Ja/Nein)	Yes	harmonic filter (yes/no)
(Oberschwingungsfilter müssen auf den Netzverknüpfungspunkt ausgelegt sein.)		(harmonic filter have to be designed for the point of common coupling)
10. Bremssystem		Brake system
Bremssystem (primär/sekundär)	Blade / Mech. brake	brake system (primary/secondary)
- Aktivierung	Hydraulic	- activation
- Anordnung	Hydraulic	- location
- Bremsenart	Pitch blade/ brake disc	- type
- Betätigung	Active / Passive	- actuation
11. Typenprüfung		Type test
Prüfbehörde	DNV	testing authority
Aktenzeichen		reference
12. Informativer Teil		Informative
Standort der vermessenen WEA	Høvsøre DK	location of measured WTGS
Koordinaten des Standorts	_____	coordinate of location
Seriennummer der WEA	2300439	Serial number of WTGS
der Blätter	1001/ 1002/ 1003	blades
des Getriebes	4803384 020-1	gearbox
des Generators	457691	generator
Anschrift des Herstellers	SIEMENS Siemens Wind Power A/S Postbox 171 - Borupvej 16 DK-7330 Brande - Denmark Tel.: +45 9942 2222	
Address of manufacturer	22.8.05 [Signature] Stempel, Unterschrift stamp, signature	

Der Hersteller der Windenergieanlage bestätigt, daß die WEA, deren Schallemission, Leistungskurve und elektrischen Eigenschaften in den Prüfberichten abgebildet ist, hinsichtlich ihrer technischen Daten mit den o.g. Positionen identisch ist.

The manufacturer of the wind turbine generator system confirms that the WTGS whose noise level, power curve and grid compatibility is measured and depicted in the test report xxxxxxx is identical with the above entries with regard to its technical data.

Published by and copyright © 2009:
Siemens AG
Energy Sector
Freyeslebenstrasse 1
91058 Erlangen, Germany

Siemens Wind Power A/S
Borupvej 16
7330 Brande, Denmark
www.siemens.com/wind

For more information, please contact
our Customer Support Center.
Phone: +49 180 524 70 00
Fax: +49 180 524 24 71
(Charges depending on provider)
E-mail: support.energy@siemens.com

Renewable Energy Division
Order No. E50001-W310-A121-X-4A00
Printed in Germany
Dispo 34804, c4bs No. 7491
61/19716 L WS 04096.

Printed on elementary chlorine-free
bleached paper.

All rights reserved.
Trademarks mentioned in this document
are the property of Siemens AG, its affiliates,
or their respective owners.

Subject to change without prior notice.
The information in this document contains
general descriptions of the technical options
available, which may not apply in all cases.
The required technical options should therefore
be specified in the contract.

www.siemens.com/energy

The new standard for moderate wind conditions

Siemens Wind Turbine SWT-2.3-101

Answers for energy.

SIEMENS



Your trusted partner

Siemens has been a major driver of innovation in the wind power industry since the early 1980s when wind turbine technology was still in its infancy.

Technology has changed with the times, but Siemens' commitment to providing its customers with proven wind turbine solutions remains the same.

The combination of robust and reliable turbines, highly efficient solutions for power transmission and distribution and a deep understanding of the entire energy market ensures that Siemens will continue to be a leading supplier.

Siemens' record, when it comes to on-time delivery, is impeccable. Long-lasting customer relationships, based on the successful installation of wind turbines, provide for a sound, sustainable and profitable investment.


Drawing on 140 years of experience in the energy sector, a strong focus on renewables and a global network of highly skilled and trained employees, Siemens has proven itself to be a trustworthy and reliable business partner. And will continue to be in the future.



Harvest more energy from sites with moderate wind conditions

The Siemens SWT-2.3-101 turbine is designed to deliver unparalleled performance and reliability, making it especially suited to areas with moderate wind conditions.

Siemens has the right turbines for all wind conditions



The SWT-2.3-101 turbine offers low energy production costs, and joins Siemens' 2.3-MW product family, which has proven availability that is among the highest in the industry. The 101-meter rotor is specifically designed to optimize the energy output in areas with moderate wind conditions. The turbine is also ideal for all types of grid connections in most major markets.

The SWT-2.3-101 is designed to last. The robust and reliable design offers a high yield with low maintenance costs. The turbine is backed by advanced condition monitoring and diagnostics, which constantly examine

the turbine. Any change in a turbine's performance is promptly addressed by an experienced after-sales service team either remotely or in the field.

If you desire a better return on investment and superior availability, take a closer look at the SWT-2.3-101 turbine.



Superior performance gives higher yields

Optimum energy at moderate wind conditions

Harvesting more energy

The SWT-2.3-101 wind turbine is designed to increase the energy returns from sites with moderate wind conditions. Advanced blade technology also allows for quieter operation. The B49 blade with a rotor diameter of 101 meters and pitch regulation optimizes power output and increases control over the energy output.

High availability

Currently, the Siemens fleet of 2.3-MW wind turbines sets the industry standard for availability. The SWT-2.3-101 will build on the reputation for reliability that the market has come to expect from a Siemens Wind turbine.

High yield with minimal maintenance

Siemens optimizes the return on investment in its wind turbines through intelligent maintenance that ensures the turbine to deliver high yield with low operational costs.

The rugged structural design, combined with an automatic lubrication system, internal climate control and a generator system

without slip rings contributes to exceptional reliability. The innovative design of the SWT-2.3-101 allows for longer service intervals.

Superior grid compliance

The Siemens NetConverter® system is designed for maximum flexibility in the turbine's response to voltage and frequency variations, fault ride-through capability and output adjustment. The advanced wind farm control system provides state-of-the-art fleet management.

Proven track record

Siemens has a proven track record of providing reliable turbines that last. The world's first offshore wind farm in Vindeby, Denmark, was installed in 1991 and is still fully operational. In California, Siemens installed over 1,100 turbines between 1983 and 1990, with 97% still in operation today. Siemens takes its commitment to reliability seriously and prides itself on the long lifespan that its turbines have demonstrated.



No compromise on reliability

SWT-2.3-101: Newest member of the extremely reliable product family

Designed for life

Siemens turbines are designed to last. The robust design of the SWT-2.3-101 allows for trouble-free output throughout the complete lifecycle of the turbine.

The blades are made of fiberglass-reinforced epoxy in Siemens' proprietary IntegralBlade® manufacturing process. The blades are cast in one piece in a closed process, which eliminates the traditional weaknesses found at glue joints in other manufacturers' blades. Like the turbine itself, the blades are designed to last.

Climate control within the turbine protects vital equipment from the outside environment. The turbine also offers controlled-wear strategies for critical components, which results in a further reduction of maintenance costs.

Safety first

Safety is at the heart of all Siemens operations. From production to installation, operation and service, Siemens strives to set the standard in safety.

The fail-to-safe capabilities within a turbine, combined with Siemens' superior lightning protection system, are designed to enhance security for the turbine.

Advanced operations support


Given the logistical challenges associated with servicing wind farms, Siemens has equipped its turbines with a Turbine Condition Monitoring (TCM) system that reduces the need for on-site servicing.

Continuous monitoring of turbines allows for the discovery of small faults before they become major problems.

The TCM system continuously checks the external and internal condition of the wind turbine. Twenty-four hours a day, seven days a week precise measurements are taken of vibrations in the gear-box, the generator and the main shaft bearings. The system instantly detects deviations from normal operating conditions.

Using the knowledge gained from monitoring thousands of turbines over the years, Siemens' experts are exceptionally skilled at analyzing and predicting faults within a turbine. This allows Siemens to proactively plan the service and maintenance of the turbines as each fault can be categorized and prioritized based on the severity of the fault. Siemens can then determine the most appropriate course of action to keep the turbine running at its best.

Technical specifications




Rotor	
Diameter	101 m
Swept area	8,000 m ²
Rotor speed	6-16 rpm
Power regulation	Pitch regulation with variable speed
Blades	
Type	B49
Length	49 m
Aerodynamic brake	
Type	Full-span pitching
Activation	Active, hydraulic
Transmission system	
Gearbox type	3-stage planetary/helical
Gearbox ratio	1:91
Gearbox oil filtering	Inline and offline
Gearbox cooling	Separate oil cooler
Oil volume	Approximately 400 l
Mechanical brake	
Type	Hydraulic disc brake

Generator	
Type	Asynchronous
Nominal power	2,300 kW
Voltage	690 V
Cooling system	Integrated heat exchanger
Yaw system	
Type	Active
Monitoring system	
SCADA system	WebWPS
Remote control	Full turbine control
Tower	
Type	Cylindrical and/or tapered tubular
Hub height	80 m or site-specific
Operational data	
Cut-in wind speed	3-4 m/s
Rated power at	12-13 m/s
Cut-out wind speed	25 m/s
Maximum 3 s gust	55 m/s (standard version) 60 m/s (IEC version)
Weights	
Rotor	62 tons
Nacelle	82 tons
Tower for 80-m hub height	162 tons

Sales power curve

The calculated power curve data are valid for standard conditions of 15 degrees Celsius air temperature, 1013 hPa air pressure and 1.225 kg/m³ air density, clean rotor blades and horizontal, undisturbed air flow. The calculated curve data are preliminary.



Nacelle arrangement

- | | |
|--------------------|----------------------------|
| 1. Spinner | 10. Coupling |
| 2. Spinner bracket | 11. Generator |
| 3. Blade | 12. Service crane |
| 4. Pitch bearing | 13. Meteorological sensors |
| 5. Rotor hub | 14. Tower |
| 6. Main bearing | 15. Yaw ring |
| 7. Main shaft | 16. Yaw gear |
| 8. Gearbox | 17. Nacelle bedplate |
| 9. Brake disc | 18. Oil filter |
| | 19. Canopy |
| | 20. Generator fan |

SWT-2.221-101 Low Noise, Hub Height 99.5 m Acoustic Emission

Sound Power Levels

The warranted sound power levels are presented with reference to the code IEC 61400-11:2002 with amendment 1 dated 2006-05 based on a hub height of 99.5 m and a roughness length of 1.661 m as described in the IEC code. The sound power levels (L_{wa}) presented are valid for the corresponding wind speeds referenced to a height of 10 m above ground level.

Wind speed [m/s]	4	5	6	7	8	9	10	11	12	Up to cut-out
Sound Power Level	105.0	105.0	105.0	105.0	105.0	105.0	105.0	105.0	105.0	105.0

Table 1: Noise emission, L_{wa} [dB(A) re 1 pW]

Typical Octave Band

Typical, not warranted octave band spectra are tabulated below for 6 and 8 m/s referenced to 10 m height.

Octave band, centre frequency [Hz]	63	125	250	500	1000	2000	4000	8000
Sound Power Level	82.6	93.8	97.0	99.5	99.6	97.1	89.3	84.9

Table 2: Typical octave band for 6 m/s

Octave band, centre frequency [Hz]	63	125	250	500	1000	2000	4000	8000
Sound Power Level	82.4	93.0	96.0	99.8	100.1	96.5	89.6	85.7

Table 3: Typical octave band for 8 m/s

SWT-2.126-101 Low Noise, Hub Height 99.5 m Acoustic Emission

Sound Power Levels

The warranted sound power levels are presented with reference to the code IEC 61400-11:2002 with amendment 1 dated 2006-05 based on a hub height of 99.5 m and a roughness length of 1.800 m as described in the IEC code. The sound power levels (L_{wa}) presented are valid for the corresponding wind speeds referenced to a height of 10 m above ground level.

Wind speed [m/s]	4	5	6	7	8	9	10	11	12	Up to cut-out
Sound Power Level	104.0	104.0	104.0	104.0	104.0	104.0	104.0	104.0	104.0	104.0

Table 1: Noise emission, L_{wa} [dB(A) re 1 pW]

Typical Octave Band


Typical, not warranted octave band spectra are tabulated below for 6 and 8 m/s referenced to 10 m height.

Octave band, centre frequency [Hz]	63	125	250	500	1000	2000	4000	8000
Sound Power Level	83.1	94.1	96.6	97.8	97.9	96.5	88.4	84.0

Table 2: Typical octave band for 6 m/s

Octave band, centre frequency [Hz]	63	125	250	500	1000	2000	4000	8000
Sound Power Level	82.2	92.5	94.8	98.5	99.1	95.5	89.0	85.1

Table 3: Typical octave band for 8 m/s




			Vægt ca.: Weight app.:	Matr.: Matr.:
			Emne: Part:	
			Opstalt SWT-2.3-101 Elevation SWT-2.3-101	Tegn. format: Draw. format: A2
			Dette dokument må ikke kopieres eller gøres tilgængeligt for tredjemand uden vor skriftlig tilladelse. Indholdet må kun benyttes som aftalt med os. Overtrædelse af dette vil medføre retsforfølgelse. Siemens Wind Power A/S This document must not be copied or made available to any third party without our written permission. The contents must be used only as agreed with us. Breach of the above will cause legal action. Siemens Wind Power A/S	Tegn. skala/Draw. scale: 1:500
030209	30373	AWO/HAS	Siemens Wind Power A/S Borupvej 16 DK-7330 Brande Tel. +45 9942 2222	Tegn. nr./Draw. no.: 1005651
Dato: Date:	ECN nr.: ECN no.:	Init: Init:		

Attachment B

Turbine Locations

Turbine ID	UTM_X	UTM_Y	DATUM
1	607287	4746785	NAD83, UTM Zone 17
2	605035	4746639	NAD83, UTM Zone 17
3	606942	4746830	NAD83, UTM Zone 17
4	604861	4746993	NAD83, UTM Zone 17
5	602757	4745791	NAD83, UTM Zone 17
6	606513	4747319	NAD83, UTM Zone 17
7	608495	4747949	NAD83, UTM Zone 17
8	607477	4747512	NAD83, UTM Zone 17
9	600290	4745005	NAD83, UTM Zone 17
10	593994	4748442	NAD83, UTM Zone 17
11	603472	4748075	NAD83, UTM Zone 17
12	601479	4747111	NAD83, UTM Zone 17
13	594663	4751618	NAD83, UTM Zone 17
14	603952	4750047	NAD83, UTM Zone 17
15	608232	4749798	NAD83, UTM Zone 17
16	594352	4749960	NAD83, UTM Zone 17
17	598648	4747922	NAD83, UTM Zone 17
18	587941	4753452	NAD83, UTM Zone 17
19	606366	4749368	NAD83, UTM Zone 17
20	592573	4749463	NAD83, UTM Zone 17
21	602692	4746290	NAD83, UTM Zone 17
22	601756	4751401	NAD83, UTM Zone 17
23	591178	4751634	NAD83, UTM Zone 17
24	592280	4749799	NAD83, UTM Zone 17
25	599133	4750265	NAD83, UTM Zone 17
26	607589	4749481	NAD83, UTM Zone 17
27	598999	4748313	NAD83, UTM Zone 17
28	591339	4752273	NAD83, UTM Zone 17
29	599967	4750467	NAD83, UTM Zone 17
30	606959	4749603	NAD83, UTM Zone 17
33	589588	4755581	NAD83, UTM Zone 17
34	589790	4753921	NAD83, UTM Zone 17
35	602880	4749652	NAD83, UTM Zone 17
36	590002	4755767	NAD83, UTM Zone 17
37	602481	4749039	NAD83, UTM Zone 17
38	602608	4749469	NAD83, UTM Zone 17
39	603875	4749401	NAD83, UTM Zone 17
40	604239	4749614	NAD83, UTM Zone 17
41	590395	4753879	NAD83, UTM Zone 17
42	600381	4750377	NAD83, UTM Zone 17
43	588466	4752970	NAD83, UTM Zone 17
44	599489	4748483	NAD83, UTM Zone 17
45	590085	4753880	NAD83, UTM Zone 17
46	590582	4751836	NAD83, UTM Zone 17
47	604740	4750499	NAD83, UTM Zone 17
48	594126	4750504	NAD83, UTM Zone 17

49	608750	4749784	NAD83, UTM Zone 17
50	609091	4749844	NAD83, UTM Zone 17
51	601762	4745085	NAD83, UTM Zone 17
52	599708	4748016	NAD83, UTM Zone 17
53	600301	4748359	NAD83, UTM Zone 17
54	607370	4746400	NAD83, UTM Zone 17
55	600136	4746677	NAD83, UTM Zone 17
56	598675	4750335	NAD83, UTM Zone 17
57	606650	4751283	NAD83, UTM Zone 17
58	589733	4750362	NAD83, UTM Zone 17
59	614355	4748118	NAD83, UTM Zone 17
60	614974	4747470	NAD83, UTM Zone 17
61	614326	4747732	NAD83, UTM Zone 17
62	614680	4748176	NAD83, UTM Zone 17
63	614750	4747811	NAD83, UTM Zone 17
64	614705	4747338	NAD83, UTM Zone 17
65	611480	4747403	NAD83, UTM Zone 17
66	611758	4747387	NAD83, UTM Zone 17
67	612236	4747633	NAD83, UTM Zone 17
68	602131	4748909	NAD83, UTM Zone 17
69	606923	4747368	NAD83, UTM Zone 17



June 2011
160960577

Legend

- | | |
|-------------------------|-------------------------------|
| Samsung GREP Turbine | Noise Receptor |
| Other Proponent Turbine | Participant |
| Road | Receptor |
| Property Boundary | Vacant Lot Surrogate Receptor |
| Conservation Area | |
| Provincial Park | |
| Waterbody | |

Notes

1. Coordinate System: UTM NAD 83 - Zone 17.
2. Data Sources: Ontario Ministry of Natural Resources © Queens Printer Ontario, 2009; © Samsung, 2010; © NextEra, 2010; © Zephyr North, 2010.

Client/Project
SAMSUNG, PATTERN & KEPKO (SPK)
GRAND RENEWABLE ENERGY PARK

Figure No.
DRAFT

Title
**PRELIMINARY LAYOUT
MAP**

